

40 CFR 63 Subpart ZZZZ
Reciprocating Internal Combustion Engines
(RICE MACT)
Diversion Diesel Pump
Engine A (D-200A)

The Dow Chemical Company Michigan Operations Midland, MI

Quality Information

Prepared by



Randy Reinke Environmental Technician Checked by

James Edmister, PM Air Quality Scientist IV

Jamelie

Prepared for:

Chuck Glenn Air SME The Dow Chemical Company Freeport, Texas, 77541 T: 979.709.2307

E: cglenn@dow.ccom

Managed by:

Mr. James Edmister Project Manager

M: (585) 721-9128 (cell)

E: James.Edmister@aecom.com

AECOM 3700 James Savage Rd Midland, MI 48642 USA

www.aecom.com

<u>Please note</u>: The Dow process unit is the final copyholder and owner of this document. A temporary electronic copy will be retained by the AECOM test team for a short period of time.

Copyright © 2022 by AECOM

All rights reserved. No part of this copyrighted work may be reproduced, distributed, or transmitted in any form or by any means without the prior written permission of AECOM.

Table of Contents

1.	Intro	oduction	1		
	1.1	Summary of Test Program	1		
	1.2	Key Personnel			
2.	Plant and Sampling Location Description				
	2.1	Facility Description	3		
	2.2	Flue Gas Sampling Locations	3		
3.	Summary and Discussion of Test Results				
	3.1	Objectives and Test Matrix	4		
	3.2	Facility Operations	4		
	3.3	Test Results	4		
4.	Sam	pling and Analytical Procedures	5		
	4.1	Test Methods	5		
5 .	Cald	culations	7		
	5.1	Calibration Error - Equation 7E-1	7		
	5.2	System Bias - Equation 7E-2	8		
	5.3	System Drift - Equation 7E-4	9		
	5.4	Effluent Concentration - Equation 7E-5b	10		
	5.5	Effluent Concentration Corrected for Oxygen Concentration	11		
6.	Trailer Run Data				
	6.1	Outlet Oxygen Calibration Data Summary	12		
	6.2	Outlet Carbon Monoxide Calibration Data Summary	13		
	6.3	Inlet Oxygen Calibration Data Summary	14		
	6.4	Inlet Carbon Monoxide Calibration Data Summary	15		
	6.5	Response Time	16		
	6.6	Stratification Determination	17		
	6.7	Compliance Corrected Concentration	18		
	6.8	Compliance Summary	19		
	6.9	Summary Data	20		
7.	Cer	tificates of Analysis	70		
8.	Pro	cess Data	75		
Tab	les				
Table	3-1·	P200 Engine A Test Summary	4		
		P200 Engine A Test Run Data			
		P200 Engine A Process Data			
Fig	ure	\$			
Figure	∙e 4-1	: Sampling Train Used for CO & O ₂ (M10 & M3A)	6		
	→ T !	. Particularly from Pool of Co a cylinic addition in minimum minimum minimum minimum market and commission of the commis			

1. Introduction

1.1 Summary of Test Program

The Dow Chemical Company (Dow) in Midland, Michigan, is a large complex with manufacturing and utility plants. Dow's Michigan Operations (MiOps) is a major source of Hazardous Air Pollutants (HAPS).

AECOM was contracted to conducted compliance sampling on two 1050 horsepower (hp) non-emergency diesel engines (called Engine A and Engine B) to demonstrate compliance with the RICE MACT, 40CFR63, Subpart ZZZZ. The engines are operated to divert influent wastewater and storm water away from the onsite wastewater treatment plant (WWTP) to wastewater storage tanks for a variety of reasons. The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2c of the RICE MACT, 40CFR63, Subpart ZZZZ.

The following table summarizes the pertinent data for this compliance test:

Responsible Groups	 The Dow Chemical Company Michigan Department of Energy, Great Lakes, and Environment. (EGLE) Environmental Protection Agency (EPA) 		
Applicable Regulations	ROP- MI-A4033-2017b40 CFR 63 Subpart ZZZZ (RICE MACT)		
Industry / Plant	Environmental Operations Plant (EVO)		
Plant Location	The Dow Chemical Company Midland, MI, 48667		
Unit Installation Date	Engine A 6/2/2021Engine B 3/17/2022		
Unit Initial Compliance Date	Engine A 11/18/2021 Engine B TBD		
Air Pollution Control Equipment	 All engines are equiped with dual single stage catalytic reduction and closed crankcase filtration emission control system 		
Emission Points	P200 Diesel Engine A		
Pollutants/Diluent Measured	Carbon Monoxide (CO)Oxygen (O₂)		
Test Dates	May 17, 2022 (Engine A only)		

RECEIVED

JUL 06 2022

1.2 Key Personnel

Names and affiliations of personnel, including their roles in the test program, are summarized in the following table.

Role	Role Description	Name	Affiliation
Process Focal Point	 Coordinate plant operation during the test. Ensure the unit is operating at the agreed upon conditions in the test plan. Collect any process data required. Provide all technical support related to process operation. 	Morgan Raup	Dow Chemical
Environmental Focal Point	 Ensure all regulatory requirements and citations are reviewed and considered for the testing. 	Becky Meyerholt	Dow Chemical
Air SME	 Leadership of the sampling program. Develop the overall testing plan. Determine the correct sample methods. 	Chuck Glenn	Dow Chemical
Technical Reviewer	Completes technical review of the test data.	Rob Sava	AECOM
Field Team Leader	Ensures field sampling meets the quality assurance objectives of the plan.	Randy Reinke	AECOM
Sample Project Leader	Ensures data generated meets the quality assurance objectives of the plan.	James Edmister	AECOM

2. Plant and Sampling Location Description

2.1 Facility Description


Dow operates a chemical manufacturing facility in Midland, Michigan. Environmental Operations (EVO) operates two diesel 1050 hp engines to divert influent wastewater and storm water away from the on-site wastewater treatment plant (WWTP) to wastewater storage tanks for a variety of reasons.

Engine A completed its initial performance test on November 18, 2021. This report includes the results from the May 17, 2022 testing of Engine A only due to an equipment malfunction on Engine B. Engine B will be tested for its initial compliance test as soon as the equipment is operational.

The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2b of the RICE MACT, 40CFR63, Subpart ZZZZ.

2.2 Flue Gas Sampling Locations

Sampling was conducted on Engine A prior to and after the dual (in parallel) single stage catalytic reduction. Flue gas sample locations met the minimum guidelines for carbon monoxide (CO) and oxygen (O_2) sampling.



3. Summary and Discussion of Test Results

3.1 Objectives and Test Matrix

Under contract with Dow, Midland Operations, AECOM, Inc., conducted compliance sampling on the engines located at the Environmental Operations Plant (EVO) at Dow's Michigan Operations facility (MiOps). These engines are operated in non-emergency situations to manage wastewater and storm water at the MiOps site. The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2c. The specific objectives of this test were to:

Verify the scrubber reduction efficiency (SRE) for CO is greater than 70%.

3.2 Facility Operations

For engines >500HP the facility must:

- Minimize idle time at startup to <30 minutes
- Maintain the catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; AND
- Exhaust maintained such that 450°F ≥ catalyst inlet temperature ≤ 1350°F

During Engine A's initial performance test on November 18, 2021, the engine was operated at 96% load speed due to an operational limitation that has since been resolved. The test on Engine A that occurred on May 17, 2022, was operated without this limitation in place so the load speed was 100%

3.3 Test Results

Table 3-1: P200 Engine A Test Summary

SAMPLE TYPE	TEST METHOD	*ACTUAL EMISSION REDUCTION	REQUIRED EMISSION REDUCTION
CO Emissions (SRE)	EPA Method 10	95 %	70 %

^{*} Average over three one-hour runs.

Table 3-2: P200 Engine A Test Run Data

PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE
Sample Date	05/17/2022	05/17/2022	05/17/2022	
Sample Times (start/end)	10:05-11:05	11:35-12:35	13:05-14:05	
Outlet CO (ppmv @ 15% O ₂)	1.65	1.35	1.40	1.47
Inlet CO (ppmv @ 15% O ₂)	32.68	32.07	32.92	32,55
CO (SRE %)	95.0	95.8	95.7	95

Table 3-3: P200 Engine A Process Data

PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE		
Sample Date	05/17/2022	05/17/2022	05/17/2022			
Sample Times (start-end)	10:05-11:05	11:35-12:35	13:05-14:05			
Engine RPM (RPM)	1439	1414	1403	1418		
Engine Load Speed	100	100	100	100		
Fuel Consumed (% of Tank)	2.67	2.81	2.85	2.78		
Outlet Temp (Deg F)	165.4	166.7	166.7	166.3		
Catalyst A						
Catalyst Inlet Temp (Deg F)	755	753	762	757		
Differential Pressure (IWC)	22,6	22.6	22.5	22.6		
Catalyst B						
Catalyst Inlet Temp (Deg F)	759	759	767	762		
Differential Pressure (IWC)	21.3	21.3	21.2	21.3		

4. Sampling and Analytical Procedures

4.1 Test Methods

All sampling and analytical procedures are EPA published methods or methods allowed by 63.6610. This compliance test utilized the following methods:

- EPA Method 3A for O₂ Concentration
- EPA Method 10 for CO Concentration

Procedures

The above methods were performed using mobile continuous emission monitors provided by the AECOM internal testing team. Gas was withdrawn from the stack and transported to monitors located at ground level. A stainless-steel probe was inserted into the stack and used to collect sample gas. A Teflon sample line heated to 250°F transported sample gas from the probe to the analyzers. The analyzers were kept at a constant temperature inside the mobile laboratory.

Sample gas was collected continuously from the stack. At the mobile laboratory, the stack gas is routed to a condenser and then transported to the analyzers for analysis.

EPA Method 3A (Flue Gas Composition and Molecular Weight)

EPA Method 3A (Instrumental Method) was utilized to determine the diluent during each run on the outlet.

An analyzer measured O_2 content on the basis of the strong paramagnetic properties of O_2 relative to other compounds present in combustion gases. In the presence of a magnetic field, O_2 molecules become temporary magnets. The analyzer determines the sample gas O_2 concentration by detecting the displacement torque of the sample test body in the presence of a magnetic field.

EPA Method 10 (CO Sampling and Analysis)

EPA Method 10 was utilized to determine carbon monoxide concentrations during each run on the outlet.

An analyzer measured CO based on its absorption of infrared radiation. The infrared unit uses a single beam, single wavelength technique, with wavelength selection being achieved by a carefully specified narrow band optical filter making it highly selective for CO measurement in the presence of other infrared-absorbing gases.

System Bypass Oxygen Analyzer Stainless Steel Sample Probe Carbon Dioxide Analyzer Heated Teflon Sample Line (250°F) Carbon Monoxide Analyzer L:WABSIA-VIGRAPHICS_Figures\CEMS System_G Youngerman_CEMS System_Schematic Full System Sulfur Stack Dioxide Analyzer Nitrogen Oxide Analyzer Heated Teflon Sample Line (250°F) Heated Filter Calibration Error Line Refrigerated Condenser Heated Pump System Calibration Line Compressed Calibration Gases

Figure 4-1: SAMPLING TRAIN USED FOR CO & O₂ (M10 & M3A)