



**RECEIVED**

**JUL 03 2018**

**AIR QUALITY DIVISION**



REPORT ON COMPLIANCE  
TESTING

Detroit Refinery  
NHT Charge Heater Stack

Marathon Petroleum Company LP  
1300 South Fort Street  
Detroit, MI 48217  
Client Reference No. 4101379616

CleanAir Project No. 13551-3  
A2LA ISO 17025 Certificate No. 4342.01  
A2LA / STAC Certificate No. 4342.02  
Revision 0, Final Report  
June 18, 2018

**RECEIVED**

JUL 03 2018

AIR QUALITY DIVISION

# 1. PROJECT OVERVIEW

## Test Program Summary

Marathon Petroleum Company LP (MPC) contracted CleanAir Engineering (CleanAir) to successfully complete compliance testing at the Detroit Refinery. The test program included testing at the NHT Charge Heater (EU16-NHTCHARHTR-S-1) to demonstrate compliance with the Michigan Department of Environmental Quality (DEQ) Renewable Operating Permit No. MI-ROP-A9831-2012c.

A summary of the test program results is presented below. Section 2 Results provides a more detailed account of the test conditions and data analysis. Test program information, including the test parameters, on-site schedule and a project discussion, begins on page 2.

**Table 1-1:  
Summary of Results**

Source Constituent	Sampling Method (USEPA)	Average Emission	Permit Limit <sup>1</sup>
<u>NHT Charge Heater</u>			
NO <sub>x</sub> (lb/MMBtu)	M-7E	0.17	0.20

<sup>1</sup> Permit limits obtained from MDEQ Renewable Operating Permit No. MI-ROP-A9831-2012c.

## Test Program Details

### Parameters

The test program included the following measurements:

- oxygen (O<sub>2</sub>)
- carbon dioxide (CO<sub>2</sub>)
- nitrogen oxide (NO<sub>x</sub>)

### Schedule

Testing was performed on May 25, 2018. The on-site schedule followed during the test program is outlined in Table 1-2.

**Table 1-2:  
Test Schedule**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	NHT Charge Heater	USEPA Method 3A/7E	O <sub>2</sub> /NO <sub>x</sub>	05/25/18	10:15	11:15
2	NHT Charge Heater	USEPA Method 3A/7E	O <sub>2</sub> /NO <sub>x</sub>	05/25/18	11:21	12:21
3	NHT Charge Heater	USEPA Method 3A/7E	O <sub>2</sub> /NO <sub>x</sub>	05/25/18	12:32	13:32

## Discussion

### *Project Synopsis*

#### *NO<sub>x</sub> Emission Testing*

NO<sub>x</sub> emissions were determined using EPA Method 7E in conjunction with EPA Method 3A. NO<sub>x</sub> emissions results were calculated in units of pounds per million Btu (lb/MMBtu). Minute-average data points for O<sub>2</sub>, CO<sub>2</sub>, and NO<sub>x</sub> (dry basis) were collected over a period of 60 minutes for a total of three (3) runs. CO<sub>2</sub> concentrations were determined for supplemental purposes. A stratification check was performed during Run 1 and is presented in Appendix D of this report. The final results are expressed as an average of three (3) valid runs.

#### *Fuel Analysis*

Emission results in units of dry volume-based concentration (lb/dscf, ppm<sub>dv</sub>) were converted into units of pound per million Btu (lb/MMBtu) by calculating an oxygen-based fuel factor ( $F_d$ ) for refinery gas per EPA Method 19 specifications. The  $F_d$  factor was calculated from percent volume composition analytical data provided by MPC and tabulated heating values for each of the measured constituents.

#### *Test Conditions*

The unit was operated at the maximum normal operating capacity during each of the emissions compliance test runs. MPC was responsible for logging any relevant process-related data and providing it to CleanAir for inclusion in the test report.

---

*End of Section*

## 2. RESULTS

This section summarizes the test program results. Additional results are available in the report appendices, specifically Appendix C Parameters.

**Table 2-1:  
NHT Charge Heater – NO<sub>x</sub> Emissions**

Run No.		1	2	3	Average
Date (2018)		May 25	May 25	May 25	
Start Time (approx.)		10:15	11:21	12:32	
Stop Time (approx.)		11:15	12:21	13:32	
<b>Process Conditions</b>					
P <sub>1</sub>	NHT charge rate (bpd)	36,000	36,000	36,000	<b>36,000</b>
P <sub>2</sub>	Fuel Gas Flow (MSCF/D)	1,280	1,250	1,290	<b>1,273</b>
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	8,354	8,354	8,354	<b>8,354</b>
H <sub>i</sub>	Actual heat input (MMBtu/hr)	56	57	57	<b>56</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	4.0	4.1	4.1	<b>4.1</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.3	10.3	10.3	<b>10.3</b>
<b>Nitrogen Oxides Results</b>					
C <sub>sd</sub>	Concentration (ppmdv)	134.7	135.5	136.3	<b>135.5</b>
C <sub>sd</sub>	Concentration (lb/dscf)	1.61E-05	1.62E-05	1.63E-05	<b>1.62E-05</b>
E <sub>Fd</sub>	Emission Rate - F <sub>d</sub> -based (lb/MMBtu)	0.166	0.168	0.169	<b>0.168</b>

*End of Section*

### 3. DESCRIPTION OF INSTALLATION

#### Process Description

MPC's facility in Detroit, Michigan, produces refined petroleum products from crude oil. MPC must continue to demonstrate that select process units are in compliance with permitted emission limits.

The Naphtha Hydrotreater unit uses hydrogen to remove sulfur and nitrogen from straight-run and coker naphthas. This process, known as hydrotreating, uses a catalyst to promote the desulfurization reaction. The desulfurized or sweet naphtha is blended into gasoline or used for platformer feed. The NHT unit consists of process vessels (including exchangers, reactors, receivers, separators, and a stripper column), heaters, tanks, containers, pumps, piping, drains, and various components (pump seals, process valves, pressure relief valves, flanges, connectors, etc.).

The NHT Charge Heater (EU16-NHTCHARHTR-S1) preheats the feed to the reactor. The unit is fired by refinery fuel gas. Emissions are vented to the atmosphere via the NHT Charge Heater Stack (SV16-H4) where testing was performed.

#### Test Location


The sample point locations were determined by EPA Method 7E specifications. Table 3-1 presents the sampling information for the test location described in this report. The figure shown on page 5 represents the layout of the test location.

**Table 3-1:  
Sampling Information**

<u>Source</u> Constituent	Method (USEPA)	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
<u>NHT Charge Heater</u>							
O <sub>2</sub> /NO <sub>x</sub>	3A/7E	1 <sup>1</sup>	1	3	20	60	3-1
O <sub>2</sub> /NO <sub>x</sub>	3A/7E	2-3	1	1	60	60	3-1

<sup>1</sup> During Run 1, a stratification check was performed per Method 7E.

**Figure 3-1:  
 NO<sub>x</sub> Sample Point Layout (EPA Method 7E)**



Sampling Point	% of Stack Diameter	Port to Point Distance (inches)
1	83.3	45.4
2	50.0	27.3
3	16.7	9.1

Duct diameters upstream from flow disturbance (A): 2.9      Limit: 0.5  
 Duct diameters downstream from flow disturbance (B): 3.1      Limit: 2.0

End of Section

**RECEIVED**~~JUL 03 2018~~

## 4. METHODOLOGY

### AIR QUALITY DIVISION

#### Procedures and Regulations

---

The test program sampling measurements followed procedures and regulations outlined by the United States Environmental Protection Agency (USEPA) and the DEQ. These methods appear in detail in Title 40 of the CFR and at <https://www.epa.gov/emc>.

Appendix A includes diagrams of the sampling apparatus, as well as specifications for sampling, recovery, and analytical procedures. Any modifications to standard test methods are explicitly indicated in this appendix.

In accordance with ASTM D7036 requirements, CleanAir included a description of any such modifications, along with the full context of the objectives and requirements of the test program in the test protocol submitted prior to the measurement portion of this project. Modifications to standard methods are not covered by the ISO 17025 and TNI portions of CleanAir's A2LA accreditation.

CleanAir follows specific QA/QC procedures outlined in the individual methods and in USEPA "Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III Stationary Source-Specific Methods," EPA/600/R-94/038C. Appendix D contains additional QA/QC measures, as outlined in CleanAir's internal Quality Manual.

#### Title 40 CFR Part 60, Appendix A

- |           |   |
|-----------|---|
| Method 3A | "Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary                                       |
| Method 7E | "Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)"                         |
| Method 19 | "Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates" |

#### Methodology Discussion

---

##### O<sub>2</sub> and NO<sub>x</sub> Testing – USEPA Methods 3A and 7E

Reference method O<sub>2</sub> emissions were determined using a paramagnetic analyzer per EPA Method 3A. NO<sub>x</sub> emissions were determined using a chemiluminescent analyzer per EPA Method 7E.

Sample gas was extracted at a constant rate, conditioned to remove moisture and delivered to an analyzer bank which measured concentration on a dry basis (units of %dv or ppm<sub>dv</sub>).

Calibration error-checks were performed by introducing zero N<sub>2</sub>, high range and mid-range calibration gases to the inlet of each analyzer. Bias checks were performed before and after each sampling run by introducing calibration gas to the inlet of the sampling system's heated filter. Minute-average data points for O<sub>2</sub> and NO<sub>x</sub> (dry basis) were collected over a period of 60 minutes for each run. Per Methods 3A and 7E, the average results for each run were drift-corrected. An NO<sub>2</sub> conversion check was conducted per EPA Method 7E specifications.