



WASTE WATER TREATMENT PLANT
32360 Warkop
Warren, Michigan 48093
(586) 264-2530

David M. Monette
Division Head

October 24, 2018

Mr. Sebastian Kallumkal
MDEQ – Air Quality Division
Southeast Michigan District
27700 Donald Court
Warren, MI 48092-2793

RE: Notice of Intent to Retest the Emissions from the City of Warren Waste Water Treatment Plant Multi Hearth Sewage Sludge Incinerator

On June 12, 2018 the City of Warren Waste Water Treatment Plant performed its annual sewage sludge incinerator emission test. This testing was compliant with the test plan approved by the Air Quality Division in correspondence from Mr. Dziadosz dated June 4, 2018.

During that testing it was recognized that the output of oxides of nitrogen from the incinerator exceeded the permit limit for this pollutant as regulated in CFR 40 Part 60, Subpart M. The exceedance of the oxides of nitrogen limit occurred during the entire test period from 9:17 a.m. until 2:43 p.m.


Pursuant to your notice (attached) dated October 9, 2018 the MDEQ "AQD requests that Warren WWTP re-test the sewage sludge incinerator emissions for Carbon monoxide (CO) and Oxides of Nitrogen (NOx) with 60 days."

This correspondence shall serve as notification to the AQD that the Warren WWTP intends to perform the required compliance re-testing for CO and NOx in its incinerator emissions on Thursday December 6, 2018. Montrose Air Quality Services LLC will be the third party testing consultant on site that day to analyze the required pollutant emissions. Although the results of the testing will be known at the end of the required three 84 minute test runs, a complete compliance report will be issued to the AQD for review within 20 days of the required testing.

No additional testing plan has been required by the AQD and all sampling and testing will be performed in a manner consistent with the original test plan approved by Mr. Dziadosz earlier this year.


Should you have any questions regarding this notification treatment plant staff may be reached at (586) 264-2530.

Sincerely,
CITY OF WARREN



Todd Schaedig, P.E.
Facilities Engineer

Read and Concurred:



David Monette
Waste Water Superintendent

ts

attachment: October 9, 2018 Violation Notice

cc: Mayor Fouts
Richard Sabaugh, Public Service

Certified MAIL: 7013 3020 0000 5396 2087