

**EXECUTIVE SUMMARY**
**AIR QUALITY DIV.**

BT Environmental Consulting, Inc. (BTEC) was retained by Tetra Tech Inc. (Tetra Tech) to conduct a performance test in conformance with Michigan Rule 972 "Emissions Standards For Existing Sewage Sludge Incineration Units" and 40 CFR Part 60 Subpart MMMM. The test program consisted of sampling and analysis of stack exhaust gas concentrations and emission rates for filterable particulate matter (PM), multiple metals (Cd, Pb, and Hg), dioxins and furans (D/F), hydrogen chloride (HCl), carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>), and oxides of nitrogen (NO<sub>x</sub>) from the Incinerator exhaust stack located at the City of Warren Wastewater Treatment Plant (WWTP). The emissions test program was conducted on June 14-15, 2016.

Testing consisted of triplicate 84-minute test runs for PM and HCl, triplicate 120-minute test runs for metals and D/F, and triplicate approximate 120-minute test runs for CO, SO<sub>2</sub>, and NO<sub>x</sub>. The emissions test program was required by MDEQ Air Quality Division Renewable Operating Permit (ROP) No. MI-ROP-B1792-2016. The results of the emission test program are summarized by Table I.

**Table I**  
**Incinerator Overall Emission Summary**  
**Test Date: June 14-15, 2016**

<b>Pollutant</b>		<b>Emission Limit<sup>1</sup></b>	<b>Emission Rate<sup>1</sup></b>
PM		80 mg/dscm	2.5 mg/dscm
NO <sub>x</sub>		220 ppmv	203 ppmv
SO <sub>2</sub>		26 ppmv	2.9 ppmv
CO		3,800 ppmv	3,380 ppmv
Dioxins and Furans		5.0 ng/dscm total or 0.28 ng/dscm TEQ	4.8 ng/dscm total
			0.14 ng/dscm TEQ
Metals	Cadmium	0.095 mg/dscm	0.002 mg/dscm
	Lead	0.3 mg/dscm	0.008 mg/dscm
	Mercury	0.28 mg/dscm	0.029 mg/dscm
HCl		1.2 ppmv	0.4 ppmv

1: All emission limits and emission rates are corrected to 7% oxygen.

## 1. Introduction

BT Environmental Consulting, Inc. (BTEC) was retained by Tetra Tech Inc. (Tetra Tech) to conduct a performance test in conformance with Michigan Rule 972 "Emissions Standards For Existing Sewage Sludge Incineration Units" and 40 CFR Part 60 Subpart MMMM. The test program consisted of sampling and analysis of stack exhaust gas concentrations and emission rates for filterable particulate matter (PM), multiple metals (Cd, Pb, and Hg), dioxins and furans (D/F), hydrogen chloride (HCl), carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>), and oxides of nitrogen (NO<sub>x</sub>) from the Incinerator exhaust stack located at the City of Warren Wastewater Treatment Plant (WWTP). The emissions test program was conducted on June 14-15, 2016. The purpose of this report is to document the results of the test program.

AQD has published a guidance document entitled "Format for Submittal of Source Emission Test Plans and Reports" (December 2013). The following is a summary of the emissions test program and results in the format suggested by the aforementioned document.

### 1.a Identification, Location, and Dates of Test

Sampling and analysis for the emission test program was conducted on June 14-15, 2016 at the WWTP in Warren, Michigan. The test program included evaluation of NO<sub>x</sub>, CO, SO<sub>2</sub>, D/F, metals, PM, and HCl from the incinerator exhaust.

### 1.b Purpose of Testing

AQD issued Renewable Operating Permit No. MI-ROP-B1792-2016 to WWTP on June 15, 2016. This permit limits emissions from each turbine as summarized by Table 1.

**Table 1**  
**Existing Multiple Hearth Sewage Sludge Emission Limitations**

<b>Pollutant</b>	<b>Part 62 Subpart LLL Limit</b>
PM	80 mg/dscm
NO <sub>x</sub>	220 ppmV
SO <sub>2</sub>	26 ppmV
CO	3,800 ppmV
Dioxin and Furans	5.0 ng/dscm total or 0.28 ng/dscm TEQ
Metals	Cadmium 0.095 mg/dscm
	Lead 0.3 mg/dscm
	Mercury 0.28 mg/dscm
HCl	1.2 ppmV

All limits are corrected to 7% oxygen



### **1.c Source Description**

The City of Warren owns and operates a multiple hearth sewage sludge incinerator located in Warren, Michigan. The incinerator combusts natural gas and sewage sludge, a product of secondary and tertiary waste water treatment processes, also known as biosolids. The incinerator exhaust gases are passed through a wet scrubber prior to discharge to atmosphere.

### **1.d Test Program Contacts**

The contact for the source and test report is:

Mr. Todd Schaedig, P.E.  
Facility Engineer  
City of Warren Wastewater Treatment Plant  
32360 Warkrop Ave.  
Warren, MI 48093  
586-264-2530 ext 8203

Ms. Valerie Guenther P.E.  
Project Manager  
Tetra Tech Inc.  
710 Avis Drive, Suite 100  
Ann Arbor, Michigan 48108  
734-765-3984 (c) 734-213-4043 (w)

Mr. Barry P. Boulianne  
Senior Project Manager  
BT Environmental Consulting, Inc.  
4949 Fernlee Avenue  
Royal Oak, MI 48073  
313-449-2361

Names and affiliations for personnel who were present during the testing program are summarized by Table 2.

**Table 2**  
**Test Personnel**

<b>Name and Title</b>	<b>Affiliation</b>	<b>Telephone</b>
Ms. Valerie Guenther Project Manager	Tetra Tech Inc. 710 Avis Drive, Suite 100 Ann Arbor, Michigan 48108	(734) 765-3984
Mr. Matthew Young Project Manager	BTEC 4949 Fernlee Royal Oak, MI 48073	(248) 744-9133
Mr. Paul Diven Environmental Technician	BTEC 4949 Fernlee Royal Oak, MI 48073	(248) 548-8070
Mr. David Trahan Environmental Technician	BTEC 4949 Fernlee Royal Oak, MI 48073	(248) 548-8070
Mr. Mike Nummer Environmental Technician	BTEC 4949 Fernlee Royal Oak, MI 48073	(248) 548-8070
Mr. Jake Zott Environmental Technician	BTEC 4949 Fernlee Royal Oak, MI 48073	(248) 548-8070
Mr. Mark Dziadosz	MDEQ Air Quality Division	(586) 753-3745

## **2. Summary of Results**

Sections 2.a through 2.d summarize the results of the emissions compliance test program.

### **2.a Operating Data**

Process data monitored during the emissions test program included sludge feed rate in wet tons per hour, pH at the venturi stage drain, water flow in gpm and differential pressure in inches of water column across the VenturiPak unit and combustion chamber temperature of hearths 5, 6, & 7 in degrees Fahrenheit. The actual data that was recorded is compiled and averaged per the rule in Appendix F.

### **2.b Applicable Permit**

The applicable permit for this emissions test program is Renewable Operating Permit (ROP) No. MI-ROP-B1792-2016.

## **2.c Results**

The overall results of the emission test program are summarized by Table 3 (see Section 5.a). Detailed emission summaries can be found in Tables 4-6.

## **3. Source Description**

Sections 3.a through 3.e provide a detailed description of the process.

### **3.a Process Description**

The City of Warren owns and operates a multiple hearth sewage sludge incinerator located in Warren, Michigan. The incinerator combusts natural gas and sewage sludge, a product of secondary and tertiary waste water treatment processes, also known as biosolids. The incinerator exhaust gases are passed through a wet scrubber prior to discharge to atmosphere.

### **3.b Process Flow Diagram**

Due to the simplicity of the incinerator, a process flow diagram is not necessary.

### **3.c Raw and Finished Materials**

The process combusts dewatered biosolids which is fed to the incinerator at a maximum rate of 7 wet tons per hour, which is equivalent to an 85% feed rate of 6.4 wet tons per hour.

### **3.d Process Capacity**

The process combusts dewatered biosolids which is fed to the incinerator at a maximum rate of 7.5 wet tons per hour, which is equivalent to an 85% feed rate of 5.95 wet tons per hour.

### **3.e Process Instrumentation**

Process data monitored during the emissions test program included sludge feed rate in wet tons per hour, pH at the venturi stage drain, water flow in gpm and differential pressure in inches of water column across the VenturiPak unit and combustion chamber temperature of hearths 5, 6, & 7 in degrees Fahrenheit. The actual data that was recorded is compiled and averaged per the rule in Appendix F.

## **4. Sampling and Analytical Procedures**

Sections 4.a through 4.d provide a summary of the sampling and analytical procedures used.

#### **4.a Sampling Train and Field Procedures**

Sampling and analytical methodologies for the emissions test program were separated into five categories as follows:

- (1) Measurement of exhaust gas velocity, molecular weight, and moisture content;
- (2) Measurement of exhaust gas filterable PM and HCl concentration using USEPA Method 5/26A
- (3) Measurement of exhaust gas metals concentration using USEPA Method 29
- (4) Measurement of exhaust gas D/F concentration using USEPA Method 23
- (5) Measurement of exhaust gas O<sub>2</sub>, CO<sub>2</sub>, NO<sub>x</sub>, SO<sub>2</sub> and CO concentration using USEPA Method 3A/6C/7E/10

Sampling and analytical methodologies by category are summarized below.

##### **Exhaust Gas Velocity, Molecular Weight, and Moisture Content**

Stack gas velocity traverses were conducted in accordance with the procedures outlined in Method 1 and Method 2. S-type pitot tubes with thermocouple assemblies, calibrated in accordance with Method 2, Section 4.1.1, were used to measure exhaust gas velocity pressures (using a manometer) and temperatures during testing. The S-type pitot tube dimensions outlined in Sections 2-6 through 2-8 were within specified limits, therefore, a baseline pitot tube coefficient of 0.84 (dimensionless) was assigned. A diagram of the sample points is provided in Figure 1.

Cyclonic flow checks were performed at each sampling location. The existence of cyclonic flow is determined by measuring the flow angle at each sample point. The flow angle is the angle between the direction of flow and the axis of the stack. If the average of the absolute values of the flow angles is greater than 20 degrees, cyclonic flow exists. The null angle was determined to be less than 20 degrees at each sampling point.

The Molecular Weight of the gas stream was evaluated according to procedures outlined in Title 40, Part 60, Appendix A, Method 3A. The O<sub>2</sub>/CO<sub>2</sub> content of the gas stream was measured using an O<sub>2</sub>/CO<sub>2</sub> analyzer.

Exhaust gas was extracted as part of the sampling train. Exhaust gas moisture content was then determined gravimetrically.

##### **PM and HCl (USEPA Method 5/26A)**

40 CFR 60, Appendix A, Method 5, "*Determination of Particulate Emissions from Stationary*" and 40 CFR 60, Appendix A, Method 26A, "*Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources*" was used to measure PM and HCl concentrations and emission (see Figure 2 for a schematic of the sampling train).

BTEC's Nutech® Model 2010 modular isokinetic stack sampling systems consisted of (1) a glass nozzle, (2) a steel probe with glass liner, (3) a set of four Greenburg-Smith (GS) impingers with the first and third modified and second standard GS impingers, the first two containing 100 ml 0.1N H<sub>2</sub>SO<sub>4</sub>, the third empty, and a fourth modified GS impinger containing approximately 300 g of silica gel desiccant, (5) a length of sample line, and (6) a CleanAir® control case equipped with a pump, dry gas meter, and calibrated orifice.

A sampling train leak test was conducted before and after each test run. After completion of the final leak test for each test run, the filter was recovered, and the probe, nozzle and the front half of the filter holder assembly were brushed and triple rinsed with acetone. The acetone rinses were collected in a pre-cleaned sample container. The impinger catch solution was then transferred to pre-cleaned sample containers. The impingers were then triple rinsed with deionized water (DI H<sub>2</sub>O), and the rinses added to the H<sub>2</sub>SO<sub>4</sub> sample containers. The back-half of the filter holder was rinsed and added to the H<sub>2</sub>SO<sub>4</sub> sample container. The containers were labeled with the test number, test location, test date, and the level of liquid was marked on the outside of each container.

#### **Metals (USEPA Method 29)**

40 CFR 60, Appendix A, Method 29, "Determination of Metals Emissions From Stationary Sources" was used to measure metals concentrations and calculate appropriate emission rates (see Figure 3 for a schematic of the sampling train).

BTEC's Nutech® Model 2010 modular isokinetic stack sampling system consisted of (1) a Teflon coated stainless steel nozzle, (2) a glass probe, (3) six Greenburg-Smith (GS) impingers with the first two filled with 100 ml of a 5% HNO<sub>3</sub> / 10% H<sub>2</sub>O<sub>2</sub> solution, an empty impinger, then two with 100 ml of a 4% KMnO<sub>4</sub> / 10% H<sub>2</sub>SO<sub>4</sub> solution, and a modified impinger filled with approximately 300 grams of silica gel. (4) a length of sample line, and (5) a Nutech® control case equipped with a pump, dry gas meter, and calibrated orifice.

Upon completion of the final leak test for each test run, the filter was recovered, and the nozzle and the front half of the filter holder assembly were brushed and triple rinsed with 100 ml of 0.1N HNO<sub>3</sub>. The rinses were collected in a pre-cleaned sample container and prepared for transport.

The back half of the filter housing and first three impingers were triple rinsed with 100 ml of 0.1N HNO<sub>3</sub>. The fourth impinger (empty) was rinsed with 100 ml of 0.1N HNO<sub>3</sub>. The fifth and sixth impingers were triple rinsed with 100 ml of KMnO<sub>4</sub>, followed by a triple rinse with 100 ml of H<sub>2</sub>O and placed in their respective sample containers. The impingers were then triple rinsed with 25 ml of 8N HCl and placed in sample container with 200 ml H<sub>2</sub>O.

### **Dioxins and Furans (USEPA Method 23)**

40 CFR 60, Appendix A, Method 23, "Determination of Polychlorinated Dibenzo-p-dioxins and Polychlorinated Dibenzofurans from Municipal Waste Combustors" was used to evaluate CDD/CDF concentrations (see Figure 4 for a schematic of the sampling train).

The Method 23 sampling train consisted of (1) a borosilicate glass or quartz nozzle, (2) a steel probe w/ glass liner, (3) a heated quartz fiber filter assembly, (4) a glass recirculating ice water condenser system, (5) a XAD-2 sorbent trap, (6) an empty pot bellied impinger, (7) a set of four GS impingers, (8) a length of sample line, and (9) a Nutech® control case equipped with a pump, dry gas meter, and calibrated orifice.

Prior to each test, the first and second impingers were filled with 100 ml of HPLC water, the third impinger was empty, and the fourth impinger contained approximately 300 g of silica gel desiccant.

Upon completion of the final leak test for each test run, the filter was recovered, and the nozzle and the front half of the filter holder assembly were brushed and triple rinsed with Acetone and MeCl<sub>2</sub>. The rinses were collected in a pre-cleaned sample container.

The back half of the filter housing was rinsed with acetone and MeCl<sub>2</sub>. The Condenser was soaked in MeCl<sub>2</sub> for 5 minutes with three separate portions and recovered into the pre-cleaned sample container. A repeat of this rinse method using toluene was performed and added to the sample container.

### **O<sub>2</sub>, CO<sub>2</sub>, NO<sub>x</sub>, SO<sub>2</sub> and CO (USEPA Method 3A/6C/7E/10)**

The NO<sub>x</sub> content of the gas stream was measured using a Thermo Model 42i NO<sub>x</sub> gas analyzer. The CO content of the gas stream was measured using a TECO 48 CO gas analyzer. The SO<sub>2</sub> content was measured using a Western Research SO<sub>2</sub> gas analyzer. The O<sub>2</sub>/CO<sub>2</sub> content was measured using a Servomex 4000 gas analyzer. The gas stream was drawn through a stainless-steel probe with a heated in-line filter to remove any particulate, a heated Teflon® sample line, through a refrigerated Teflon® sample conditioner to remove the moisture from the sample before it entered the gas analyzers. Data was recorded on a PC equipped with data acquisition software. Recorded NO<sub>x</sub> concentrations were averaged and reported for the duration of each test (as drift corrected per Method 7E). A drawing of the sampling train used for the testing program is presented as Figure 5.

In accordance with Method 7E, a 4-point (zero, low, mid, and high) bias check and calibration check was performed on the analyzer prior to initiating the test program. Following each test run, a 2-point (zero and high) calibration drift check was performed. The NO<sub>x</sub> analyzer was operated at the 0-500 ppm range. The CO analyzer was operated at the 0-5000 ppm range. The SO<sub>2</sub> analyzer was operated in the 0-100 ppm range.



#### 4.b Recovery and Analytical Procedures

Descriptions of the recovery procedures are provided in section 4.a for each sampling method.

#### 4.c Sampling Ports

A diagram of the stack showing sampling ports in relation to upstream and downstream disturbances is included as Figure 1.

#### 4.d Traverse Points

A diagram of the stack indicating traverse point locations and stack dimensions is included as Figure 1

### 5. Test Results and Discussion

Sections 5.a through 5.k provide a summary of the test results.

#### 5.a Results Tabulation

The overall results of the emissions test program are summarized by Table 3. Detailed results for the emissions test program are summarized by Tables 4 through 6.

**Table 3**  
**Incinerator Overall Emission Summary**  
**Test Date: June 14-15, 2016**

Pollutant		Emission Limit <sup>1</sup>	Emission Rate <sup>1</sup>
PM		80 mg/dscm	2.5 mg/dscm
NO <sub>x</sub>		220 ppmv	203 ppmv
SO <sub>2</sub>		26 ppmv	2.9 ppmv
CO		3,800 ppmv	3,380 ppmv
Dioxins and Furans		5.0 ng/dscm total or	4.8 ng/dscm total
		0.28 ng/dscm TEQ	0.14 ng/dscm TEQ
Metals	Cadmium	0.095 mg/dscm	0.002 mg/dscm
	Lead	0.3 mg/dscm	0.008 mg/dscm
	Mercury	0.28 mg/dscm	0.029 mg/dscm
HCl		1.2 ppmv	0.4 ppmv

1: All emission limits and emission rates are corrected to 7% oxygen.

#### 5.b Discussion of Results

All emissions are below their corresponding limits.

### **5.c Sampling Procedure Variations**

On June 14 during Run 1 of the PM/HCl testing the computer recording CEM data crashed and consequently all CEM data for the run was lost. The drift corrected oxygen values measured for Run 2 and Run 3 were averaged together and used for Run 1 in order to calculate PM and HCl emission rates corrected to 7% oxygen.

A blank correction was not applied to the Method 29 results. The uncorrected laboratory results bias the metals concentrations high, but the results are over an order of magnitude below the corresponding emission limit, therefore blank correction is not necessary.

### **5.d Process or Control Device Upsets**

No upset conditions occurred during testing.

### **5.e Control Device Maintenance**

There was no control equipment maintenance performed during the emissions test program.

### **5.f Re-Test**

The emissions test program was not a re-test.

### **5.g Audit Sample Analyses**

An audit sample for cadmium, lead, and mercury was sent to Maxxam for analysis.

### **5.h Calibration Sheets**

Relevant equipment calibration documents are provided in Appendix B.

### **5.i Sample Calculations**

Sample calculations are provided in Appendix C.

### **5.j Field Data Sheets**

Field documents relevant to the emissions test program are presented in Appendix A

### **5.k Laboratory Data**

Laboratory analytical results are presented in Appendix E. Raw CEM data is provided electronically in Appendix D.

**Table 4**  
**Incinerator Particulate Matter and HCl Emission Rates**

Company Source Designation Test Date	WWTP Incinerator			Average
	6/14/2016	6/14/2016	6/14/2016	
Test Run Time	10:06-11:36	12:20-13:52	14:35-16:04	
<b>Meter/Nozzle Information</b>	<b>P-1</b>	<b>P-2</b>	<b>P-3</b>	
Meter Temperature Tm (F)	78.5	82.3	81.3	80.7
Meter Pressure - Pm (in. Hg)	29.6	29.6	29.6	29.6
Measured Sample Volume (Vm)	84.2	90.6	82.6	85.8
Sample Volume (Vm-Std ft3)	81.4	87.1	79.4	82.7
Sample Volume (Vm-Std m3)	2.31	2.47	2.25	2.34
Condensate Volume (Vw-std)	2.980	3.753	3.574	3.436
Gas Density (Ps(std) lbs/ft3) (wet)	0.0762	0.0760	0.0759	0.0760
Gas Density (Ps(std) lbs/ft3) (dry)	0.0772	0.0772	0.0772	0.0772
Total weight of sampled gas (m g lbs) (wet)	6.43	6.90	6.30	6.54
Total weight of sampled gas (m g lbs) (dry)	6.29	6.73	6.13	6.38
Nozzle Size - An (sq. ft.)	0.001336	0.001336	0.001336	0.001336
Isokinetic Variation - I	101.8	100.9	101.1	101.3
<b>Stack Data</b>				
Average Stack Temperature - Ts (F)	89.3	94.8	96.3	93.4
Molecular Weight Stack Gas- dry (Md)	29.9	29.9	29.9	29.9
Molecular Weight Stack Gas-wet (Ms)	29.5	29.4	29.4	29.4
Stack Gas Specific Gravity (Gs)	1.018	1.015	1.014	1.016
Percent Moisture (Bws)	3.53	4.13	4.31	3.99
Water Vapor Volume (fraction)	0.0353	0.0413	0.0431	0.0399
Pressure - Ps ("Hg)	29.3	29.3	29.3	29.3
Average Stack Velocity - Vs (ft/sec)	13.1	14.3	13.1	13.5
Area of Stack (ft2)	12.4	12.4	12.4	12.4
Oxygen (%)	10.71	11.93	9.49	10.7
<b>Exhaust Gas Flowrate</b>				
Flowrate ft <sup>3</sup> (Actual)	9,740	10,685	9,762	10,062
Flowrate ft <sup>3</sup> (Standard Wet)	9,181	9,971	9,085	9,412
Flowrate ft <sup>3</sup> (Standard Dry)	8,857	9,559	8,694	9,037
Flowrate m <sup>3</sup> (standard dry)	251	271	246	256
<b>Total Particulate Weights (mg)</b>				
Nozzle/Probe/Filter	4.1	6.4	1.9	4.1
<b>Total Particulate Concentration</b>				
lb/1000 lb (wet)	0.001	0.002	0.001	0.001
lb/1000 lb (dry)	0.001	0.002	0.001	0.001
mg/dscm (dry)	1.8	2.6	0.8	1.7
mg/dscm (dry) @7%O2	2.4	4.0	1.0	2.5
gr/dscf	0.0008	0.0011	0.0004	0.0008
<b>Total Particulate Emission Rate</b>				
lb/ hr	0.06	0.09	0.03	0.06
<b>Total HCl Weight (ug)</b>				
Sample Catch	910.00	980.00	870.00	920.00
Blank correction	0.00	0.00	0.00	0.00
Total	910.00	980.00	870.00	920.00
<b>Total HCl Concentration</b>				
lb/1000 lb (dry)	0.0003	0.0003	0.0003	0.0003
mg/dscm (dry)	0.4	0.4	0.4	0.4
PPMV (dry)	0.3	0.3	0.3	0.3
PPMV (dry) @7%O2	0.4	0.4	0.3	0.4
<b>Total HCl Emission Rate</b>				
lb/ hr	0.01	0.01	0.01	0.01

**Table 5**  
**Incinerator Metals Emission Rates**

Company Source Designation Test Date	WWWTP Incinerator 6/15/2016	6/15/2016	6/15/2016	
Test Run Time	9:59-12:07	13:14-15:21	16:05-18:11	
<b>Meter/Nozzle Information</b>	P-1	P-2	P-3	Average
Meter Temperature Tm (F)	80.0	92.3	94.8	89.0
Meter Pressure - Pm (in. Hg)	29.4	29.4	29.4	29.4
Measured Sample Volume (Vm)	111.4	112.7	114.7	113.0
Sample Volume (Vm-Std ft3)	106.5	105.3	106.7	106.2
Sample Volume (Vm-Std m3)	3.02	2.98	3.02	3.01
Condensate Volume (Vw-std)	3.249	2.754	3.895	3.299
Gas Density (Ps(std) lbs/ft3) (wet)	0.0764	0.0765	0.0762	0.0764
Gas Density (Ps(std) lbs/ft3) (dry)	0.0773	0.0773	0.0773	0.0773
Total weight of sampled gas (m g lbs) (wet)	8.39	8.27	8.43	8.36
Total weight of sampled gas (m g lbs) (dry)	8.23	8.14	8.25	8.21
Nozzle Size - An (sq. ft.)	0.001315	0.001315	0.001315	0.001315
Isokinetic Variation - I	99.9	99.6	101.1	100.2
<b>Stack Data</b>				
Average Stack Temperature - Ts (F)	91.9	98.6	96.3	95.6
Molecular Weight Stack Gas- dry (Md)	29.9	29.9	29.9	29.9
Molecular Weight Stack Gas-wet (Ms)	29.6	29.6	29.5	29.6
Stack Gas Specific Gravity (Gs)	1.021	1.023	1.019	1.021
Percent Moisture (Bws)	2.96	2.55	3.52	3.01
Water Vapor Volume (fraction)	0.0296	0.0255	0.0352	0.0301
Pressure - Ps ("Hg)	29.2	29.2	29.2	29.2
Average Stack Velocity - Vs (ft/sec)	12.4	12.4	12.5	12.4
Area of Stack (ft2)	12.4	12.4	12.4	12.4
Oxygen (%)	11.25	11.08	11.08	11.1
<b>Exhaust Gas Flowrate</b>				
Flowrate ft <sup>3</sup> (Actual)	9,271	9,264	9,299	9,278
Flowrate ft <sup>3</sup> (Standard Wet)	8,655	8,545	8,614	8,605
Flowrate ft <sup>3</sup> (Standard Dry)	8,399	8,327	8,311	8,346
Flowrate m <sup>3</sup> (standard dry)	238	236	235	236
<b>Total Metals Weights (ug)</b>				
Cadmium	4.0	4.3	4.5	4.3
Lead	15.4	16.8	18.6	16.9
Mercury	50.8	68.5	65.2	61.5
<b>Cadmium Concentrations</b>				
lb/1000 lb (wet)	1.05E-06	1.14E-06	1.19E-06	1.12E-06
lb/1000 lb (dry)	1.07E-06	1.16E-06	1.21E-06	1.14E-06
mg/dscm (dry)	1.32E-03	1.43E-03	1.50E-03	1.42E-03
mg/dscm (dry) @7%O2	1.90E-03	2.03E-03	2.13E-03	2.02E-03
gr/dscf	5.77E-07	6.26E-07	6.57E-07	6.20E-07
<b>Cadmium Emission Rate</b>				
lb/ hr	4.17E-05	4.48E-05	4.69E-05	4.45E-05
<b>Lead Concentrations</b>				
lb/1000 lb (wet)	4.05E-06	4.48E-06	4.86E-06	4.46E-06
lb/1000 lb (dry)	4.12E-06	4.55E-06	4.97E-06	4.55E-06
mg/dscm (dry)	5.11E-03	5.63E-03	6.16E-03	5.63E-03
mg/dscm (dry) @7%O2	7.36E-03	7.97E-03	8.71E-03	8.01E-03
gr/dscf	2.23E-06	2.46E-06	2.69E-06	2.46E-06
<b>Lead Emission Rate</b>				
lb/ hr	1.61E-04	1.76E-04	1.92E-04	1.77E-04
<b>Mercury Concentrations</b>				
lb/1000 lb (wet)	1.34E-05	1.83E-05	1.70E-05	1.62E-05
lb/1000 lb (dry)	1.36E-05	1.86E-05	1.74E-05	1.65E-05
mg/dscm (dry)	1.69E-02	2.30E-02	2.16E-02	2.05E-02
mg/dscm (dry) @7%O2	2.43E-02	3.25E-02	3.05E-02	2.91E-02
gr/dscf	7.37E-06	1.00E-05	9.43E-06	8.95E-06
<b>Mercury Emission Rate</b>				
lb/ hr	5.32E-04	7.20E-04	6.74E-04	6.42E-04

**Table 6A**  
**Incinerator Dioxins and Furans Emission Rates**

Company	WWTP			
Source Designation	Incinerator			
Test Date	6/15/2016	6/15/2016	6/15/2016	
Meter/Nozzle Information	P-1	P-2	P-3	Average
Meter Temperature Tm (F)	70.8	80.2	82.1	77.7
Meter Pressure - Pm (in. Hg)	29.4	29.4	29.4	29.4
Measured Sample Volume (Vm)	107.7	110.4	107.9	108.7
Sample Volume (Vm-Std ft3)	105.0	105.8	103.0	104.6
Sample Volume (Vm-Std m3)	2.97	2.99	2.92	2.96
Condensate Volume (Vw-std)	3.598	4.267	4.305	4.056
Gas Density (Ps(std) lbs/ft3) (wet)	0.0763	0.0761	0.0761	0.0762
Gas Density (Ps(std) lbs/ft3) (dry)	0.0773	0.0773	0.0773	0.0773
Total weight of sampled gas (m g lbs) (wet)	8.28	8.38	8.17	8.28
Total weight of sampled gas (m g lbs) (dry)	8.12	8.18	7.97	8.09
Nozzle Size - An (sq. ft.)	0.001336	0.001336	0.001336	0.001336
Isokinetic Variation - I	100.3	100.4	101.1	100.6
Stack Data				
Average Stack Temperature - Ts (F)	90.4	96.2	94.0	93.5
Molecular Weight Stack Gas- dry (Md)	29.9	29.9	29.9	29.9
Molecular Weight Stack Gas-wet (Ms)	29.5	29.5	29.4	29.5
Stack Gas Specific Gravity (Gs)	1.020	1.017	1.017	1.018
Percent Moisture (Bws)	3.31	3.88	4.01	3.73
Water Vapor Volume (fraction)	0.0331	0.0388	0.0401	0.0373
Pressure - Ps ("Hg)	29.2	29.2	29.2	29.2
Average Stack Velocity - Vs (ft/sec)	12.0	12.3	11.9	12.1
Area of Stack (ft2)	12.4	12.4	12.4	12.4
Exhaust Gas Flowrate				
Flowrate ft <sup>3</sup> (Actual)	8,963	9,172	8,842	8,992
Flowrate ft <sup>3</sup> (Standard Wet)	8,391	8,497	8,224	8,371
Flowrate ft <sup>3</sup> (Standard Dry)	8,113	8,167	7,895	8,058
Flowrate m <sup>3</sup> (standard dry)	230	231	224	228

Table 6B  
Incinerator Dioxins and Furans Emission Rates  
Tetra Tech (WVWTP)  
Warren, Michigan  
BTEC Project No. 16-4839.00  
Sampling Date: June 15, 2016

RECEIVED  
NOV 17 2016  
AIR QUALITY DIV.

Parameter	Compound Toxic Equivalency	Run 1	Run 2	Run 3	Average
Test Run Date		6/15/2016	6/15/2016	6/15/2016	
Test Run Time		9:59-12:07	13:14-15:21	16:05-18:11	
Sample Volume (dscfm)		105.0	105.8	103.0	104.6
O <sub>2</sub> Concentration (%)		11.25	11.08	11.08	11.14
<b>Laboratory Results (pg)</b>					
2378-TCDD		41.8	31.7	56.6	43.4
12378-PeCDD		4.7	6.3	6.3	5.8
123478-HxCDD		0.0	0.0	2.2	0.7
123678-HxCDD		7.6	7.6	9.0	8.1
123789-HxCDD		5.4	6.5	7.0	6.3
1234678-HpCDD		15.7	18.4	18.5	17.5
OCDD		42.9	50.4	47.1	46.8
Total Tetra CDD		83.3	267.0	586.0	1363.0
Total Penta CDD		150	212.0	194.0	185.3
Total Hexa CDD		25.7	34.1	40.5	33.4
Total Hepta CDD		27.3	31.7	36.9	32.0
<b>Total Dioxins</b>		<b>1678.9</b>	<b>2998.2</b>	<b>934.5</b>	<b>1660.5</b>
2378-TCDF		1440.0	2250.0	1950.0	1860.0
12378-PeCDF		216.0	228.0	217.0	220.3
123478-HxCDF		0.0	0.0	0.0	0.0
123678-HxCDF		262.0	226.0	270.0	252.7
1234678-HpCDF		90.0	79.8	97.5	89.1
OCDF		146.0	126.0	183.0	151.7
Total Tetra CDF		4.7	3.8	4.8	4.4
Total Penta CDF		47.6	43.5	53.0	48.0
Total Hexa CDF		6.6	6.0	6.5	6.4
Total Hepta CDF		0.0	7.8	7.7	5.2
<b>Total Furans</b>		<b>3350</b>	<b>4520.0</b>	<b>3930.0</b>	<b>3933.3</b>
Concentrations (ng/dscfm) - corrected to 7% O <sub>2</sub> , No TEQ applied		3510	3730.0	3120.0	3453.3
2378-TCDD	NA	2.0E-02	1.5E-02	2.7E-02	2.1E-02
12378-PeCDD	NA	2.5E-03	3.6E-03	3.1E-03	2.8E-03
123478-HxCDD	NA	0.0E+00	0.0E+00	1.1E-03	3.6E-04
123678-HxCDD	NA	3.7E-03	3.6E-03	4.4E-03	3.9E-03
123789-HxCDD	NA	2.6E-03	3.1E-03	3.4E-03	3.0E-03
1234678-HpCDD	NA	7.6E-03	8.7E-03	9.0E-03	8.4E-03
OCDD	NA	2.1E-02	2.4E-02	2.3E-02	2.2E-02
Total Tetra CDD	NA	4.0E-01	1.3E+00	2.8E-01	6.5E-01
Total Penta CDD	NA	7.3E-02	1.0E-01	9.4E-02	8.9E-02
Total Hexa CDD	NA	1.2E-02	1.6E-02	2.0E-02	1.6E-02
Total Hepta CDD	NA	1.3E-02	1.5E-02	1.8E-02	1.5E-02
<b>Total Dioxins</b>		<b>5.2E-01</b>	<b>1.4E+00</b>	<b>4.4E-01</b>	<b>7.9E-01</b>
2378-TCDF	NA	7.0E-01	1.1E+00	9.3E-01	9.0E-01
12378-PeCDF	NA	1.0E-01	1.0E-01	1.1E-01	1.1E-01
123478-HxCDF	NA	0.0E+00	0.0E+00	0.0E+00	0.0E+00
123678-HxCDF	NA	1.3E-01	1.1E-01	1.3E-01	1.2E-01
1234678-HpCDF	NA	4.4E-02	3.8E-02	4.7E-02	4.3E-02
OCDF	NA	7.1E-02	6.0E-02	8.9E-02	7.3E-02
Total Tetra CDF	NA	2.3E-03	1.8E-03	2.3E-03	2.1E-03
Total Penta CDF	NA	2.3E-02	2.1E-02	2.6E-02	2.3E-02
Total Hexa CDF	NA	3.2E-03	2.8E-03	3.2E-03	3.1E-03
Total Hepta CDF	NA	0.0E+00	3.7E-03	3.7E-03	2.5E-03
<b>Total Furans</b>		<b>1.6E+00</b>	<b>2.1E+00</b>	<b>1.9E+00</b>	<b>1.9E+00</b>
Concentrations (ng/dscfm) - Corrected to 7% O <sub>2</sub>		<b>1.7E+00</b>	<b>1.8E+00</b>	<b>1.5E+00</b>	<b>1.7E+00</b>
2378-TCDD	NA	4.6E-01	3.9E-01	4.8E-01	4.4E-01
12378-PeCDD	NA	3.6E-02	3.3E-02	4.0E-02	3.6E-02
123478-HxCDD	NA	3.8E+00	4.3E+00	3.9E+00	4.0E+00
123678-HxCDD	NA	4.3E+00	5.7E+00	4.4E+00	4.8E+00
123789-HxCDD	NA	4.3E+00	5.7E+00	4.4E+00	4.8E+00
1234678-HpCDD	NA	4.3E+00	5.7E+00	4.4E+00	4.8E+00
OCDD	NA	4.3E+00	5.7E+00	4.4E+00	4.8E+00
<b>Total Dioxins and Furans Totals</b>		<b>4.3E+00</b>	<b>5.7E+00</b>	<b>4.4E+00</b>	<b>4.8E+00</b>
<b>Concentrations (ng/dscfm) - Corrected to 7% O<sub>2</sub></b>					
2378-TCDD	0.1	2.0E-02	1.5E-02	2.7E-02	2.1E-02
12378-PeCDD	0.1	2.5E-03	3.6E-03	3.1E-03	2.8E-03
123478-HxCDD	0.1	0.0E+00	0.0E+00	1.1E-03	3.6E-04
123678-HxCDD	0.1	3.7E-03	3.6E-03	4.4E-03	3.9E-03
123789-HxCDD	0.1	2.6E-03	3.1E-03	3.4E-03	3.0E-03
1234678-HpCDD	0.01	7.6E-03	8.7E-03	9.0E-03	8.4E-03
OCDD	0.0003	6.2E-06	7.1E-06	6.9E-06	6.7E-06
<b>Dioxins Totals</b>		<b>2.3E-02</b>	<b>1.9E-02</b>	<b>3.2E-02</b>	<b>2.4E-02</b>
2378-TCDF	0.1	7.0E-02	1.1E-01	9.3E-02	9.0E-02
12378-PeCDF	0.03	1.1E-03	3.2E-03	3.2E-03	3.2E-03
123478-HxCDF	0.3	0.0E+00	0.0E+00	0.0E+00	0.0E+00
123678-HxCDF	0.1	1.3E-02	1.1E-02	1.3E-02	1.2E-02
1234678-HpCDF	0.1	4.4E-03	3.8E-03	4.7E-03	4.3E-03
OCDF	0.1	7.1E-03	6.0E-03	8.9E-03	7.3E-03
Total Tetra CDF	0.1	2.3E-04	1.8E-04	2.3E-04	2.1E-04
Total Penta CDF	0.01	2.3E-04	2.1E-04	2.6E-04	2.3E-04
Total Hexa CDF	0.01	3.2E-05	2.8E-05	3.2E-05	3.1E-05
Total Hepta CDF	0.0003	0.0E+00	1.1E-06	1.1E-06	7.4E-07
<b>Furans Totals</b>		<b>9.8E-02</b>	<b>1.3E-01</b>	<b>1.3E-01</b>	<b>1.2E-01</b>
<b>Dioxins and Furans Totals</b>		<b>1.2E-01</b>	<b>1.5E-01</b>	<b>1.6E-01</b>	<b>1.4E-01</b>

Note: values in Bold are below RDL (reportable detection limit) and have been reported as zero as per USEPA Method 23

dscfm = dry standard cubic feet per minute (corrected to 528°R, 29.92 in H<sub>2</sub>O)

dscfm = dry standard cubic feet (corrected to 528°R, 29.92 in H<sub>2</sub>O)

35.31 = conversion, from m<sup>3</sup> to ft<sup>3</sup>

1000 = conversion, from ng to pg

lb/hr = pounds per hour

O<sub>2</sub> = oxygen concentration, %

60 = conversion from hr to minutes

Equations

(ng/dscfm @ 7% O<sub>2</sub>) = (Lab Result/1000) \* (13.9/(20.9-O<sub>2</sub>)) / (Sample Volume \* (1/35.31))

(ng/dscfm @ 7% O<sub>2</sub>) = TEF \* (Lab Result/1000) \* (13.9/(20.9-O<sub>2</sub>)) / (Sample Volume \* (1/35.31))

**Table 7**  
**Incinerator NO<sub>x</sub>, SO<sub>2</sub>, CO Concentrations**  
**Tetra Tech**  
**Warren, Michigan**  
**BTEC Project No. 16-4839**  
**Sampling Dates: June 14-15, 2016**

Parameter	Run 1	Run 2	Run 3	Average
Test Run Date	6/15/2016	6/15/2016	6/15/2016	
Test Run Time	14:05-15:27	15:57-17:18	17:34-18:56	
Oxygen Concentration (%)	11.35	11.13	11.10	11.19
Oxygen Concentration (%; drift corrected as per USEPA 7E)	11.25	11.08	11.08	11.14
Carbon Dioxide Concentration (%)	6.86	7.05	6.76	6.89
Carbon Dioxide Concentration (%; drift corrected as per USEPA 7E)	6.76	6.97	6.68	6.80
Outlet Oxides of Nitrogen Concentration (ppmv)	129.38	139.62	156.85	141.95
Outlet NO <sub>x</sub> Concentration (ppmv, corrected as per USEPA 7E)	129.35	139.70	158.38	142.48
Outlet NO <sub>x</sub> Concentration (ppmv, corrected to 7% O <sub>2</sub> )	186.32	197.74	224.18	202.75
Outlet Carbon Monoxide Concentration (ppmv)	3,010.43	2,048.93	2,061.91	2,373.76
Outlet CO Concentration (ppmv, corrected as per USEPA 7E)	3,026.33	2,042.94	2,040.71	2,369.99
Outlet CO Concentration (ppmv, corrected to 7% O <sub>2</sub> )	4,359.17	2,891.74	2,888.58	3,379.83
Outlet Sulfur Dioxide Concentration (ppmv)	1.00	-0.06	-0.37	0.19
Outlet SO <sub>2</sub> Concentration (ppmv, corrected as per USEPA 7E)	1.93	1.81	2.37	2.04
Outlet SO <sub>2</sub> Concentration (ppmv, corrected to 7 % O <sub>2</sub> )	2.78	2.56	3.35	2.90



ppmv = parts per million on a volume-to-volume basis

#### Equations

$$\text{Conc}_{@7\%O_2} = \text{Conc} * (20.9 - 7) / (20.9 - \%O_2)$$



diameter = 49.25 inches



Not to Scale

Points	Distance "
1	1.0
2	3.3
3	5.8
4	8.7
5	12.3
6	17.5
7	31.7
8	36.9
9	40.5
10	43.4
11	46.0
12	48.2

Figure No. 1

Site:  
Incinerator Exhaust  
WWTP  
Warren, Michigan

Sampling Date:  
June 14-15, 2016

BT Environmental Consulting, Inc.  
4949 Fernlee Avenue  
Royal Oak, Michigan 48073






Figure No. 2

Site:  
USEPA Method 5/26A  
WWTP  
Warren, Michigan

Sampling Date:  
June 14, 2016

BT Environmental Consulting, Inc.  
4949 Fernlee Avenue  
Royal Oak, Michigan 48073




Figure No. 3

Site:  
USEPA Method 29  
WWTP  
Warren, Michigan

Sampling Date:  
June 15, 2016

BT Environmental Consulting Inc.  
4949 Fernlee Avenue  
Royal Oak, MI 48073




Figure No. 4

Site:  
USEPA Method 23  
WWTP  
Warren, Michigan

Sampling Date:  
June 15, 2016

BT Environmental Consulting, Inc.  
4949 Fernlee Avenue  
Royal Oak, Michigan 48073




Figure No. 5

Site:  
USEPA Method 6C, 7E, and 10  
WWTP  
Warren, Michigan

Sampling Date:  
June 14-15, 2016

BT Environmental Consulting Inc.  
4949 Fernlee Avenue  
Royal Oak, MI 48073