

# FINAL REPORT



## CITY OF WARREN WASTEWATER TREATMENT PLANT

WARREN, MICHIGAN

### PERFORMANCE TESTING: SEWAGE SLUDGE INCINERATOR (EU-INCINERATOR)

RWDI #2304506

August 21, 2023

#### SUBMITTED TO

**Brian Rubel, P.E.**  
Vice President  
Brian.Rubel@tetrattech.com

**Tetra Tech, Inc.**  
1136 Oak Valley Dr, Suite 100  
Ann Arbor, MI 48108  
T: 734.665.6000

#### CC:

**Ted Bishop**  
Senior Project Manager  
Ted.Bishop@tetrattech.com

**City of Warren**  
**Wastewater Treatment Plant**  
32360 Warkop Avenue  
Warren, Michigan 48093

#### SUBMITTED BY

**Brad Bergeron, A.Sc.T., d.E.T.**  
Senior Project Manager | Principal  
Brad.Bergeron@rwdi.com

**Steve Smith, QSTI**  
Project Manager  
Steve.Smith@rwdi.com

**RWDI USA LLC**  
**Consulting Engineers & Scientists**  
2239 Star Court  
Rochester Hills, Michigan 48309

T: 248.841.8442  
F: 519.823.1316

**CITY OF WARREN WASTEWATER TREATMENT PLANT:  
SEWAGE SLUDGE INCINERATOR (EU-INCINERATOR) PERFORMANCE TESTING REPORT**

RWDI#2304506  
August 21, 2023



## EXECUTIVE SUMMARY

RWDI USA LLC (RWDI) was retained by The City of Warren Wastewater Treatment Plant (Warren WWTP) to complete a testing program at the sewage sludge incinerator (EU-INCINERATOR) located in Warren, Michigan. The purpose of the testing program was to determine compliance of EU-INCINERATOR with Michigan EGLE Permit Number MI-ROP-B1792-2021 and 40 CFR 60 Subpart M requirements. Testing consisted of the following:

- Carbon Monoxide (CO);
- Oxides of Nitrogen (NO<sub>x</sub>);
- Sulfur Dioxide (SO<sub>2</sub>);
- Filterable Particulate Matter (PM);
- Hydrogen Chloride (HCl);
- Polychlorinated dibenzo-p-dioxins and polychlorinated dibenzofurans (PCDD/PCDF);
- Lead (Pb);
- Cadmium (Cd);
- Mercury (Hg); and
- Visible Emissions.

### Executive i: Results Summary - CEMS

Parameter	Units	Test 1	Test 2	Test 3	Average	ROP Limit
NO <sub>x</sub>	ppm @ 7% O <sub>2</sub>	136.17	111.35	131.99	126.5	220
CO	ppm @ 7% O <sub>2</sub>	1,324.0	1,716.3	1,549.4	1529.9	3,800
SO <sub>2</sub>	ppm @ 7% O <sub>2</sub>	4.98	10.41	0.54	5.31	26

**CITY OF WARREN WASTEWATER TREATMENT PLANT:  
SEWAGE SLUDGE INCINERATOR (EU-INCINERATOR) PERFORMANCE TESTING REPORT**

RWDI#2304506  
August 21, 2023



**Executive ii:** Results Summary – Method 5, 26A, 23 and 29

Parameter	Units	Test 1	Test 2	Test 3	Average	ROP Limit
PM	mg/dscm @ 7% O <sub>2</sub>	31.76	8.44	10.07	16.76	80
	lb per 1,000 lb of exhaust air, corrected to 50% excess air	0.022	0.006	0.007	0.011	0.2
HCl	ppm @ 7% O <sub>2</sub>	0.28	0.25	0.39	0.30	1.2
D&F (TEQ)	ng/m <sup>3</sup> @ 7% O <sub>2</sub>	0.053	0.042	0.036	0.044	0.32
Pb	mg/dscm @ 7% O <sub>2</sub>	0.013	0.018	0.009	0.013	0.30
Cd	mg/dscm @ 7% O <sub>2</sub>	0.0028	0.0032	0.0021	0.0027	0.095
Hg	mg/dscm @ 7% O <sub>2</sub>	0.040	0.050	0.039	0.043	0.28

**Executive iii:** Results Summary – Method 22 – Visible Emissions

Parameter	Units	Test 1	Test 2	Test 3	Average	ROP Limit
Visible Emissions	Percentage	0%	0%	0%	0%	5%





## TABLE OF CONTENTS

<b>1</b>	<b>INTRODUCTION .....</b>	<b>1</b>
1.1	Location and Dates of Testing .....	1
1.2	Purpose of Testing .....	1
1.3	Description of Source .....	1
1.4	Personnel Involved in Testing .....	2
<b>2</b>	<b>PROCESS INFORMATION .....</b>	<b>2</b>
<b>3</b>	<b>SOURCE DESCRIPTION .....</b>	<b>3</b>
3.1	Description of Process and Emission Control Equipment.....	3
3.2	Process Flow Sheet or Diagram .....	3
3.3	Type and Quantity of Raw and Finished Materials.....	3
3.4	Normal Rated Capacity of Process.....	3
3.5	Process Instrumentation Monitored During the Test.....	3
<b>4</b>	<b>SAMPLING AND ANALYSIS PROCEDURES .....</b>	<b>4</b>
4.1	Stack Velocity, Temperature, and Volumetric Flow Rate (EPA Method 1-4) .....	4
4.2	Carbon Monoxide, Oxides of Nitrogen, Sulfur Dioxide, Oxygen, and Carbon Dioxide (EPA Methods 3A, 6C, 7E, and 10) .....	5
4.3	Particulate Matter and Hydrochloric Acid (EPA Method 5/26A).....	6
4.4	Dioxins and Furans (EPA Method 23).....	6
4.5	Lead, Cadmium, and Mercury (EPA Method 29).....	7
4.6	Gas Dilution System (EPA Method 205).....	7
4.7	Visual Fugitive Emissions (EPA Method 22).....	8
4.8	Description of Recovery and Analytical Procedures .....	8
4.9	Sampling Port Description.....	8

CITY OF WARREN WASTEWATER TREATMENT PLANT:  
SEWAGE SLUDGE INCINERATOR (EU-INCINERATOR) PERFORMANCE TESTING REPORT

RWDI#2304506  
August 21, 2023



<b>5</b>	<b>TEST RESULTS AND DISCUSSION .....</b>	<b>9</b>
5.1	Detailed Results .....	9
5.1.1	Discussion of Results .....	9
5.2	Variations in Testing Procedures.....	10
5.3	Process Upset Conditions During Testing.....	10
5.4	Maintenance Performed in Last Three Months .....	10
5.5	Re-Test.....	10
5.6	Audit Samples.....	10
5.7	Process Data.....	10
5.8	Field Data Sheets .....	11
5.9	Calibration Data.....	11
5.10	Laboratory Data .....	11
5.11	Example Calculations.....	11

**CITY OF WARREN WASTEWATER TREATMENT PLANT:  
SEWAGE SLUDGE INCINERATOR (EU-INCINERATOR) PERFORMANCE TESTING REPORT**

RWDI#2304506  
August 21, 2023



## LIST OF TABLES

(Found Within the Report)

<b>Table 1.4:</b>	Testing Personnel
<b>Table 5.1.1 &amp; Executive i:</b>	Results Summary – CEMS
<b>Table 5.1.2 &amp; Executive ii:</b>	Results Summary – CEMS – Method 5, 26A, 23, and 29
<b>Table 5.1.3 &amp; Executive iii:</b>	Results Summary – Visible Emissions

## LIST OF TABLES

(Found After the Report)

<b>Table 1:</b>	Summary of Sampling Parameters and Methodology
<b>Table 2:</b>	Sample Summary and Sample Log
<b>Table 3a:</b>	Sampling Summary – Flow Characteristics – Filterable PM / HCL
<b>Table 3b:</b>	Sampling Summary – Flow Characteristics – Dioxins & Furans
<b>Table 3c:</b>	Sampling Summary – Flow Characteristics – Metals
<b>Table 4:</b>	Sampling Summary – CEMS – June 27, 2023
<b>Table 5:</b>	Sampling Summary – CEMS – June 28, 2023
<b>Table 6:</b>	Sampling Summary – Particulate and Hydrogen Chloride
<b>Table 7:</b>	Sampling Results - Dioxins and Furans - TOTAL TOXIC EQUIVALENCY
<b>Table 8:</b>	Sampling Summary – Metals

## LIST OF FIGURES

(Found After the Report)

<b>Figure 1a:</b>	Stack Traverse Point Diagram - CEMs
<b>Figure 1b:</b>	Stack Traverse Point Diagram – Method 5, 26A, 23, and 29
<b>Figure 2:</b>	EPA Method 5/26A Sampling Train
<b>Figure 3:</b>	EPA Method 29 Sampling Train
<b>Figure 4:</b>	EPA Method 23 Sampling Train
<b>Figure 5:</b>	EPA Method 3A, 6C, 7E, and 10 Sampling System



**CITY OF WARREN WASTEWATER TREATMENT PLANT:  
SEWAGE SLUDGE INCINERATOR (EU-INCINERATOR) PERFORMANCE TESTING REPORT**

RWDI#2304506  
August 21, 2023



## LIST OF GRAPHS

(Found After the Report)

<b>Graph 1:</b>	O <sub>2</sub> & CO <sub>2</sub> Concentration – June 27, 2023 - Test 1
<b>Graph 2:</b>	O <sub>2</sub> & CO <sub>2</sub> Concentration – June 27, 2023 - Test 2
<b>Graph 3:</b>	O <sub>2</sub> & CO <sub>2</sub> Concentration – June 27, 2023 - Test 3
<b>Graph 4a:</b>	NO <sub>x</sub> , CO, O <sub>2</sub> , and SO <sub>2</sub> Concentration – June 28, 2023 – Test 1
<b>Graph 4b:</b>	CO Concentration – June 28, 2023 – Test 1
<b>Graph 4c:</b>	NO <sub>x</sub> Concentration – June 28, 2023 – Test 1
<b>Graph 4d:</b>	SO <sub>2</sub> Concentration – June 28, 2023 – Test 1
<b>Graph 5a:</b>	NO <sub>x</sub> , CO, O <sub>2</sub> , and SO <sub>2</sub> Concentration – June 28, 2023 – Test 2
<b>Graph 5b:</b>	CO Concentration – June 28, 2023 – Test 2
<b>Graph 5c:</b>	NO <sub>x</sub> Concentration – June 28, 2023 – Test 2
<b>Graph 5d:</b>	SO <sub>2</sub> Concentration – June 28, 2023 – Test 2
<b>Graph 6a:</b>	NO <sub>x</sub> , CO, O <sub>2</sub> , and SO <sub>2</sub> Concentration – June 28, 2023 – Test 3
<b>Graph 6b:</b>	CO Concentration – June 28, 2023 – Test 3
<b>Graph 6c:</b>	NO <sub>x</sub> Concentration – June 28, 2023 – Test 3
<b>Graph 6d:</b>	SO <sub>2</sub> Concentration – June 28, 2023 – Test 3

## LIST OF APPENDICES

(Found After the Report)

<b>Appendix A:</b>	Process Data
<b>Appendix B:</b>	CEMs Data
<b>Appendix B1:</b>	CEMs Data – July 27, 2023
<b>Appendix B2:</b>	CEMs Data – July 28, 2023
<b>Appendix C:</b>	EPA Method 5/26 Data
<b>Appendix D:</b>	EPA Method 23 Data
<b>Appendix E:</b>	EPA Method 29 Data
<b>Appendix F:</b>	EPA Method 22 Results
<b>Appendix G:</b>	Field Sheets
<b>Appendix H:</b>	Calibrations Records
<b>Appendix I:</b>	Laboratory Results
<b>Appendix J:</b>	Example Calculations
<b>Appendix K:</b>	Copy of EGLE Correspondence & Test Plan



# 1 INTRODUCTION

RWDI USA LLC (RWDI) was retained by The City of Warren Wastewater Treatment Plant (Warren WWTP) to complete a testing program at the sewage sludge incinerator (EUINCINERATOR) located in Warren, Michigan. The purpose of the testing program was to determine compliance of EUINCINERATOR with Michigan EGLE Permit Number MI-ROP-B1792-2021 and 40 CFR 60 Subpart Mmmm requirements. Testing consisted of the following:

- Carbon Monoxide (CO);
- Oxides of Nitrogen (NO<sub>x</sub>);
- Sulfur Dioxide (SO<sub>2</sub>);
- Filterable Particulate Matter (PM);
- Hydrogen Chloride (HCl);
- Polychlorinated dibenzo-p-dioxins and polychlorinated dibenzofurans (PCDD/PCDF);
- Lead (Pb);
- Cadmium (Cd);
- Mercury (Hg); and
- Visible Emissions.

## 1.1 Location and Dates of Testing

The test program was completed on June 27<sup>th</sup> and 28<sup>th</sup>, 2023 at the Warren WWTP.

## 1.2 Purpose of Testing

The testing program was completed as compliance testing under Permit MI-ROP-B1792-2021 and to demonstrate compliance with the emission limitations contained in the applicable New Source Performance Standard (NSPS) at 40 CFR Part 60 Subpart Mmmm.

## 1.3 Description of Source

The process is a Nichols Herreshoff hearth sludge incinerator with ten hearths. Processed sewage sludge solids are dried and combusted with natural gas as a supplemental fuel during the incineration process. Emissions from the incinerator are controlled by a VenturiPak wet scrubber consisting of three stages including: 1) Quench stage, 2) Subcooling Stage (Impingement Type Wet Scrubber), and 3) Venturi Stage followed by a mist eliminator.





## 1.4 Personnel Involved in Testing

Table 1.4: Testing Personnel

<b>Bryan Clor</b> Division Head Bclor@cityofwarren.com	<b>City of Warren WWTP</b> 32360 Warkop Avenue Warren, Michigan 48093	(586) 264-2530 x 8103
<b>Ted Bishop</b> Senior Project Manager Ted.Bishop@tetrattech.com	<b>Tetra Tech</b> 1136 Oak Valley Dr, Suite 100 Ann Arbor, MI 48108	(248) 321-8554
<b>Brad Bergeron</b> Senior Project Manager Brad.Bergeron@rwdi.com	<b>RWDI USA LLC</b> 2239 Star Court Rochester Hills, MI 48309	(248) 234-3885
<b>Mason Sakshaug</b> Senior Scientist Mason.Sakshaug@rwdi.com		(989) 323-0355
<b>Ben Durham</b> Senior Field Technician Ben.Durham@rwdi.com		(734) 751-9701
<b>Mike Nummer</b> Senior Field Technician Michael.Nummer@rwdi.com		(586) 863-8237
<b>Cade Smith</b> Field Technician Cade.Smith@rwdi.com		(734) 552-7270

## 2 PROCESS INFORMATION

Operational data collected during the testing is provided in **Appendix A**.



## 3 SOURCE DESCRIPTION

### 3.1 Description of Process and Emission Control Equipment

Refer to Section 1.3 for a description of the process.

### 3.2 Process Flow Sheet or Diagram

Stack parameters are found in **Figure 1a and 1b**.

### 3.3 Type and Quantity of Raw and Finished Materials

The process combusts dewatered biosolids which are fed to the incinerator at a maximum rate of 6.6 wet tons per hour, which is equivalent to an 85% feed rate of 5.6 wet tons per hour.

### 3.4 Normal Rated Capacity of Process

The rated capacity of the facility is 6.6 wet tons of biosolids per hour. Average production is typically between 4.5 to 5.5 wet tons per hour.

### 3.5 Process Instrumentation Monitored During the Test

An O<sub>2</sub> continuous emissions monitoring system is permanently installed to monitor O<sub>2</sub> concentrations in the gas stream and O<sub>2</sub> is monitored during the testing. The incinerator process is regulated through monitoring of combustion temperature and exhaust gas pressure drop. Water flow through the scrubber and pH of the scrubber water is also monitored.



## 4 SAMPLING AND ANALYSIS PROCEDURES

The emission test program will utilize the following test methods codified at Title 40, Part 60, Appendix A of the Code of Federal Regulations (40 CFR 60, Appendix A)

- Method 1 – Sample and Velocity Traverses for Stationary Sources
- Method 2 – Determination of Stack Gas Velocity and Volumetric Flowrate
- Method 3A – Determination of Molecular Weight of Dry Stack Gases
- Method 4 – Determination of Moisture Content in Stack Gases
- Method 5 – Determination of Particulate Matter Emissions from Stationary Sources
- Method 6C – Determination of Sulfur Dioxide Emissions from Stationary Sources
- Method 7E – Determination of Nitrogen Oxides Emissions from Stationary Sources
- Method 10 – Determination of Carbon Monoxide Emissions from Stationary Sources
- Method 23 – Determination of Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans from Stationary Sources
- Method 26A – Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources
- Method 29 – Determination of Metals Emissions from Stationary Sources
- Method 205 – Verification of Gas Dilution Systems for Field Instrument Calibrations
- Method 22 – Visible Determination of Fugitive Emissions

### 4.1 Stack Velocity, Temperature, and Volumetric Flow Rate (EPA Method 1-4)

Stack gas velocity traverses were conducted in accordance with the procedures outlined in Method 1 and Method 2. S-type pitot tubes with thermocouple assemblies, calibrated in accordance with Method 2, Section 4.1.1, was used to measure exhaust gas velocity pressures (using a manometer) and temperatures during testing. The S-type pitot tube dimensions outlined in Sections 2-6 through 2-8 was within specified limits, therefore, a baseline pitot tube coefficient of 0.84 (dimensionless) will be assigned. A diagram of the sample points is provided in Figure 1. Cyclonic flow checks were performed. The existence of cyclonic flow was determined by measuring the flow angle at each sample point. The flow angle was the angle between the direction of flow and the axis of the stack. If the average of the absolute values of the flow angles is greater than 20 degrees, cyclonic flow exists. The Molecular Weight of the gas stream was evaluated according to procedures outlined in Title 40, Part 60, Appendix A, Method 3A. The O<sub>2</sub> /CO<sub>2</sub> content of the gas stream was measured using an analyzer. Exhaust gas was extracted as part of the sampling train. Exhaust gas moisture content was determined gravimetrically.





## 4.2 Carbon Monoxide, Oxides of Nitrogen, Sulfur Dioxide, Oxygen, and Carbon Dioxide (EPA Methods 3A, 6C, 7E, and 10)

NO<sub>x</sub>, SO<sub>2</sub>, CO, O<sub>2</sub>, and CO<sub>2</sub> concentrations were determined utilizing RWDI's continuous emissions monitoring (CEM) system. Prior to testing, a 3-point analyzer calibration error check was conducted using USEPA protocol gases. The calibration error check was performed by introducing zero, mid and high-level calibration gases directly into the analyzer. The calibration error check was performed to confirm that the analyzer response is within  $\pm 2\%$  of the certified calibration gas introduced. Prior to each test run, a system-bias test was performed where known concentrations of calibration gases were introduced at the probe tip to measure if the analyzers response was within  $\pm 5\%$  of the introduced calibration gas concentrations. At the conclusion of each test run a system-bias check was performed to evaluate the percent drift from pre and post-test system bias checks. The system bias checks were used to confirm that the analyzer did not drift greater than  $\pm 3\%$  throughout a test run.

Zero and upscale calibration checks were conducted both before and after each test run to quantify measurement system calibration drift and sampling system bias. Upscale is either the mid- or high-range gas, whichever most closely approximates the flue gas level. During these checks, the calibration gases were introduced into the sampling system at the probe outlet so that the calibration gases were analyzed in the same manner as the flue gas samples.

A gas sample was continuously extracted from the stack and delivered to a series of gas analyzers, which measure the pollutant or diluent concentrations in the gas. The analyzers were calibrated on-site using EPA Protocol No. 1 certified calibration mixtures. The probe tip was equipped with a sintered stainless-steel filter for particulate removal. The end of the probe will be connected to a heated Teflon sample line, which delivers the sample gases from the stack to the CEM system. The heated sample line will be designed to maintain the gas temperature above 250°F to prevent condensation of stack gas moisture within the line.

Before entering the analyzers, the gas sample passed directly into a refrigerated condenser, which cools the gas to approximately 35°F to remove the stack gas moisture. After passing through the condenser, the dry gas was entered a Teflon-head diaphragm pump and a flow control panel, which will deliver the gas in series to the NO<sub>x</sub>, SO<sub>2</sub>, CO, O<sub>2</sub>, CO<sub>2</sub> analyzers. Each of these analyzers were measure the respective gas concentrations on a dry volumetric basis.

RECEIVED

AUG 22 2023

AIR QUALITY DIVISION



### 4.3 Particulate Matter and Hydrochloric Acid (EPA Method 5/26A)

Method 5, "Determination of Particulate Emissions from Stationary Sources" and Method 26A, "Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources" was used to measure particulate matter and hydrochloric acid concentrations and emission rates. Figure 2 provides the sampling train. The stack sampling system was consist of (1) a glass nozzle, (2) a steel probe with glass liner, (3) tared quartz filter, (4) a set of four Greenburg-Smith (GS) impingers with the first and third modified and the second was a standard GS impinger, The first two contained 100 ml 0.1N H<sub>2</sub>SO<sub>4</sub>, the third empty, and a fourth impinger filled with silica gel, (5) a length of sample line, and (6) a calibrated pump and dry gas meter. A sampling train leak test was conducted before and after each test run. After completion of the final leak test for each test run, the filter was recovered, and the probe, nozzle and the front half of the filter holder assembly was brushed, and triple rinsed with acetone. The acetone rinses was collected in a pre-cleaned sample container. The impinger catch solution was transferred to pre-cleaned sample containers. The impingers and back half of the filter housing was triple rinsed with deionized water (DI H<sub>2</sub>O), and the rinses added to the back half train sample jar. The containers were labeled with the test number, test location, test date, and the level of liquid will be marked on the outside of each container.

### 4.4 Dioxins and Furans (EPA Method 23)

Method 23, " Determination of Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans from Stationary Sources " was used to evaluate CDD/CDF concentrations. Figure 4 provides the sampling train. The Method 23 sampling train was consist of (1) a borosilicate glass or quartz nozzle, (2) a steel probe with glass liner, (3) a heated quartz filter, (4) a glass recirculating ice water condenser system, (5) a XAD-2 sorbent trap, (6) an empty potbellied impinger, (7) a set of four GS impingers, (8) a length of sample line, and (9) calibrated pump and dry gas meter. Prior to each test, the first and second impingers was filled with 100 ml of HPLC water, the third impinger was empty, and the fourth impinger was contain silica gel. Upon completion of the final leak test for each test tun, the filter was recovered, the nozzle and the front half of the filter housing will be brushed, and triple rinsed with acetone and toluene. The rinses were collected in a pre-cleaned sample container. The back half of the filter housing and condenser was rinsed with acetone and toluene. The containers was labeled with the test number, test location, test date, and the level of liquid was marked on the outside of each container.





## 4.5 Lead, Cadmium, and Mercury (EPA Method 29)

The sample train consisted of a teflon coated steel nozzle, a heated glass probe, a heated quartz filter, two chilled impingers each with 100 mL of 5%  $\text{HNO}_3$ /10%  $\text{H}_2\text{O}_2$ , an empty impinger, two chilled impingers each with 100 mL of 4%  $\text{KMnO}_4$ /10%  $\text{H}_2\text{SO}_4$ , an impinger with 200 grams of silica gel, and a dry gas metering console. The temperature of the filter was monitored and controlled to  $248 \pm 250^\circ\text{F}$ .

At the end of each test run, the nozzle, probe, and filter front half were then rinsed with 100 mL of 0.1 N nitric acid into the first sample jar. The filter was then recovered into the original labeled petri dish.

The contents of the 5%  $\text{HNO}_3$ /10%  $\text{H}_2\text{O}_2$  impinger were poured back into the original reagent jar. Any condensate in the empty impinger was poured into a sample jar. The 4%  $\text{KMnO}_4$ /10%  $\text{H}_2\text{SO}_4$  impingers were then recovered into another sample jar.

The moisture catch was then determined gravimetrically. The filter back half and 5%  $\text{HNO}_3$ /10%  $\text{H}_2\text{O}_2$  impingers were rinsed with 100 mL of 0.1 N nitric acid into a sample jar.

The empty impinger was rinsed with 100 mL of 0.1 N nitric acid into a sample jar. The 4%  $\text{KMnO}_4$ /10%  $\text{H}_2\text{SO}_4$  impingers were then rinsed with 100 mL 4%  $\text{KMnO}_4$ /10%  $\text{H}_2\text{SO}_4$  and 100 mL of DI water into the jar containing the 4%  $\text{KMnO}_4$ /10%  $\text{H}_2\text{SO}_4$  reagent. The 4%  $\text{KMnO}_4$ /10%  $\text{H}_2\text{SO}_4$  impingers and connecting glassware were rinsed with 25 mL of 8 N HCl if any brown residue remained. This HCl rinse was added to a jar containing 200 mL of DI water.

## 4.6 Gas Dilution System (EPA Method 205)

Calibration gases were mixed using an Environics 4040 Gas Dilution System. The mass flow controllers are factory calibrated using a primary flow standard traceable to the United States National Institute of Standards and Technology (NIST). Each flow controller utilizes an 11-point calibration table with linear interpolation, to increase accuracy and reduce flow controller nonlinearity. The calibration is done yearly, and the records will be included in the Source Testing Report. A multi-point EPA Method 205 check will be executed in the field prior to testing to ensure accurate gas-mixtures. The gas dilution system consisting of calibrated orifices or mass flow controllers and dilutes a high-level calibration gas to within  $\pm 2\%$  of predicted values. The gas divider is capable of diluting gases at set increments and will be evaluated for accuracy in the field in accordance with US EPA Method 205 "Verification of Gas Dilution Systems for Field Instrument Calibrations". The gas divider dilutions were measured to evaluate that the responses are within  $\pm 2\%$  of predicted values. In addition, a certified mid-level calibration gas within  $\pm 10\%$  of one of the tested dilution gases were introduced into an analyzer to ensure the response of the gas calibration is within  $\pm 2\%$  of gas divider dilution concentration.





## 4.7 Visual Fugitive Emissions (EPA Method 22)

Method 22, "Visual Determination of Fugitive Emissions from Material Sources and Smoke Emissions from Flares" was used to measure opacity of the EU-INCINERATOR ash handling operation lagoons. Triplicate test runs of 60 minutes was conducted to note presence of fugitive emissions at the ash lagoon. EPA Method 22 was used to determine the frequency of fugitive emissions from stationary sources.

## 4.8 Description of Recovery and Analytical Procedures

All sample recovery and analytical procedures following the prescribed methods of USEPA Method 1 to 4, 5/26A and 23.

## 4.9 Sampling Port Description

All sampling ports meet USEPA Method 1 locations and can be found in the **Figure Section**.

## 5 TEST RESULTS AND DISCUSSION

### 5.1 Detailed Results

**Table 5.1.1:** Results Summary – CEMS

Parameter	Units	Test 1	Test 2	Test 3	Average	ROP Limit
NO <sub>x</sub>	ppm @ 7% O <sub>2</sub>	136.17	111.35	131.99	126.5	220
CO	ppm @ 7% O <sub>2</sub>	1,324.0	1,716.3	1,549.4	1529.9	3,800
SO <sub>2</sub>	ppm @ 7% O <sub>2</sub>	4.98	10.41	0.54	5.31	26

**Table 5.1.2:** Results Summary – Method 5, 26A, 23 and 29

Parameter	Units	Test 1	Test 2	Test 3	Average	ROP Limit
PM	mg/dscm @ 7% O <sub>2</sub>	31.76	8.44	10.07	16.76	80
	lb per 1,000 lb of exhaust air, corrected to 50% excess air	0.022	0.006	0.007	0.011	0.2
HCl	ppm @ 7% O <sub>2</sub>	0.28	0.25	0.39	0.30	1.2
D&F (TEQ)	ng/m <sup>3</sup> @ 7% O <sub>2</sub>	0.053	0.042	0.036	0.044	0.32
Pb	mg/dscm @ 7% O <sub>2</sub>	0.013	0.018	0.009	0.013	0.30
Cd	mg/dscm @ 7% O <sub>2</sub>	0.0028	0.0032	0.0021	0.0027	0.095
Hg	mg/dscm @ 7% O <sub>2</sub>	0.040	0.050	0.039	0.043	0.28

**Table 5.1.3:** Results Summary – Visible Emissions Method 22

Parameter	Units	Test 1	Test 2	Test 3	Average	ROP Limit
Visible Emissions	Percentage	0%	0%	0%	0%	5%

#### 5.1.1 Discussion of Results

The detailed results can be found in the following Appendices:

- **Appendix B** – Summary of Continuous Emissions Monitoring
- **Appendix C** – Summary of Particulate Matter & Hydrogen Chloride Results (Method 5 and 26A)
- **Appendix D** – Summary of Dioxin & Furan Results (Method 23)
- **Appendix E** – Summary of Metals (Method 29)
- **Appendix F** – Summary of Visible Emissions (Method 22)



## 5.2 Variations in Testing Procedures

The testing program was completed in adherence to the methods. No variations were made.

## 5.3 Process Upset Conditions During Testing

There were no process disruptions during testing. The incinerator bypass stack was not opened or used during any testing.

## 5.4 Maintenance Performed in Last Three Months

A portion of the scrubber Annual Inspection was conducted in May 2023 and minor maintenance/cleaning activities were performed on the scrubber at that time. In addition, in June 2023, the ID fan bearings were replaced and internal work was done on the incinerator to clear drop chutes on Hearth 5 and replace broken teeth on Hearths 5 and 6.

## 5.5 Re-Test

This was not a retest.

## 5.6 Audit Samples

No audit samples were collected.

## 5.7 Process Data

Process data is included in **Appendix A**. Process operating data collected during the testing includes:

- Sewage sludge feed rate
- Sewage sludge feed moisture content
- Operating temperatures of each hearth for Hearths 1 – 8
- Pressure drop across the wet scrubber
- Scrubber liquid flow rate
- pH of the scrubber liquid

Please note that new operational parameter limits have been established based on the operating data collected during this testing event.





## 5.8 Field Data Sheets

Field data can be found in **Appendix G**.

## 5.9 Calibration Data

Calibration can be found in **Appendix H**.

## 5.10 Laboratory Data

Laboratory data can be found in **Appendix I**.

## 5.11 Example Calculations

Example calculations can be found in **Appendix J**.

RECEIVED  
AUG 22 2023  
AIR QUALITY DIVISION

## TABLES



**Table 1: Summary of Sampling Parameters and Methodology (EU-INCINERATOR)**

Source Location	No. of Tests per Stack	Sampling Parameter	Sampling Method
EU-INCINERATOR	3	Velocity, Temperature and Flow Rate	U.S. EPA [1] Methods 1-4
	3	Dioxins & Furans	U.S. EPA [1] Method 23
	3	Filterable PM / HCl	U.S. EPA [1] Method 5/26A
	3	Metals	U.S. EPA [1] Method 29
	6	Oxygen & Carbon Dioxide	U.S. EPA [1] Method 3A
	3	Carbon Monoxide, Oxides of Nitrogen, & Sulfur Dioxide	U.S. EPA [1] Method 10, 7E and 6C

**Notes:**

[1] U.S. EPA - United States Environmental Protection Agency



**Table 2: Sampling Summary and Sample Log (Filterable PM, HCl, D&F, and Metals) (EU-INCINERATOR)**

Source and Test #	Sampling Date	Start Time	End Time	Filter ID / Trap ID
<b>EU-INCINERATOR - Dioxins &amp; Furans</b>				
Blank	27-Jun-23	-	-	83QFF
Proof Blank	26-Jun-23	13:18	15:18	83QFF / Trap #3
Test #1	27-Jun-23	9:40	11:48	83QFF / Trap #5
Test #2	27-Jun-23	13:05	15:11	83QFF / Trap #2
Test #3	27-Jun-23	15:47	17:52	83QFF / Trap #1
<b>EU-INCINERATOR - Filterable PM / HCL</b>				
Blank	28-Jun-23	-	-	QZ78
Test #1	28-Jun-23	8:50	10:18	QZ69
Test #2	28-Jun-23	11:13	12:41	QZ55
Test #3	28-Jun-23	13:17	14:45	QZ59
<b>EU-INCINERATOR - Metals</b>				
Blank	27-Jun-23	-	-	QZ78
Test #1	27-Jun-23	9:40	11:48	QZ78
Test #2	27-Jun-23	13:05	15:11	QZ73
Test #3	27-Jun-23	15:47	17:52	QZ70

**Table 3A: Sampling Summary - Flow Characteristics - Filterable PM / HCL  
EU-INCINERATOR**

Stack Gas Parameter		Test No. 1	Test No. 2	Test No. 3	Average
Testing Date		28-Jun-23	28-Jun-23	28-Jun-23	
Stack Temperature	°F	103	109	98	104
Moisture	%	6.3%	7.5%	4.5%	6.1%
Velocity	ft/s	10.80	11.00	10.80	10.87
Referenced Flow Rate	CFM	6,901	6,867	7,060	6,943
Sampling Isokinetic Rate	%	101.1	101.5	98.6	100.4

**Notes:**

[1] Referenced flow rate expressed as dry at 101.3 kPa, 68 °F, and Actual Oxygen



**Table 3C: Sampling Summary - Flow Characteristics - Metals**  
**EU-INCINERATOR**

Stack Gas Parameter		Test No. 1	Test No. 2	Test No. 3	Average
Testing Date		27-Jun-23	27-Jun-23	27-Jun-23	
Stack Temperature	°F	95	95	93	94
Moisture	%	4.6%	3.5%	4.5%	4.2%
Velocity	ft/s	11.30	10.80	10.80	10.97
Referenced Flow Rate	CFM	7,156	6,898	6,877	6,977
Sampling Isokinetic Rate	%	100.9	97.4	98.4	98.9

**Notes:**

[1] Referenced flow rate expressed as dry at 101.3 kPa, 68 °F, and Actual Oxygen

**Table 4: Sampling Summary - CEMS - June 27, 2023**

RWDI Project #2304506

Incinerator - June 28, 2023				O <sub>2</sub>	CO <sub>2</sub>
Test ID	Date	Start	End	%	%
1	2023-06-27	9:39	11:48	8.66	8.80
2	2023-06-27	13:05	15:11	8.47	9.11
3	2023-06-27	15:37	17:53	8.16	9.25
Average				8.43	9.06

	Needs to be filled in
	Linked to CEMs Bias calcs
	Calculations



**Table 5: Sampling Summary - CEMs - June 28, 2023**

RWDI Project #2304506

Incinerator - June 28, 2023				O <sub>2</sub>	CO <sub>2</sub>	NOx	NOx	CO	CO	SO <sub>2</sub>	SO <sub>2</sub>
Test ID	Date	Start	End	%	%	ppm	ppm @ 7% O <sub>2</sub>	ppm	ppm @ 7% O <sub>2</sub>	ppm	ppm @ 7% O <sub>2</sub>
1	2023-06-28	8:50	10:17	8.82	8.84	118.4	136.17	1151.0	1324.0	4.33	4.98
2	2023-06-28	11:13	12:40	7.72	9.71	105.6	111.35	1627.0	1716.3	9.87	10.41
3	2023-06-28	13:17	14:44	9.30	8.57	110.1	131.99	1292.8	1549.4	0.45	0.54
Average				8.61	9.04	111.4	126.5	1357.0	1529.9	4.88	5.31
Limit						220		3800		26	
Percent of Limit						57.5%		40.3%		20.4%	

	Needs to be filled in
	Linked to CEMs Bias calcs
	Calculations

Table 6: Summary of Particulate and Hydrogen Chloride Results

Company	Warren WWTP				
Source	Incinerator				
Parameter(s) / Method(s)	Particulate / Hydrogen Chloride / US EPA Method 5 / 26A				
Date	28-Jun-23	28-Jun-23	28-Jun-23		
Test Number	Test 1	Test 2	Test 3	Average	
Test Start Time	8:50	11:13	13:17	--	
Test End Time	10:18	12:41	14:45	--	
Stack Information					
Flow Rate (ft³/min) (Actual)	8,003	8,152	7,968	8,041	
Flow (ft3/min) (Standard Wet)	7,363	7,426	7,396	7,395	
Flow (ft3/min) (Standard Dry)	6,901	6,867	7,060	6,943	
Flow (m³/min) (Standard Dry)	195	194	200	197	
Percent Moisture (%)	6.3	7.5	4.5	6.1	
Pressure Ps ("Hg)	29.37	29.37	29.37	29.37	
Average Stack Temperature Ts (°F)	103.3	108.9	98.3	103.5	
Molecular Weight of Stack Gas dry (Md) (g/mole)	29.77	29.86	29.74	29.79	
Molecular Weight of Stack Gas wet (Ms) (g/mole)	29.03	28.97	29.21	29.07	
Stack Gas Specific Gravity (Gs) (kg/L)	1.0	1.0	1.0	1.0	
Water Vapor Volume Fraction (%)	0.1	0.1	0.0	0.1	
Average Stack Velocity Vs (ft/sec)	10.8	11.0	10.8	10.9	
Area of Stack (ft²)	12.3	12.3	12.3	12.3	
Percent Carbon Dioxide (%)	8.84	9.71	8.57	9.04	
Percent Oxygen (%)	8.82	7.72	9.30	8.61	
Percent Carbon Monoxide (%)	0.0	0.0	0.0	0.0	
Meter Info					
Isokinetic Variation I (%)	101.1	101.5	98.6	100.4	
Meter Pressure Pm ("Hg)	29.4	29.4	29.4	29.4	
Meter Temperature Tm (°F)	71.8	75.3	78.3	75.1	
Measured Sample Volume Vm (ft³)	47.72	47.97	48.16	47.95	
Sample Volume (Vm St ft³)	45.93	45.87	45.79	45.86	
Sample Volume (Vm St m³)	1.30	1.30	1.30	1.30	
Total Weight of Sampled Gas (lbs) wet	3.68	3.71	3.62	3.67	
Total Weight of Sampled Gas (lbs) dry	3.53	3.54	3.52	3.53	
Gas Density Ps wet (in hg)	0.08	0.07	0.08	0.08	
Gas Density Ps dry (in hg)	0.08	0.08	0.08	0.08	
Condensate Volume (ft³)	3.07	3.73	2.18	3.00	
Nozzle Size (in)	0.00099	0.00099	0.00099	0.00099	
Impinger Gain (g)	49.1	67.5	36.3	51.0	
Silica Gel Gain (g)	16.1	11.7	9.9	12.6	
Total Gas Sampled (vm st ft³ + condensate volume)	49.00	49.60	47.97	48.86	
Particulate Results					
Nozzle/Probe/Filter Weight (mg)	35.9	10.4	10.9	19.1	
Total Particulate (mg)	35.9	10.4	10.9	19.1	
Total Particulate Emission Rate (lb/hr)	0.72	0.21	0.22	0.38	
lb/1000 lb (wet) @ 50% excess air	0.022	0.006	0.007	0.011	
Total Particulate Concentration (mg/dscm) (dry) @ 7% O2	31.76	8.44	10.07	16.76	
Total Particulate Concentration (gr/dscf)	0.014	0.0037	0.0044	0.0073	
HCl Results					
Sample Weight (µg)	470	470	630	523	
Blank Correction (µg)	0	0	0	0	
Total Weight (µg)	470	470	630	523	
HCl Concentration (mg/dscm) (dry)	0.36	0.36	0.49	0.40	
HCl Emission Rate (lb/hr)	0.009	0.009	0.013	0.011	
HCl Concentration (ppm)	0.24	0.24	0.32	0.27	
HCl Concentration (ppm) @7% O2	0.28	0.25	0.39	0.30	
				ROP Limit	% of ROP Limit
				0.2	5.72%
				80	21.0%
				1.2	25.4%



**Table 7: Sampling Results - Dioxins and Furans - TOTAL TOXIC EQUIVALENCY**

Source: EU-INCINERATOR

Test :	Blank	Test #1				Test #2			Test #3			Test 3		Average	Average	ROP Limit	% of ROP Limit
Sample Volume (ft <sup>3</sup> ) <sup>[1]</sup>		69.2				66.5			64.9			Test 3	Concentration	Concentration			
Sample Volume (m <sup>3</sup> ) <sup>[1]</sup>		1.96			Test 1	1.88			1.84			Concentration	@68 °F and	@68 °F and			
Stack Flow Rate (dscfm) <sup>[1]</sup>		6821			Concentration	6564			6537			@68 °F and	@68 °F and				
Stack Flow Rate (m <sup>3</sup> /s) <sup>[1]</sup>		3.22			@68 °F and	3.10			3.09			7% O <sub>2</sub>	7% O <sub>2</sub>				
	(pg)	(pg)	(pg/m <sup>3</sup> )	(pg/s)	(ng/m <sup>3</sup> )	(pg)	(pg/m <sup>3</sup> )	(pg/s)	(ng/m <sup>3</sup> )	(pg)	(pg/m <sup>3</sup> )	(pg/s)	(ng/m <sup>3</sup> )	(pg/m <sup>3</sup> )	(ng/m <sup>3</sup> )		
Total TEQ	--	91.5	47	150	0.053	71.6	38.0	120	0.042	60.0	33	102	0.036	39	0.044	0.32	13.7%

Notes:

[1] Sample volume and volumetric flow rate based on dry referenced conditions (101.3 kPa and 68 °F)

'<' indicates that laboratory results were below the Reportable Detection Limit (RDL). This detection limit was used to calculate the concentration and emission rate.

\*CDD = chlorodibenzo-p-dioxin

\*\*CDF = chlorodibenzo-p-furan

Test 1 8.66 O2 8.8 CO2

Test 2 8.47 O2 9.11 CO2

Test 3 8.16 O2 9.25 CO2

RECEIVED  
AUG 22 2023  
AIR QUALITY DIVISION

Table 8: Summary of Metal Results

Company	Warren WTP			
Source	Incinerator			
Parameter / Method	Metals / USEPA Method 29			
Date	27-Jun-23	27-Jun-23	27-Jun-23	
Test Number	Test 1	Test 2	Test 3	Average
Test Start Time	9:40	13:05	15:47	--
Test End Time	11:48	15:11	17:52	--
<b>Stack Information</b>				
Flow Rate (ft3/min) (Actual)	8,362	7,962	7,991	8,105
Flow (ft3/min) (Standard Wet)	7,498	7,148	7,205	7,284
Flow (ft3/min) (Standard Dry)	7,156	6,898	6,877	6,977
Flow (m3/min) (Standard Dry)	203	195	195	198
Percent Moisture (%)	4.6	3.5	4.5	4.2
Pressure Ps (in Hg)	28.23	28.23	28.23	28.23
Average Stack Temperature Ts (oF)	95.5	94.9	92.5	94.3
Molecular Weight of Stack Gas dry (Md) (g/mole)	29.75	29.80	29.81	29.79
Molecular Weight of Stack Gas wet (Ms) (g/mole)	29.22	29.38	29.27	29.29
Stack Gas Specific Gravity (Gs) (kg/L)	1.0	1.0	1.0	1.0
Water Vapor Volume Fraction (%)	0.0	0.0	0.0	0.0
Average Stack Velocity Vs (ft/sec)	11.3	10.8	10.8	11.0
Area of Stack (ft2)	12.3	12.3	12.3	12.3
Percent Carbon Dioxide (%)	8.8	9.1	9.3	9.1
Percent Oxygen (%)	8.7	8.5	8.2	8.4
Percent Carbon Monoxide (%)	0.0	0.0	0.0	0.0
<b>Meter Info</b>				
Isokinetic Variation I (%)	100.9	97.4	98.4	98.9
Meter Pressure Pm (in Hg)	28.3	28.3	28.3	28.3
Meter Temperature Tm (oF)	74.6	73.8	74.4	74.3
Measured Sample Volume Vm (ft3)	73.73	68.50	69.09	70.44
Sample Volume (Vm St ft3)	67.88	63.13	63.62	64.88
Sample Volume (Vm St m3)	1.92	1.79	1.80	1.84
Total Weight of Sampled Gas (lbs) wet	5.37	4.97	5.04	5.13
Total Weight of Sampled Gas (lbs) dry	5.22	4.86	4.90	4.99
Gas Density Ps wet (in hg)	0.08	0.08	0.08	0.08
Gas Density Ps dry (in hg)	0.08	0.08	0.08	0.08
Condensate Volume (ft3)	3.24	2.28	3.03	2.85
Nozzle Size (in)	0.00099	0.00099	0.00099	0.00
Impinger Gain (g)	53.8	33.2	46.4	44.5
Silica Gel Gain (g)	15.0	15.2	17.9	16.0
Total Gas Sampled (vm st ft3 + condensate volume)	71.12	65.42	66.65	67.73
<b>Lead Results</b>				
Lead Weight (ug)	22.22	28.20	15.13	21.85
Lead mg/dscm (dry)	0.012	0.016	0.008	0.012
Lead mg/dscm (dry) @ 7% O <sub>2</sub>	0.013	0.018	0.009	0.013
Lead (gr/dscf)	5.05E-06	6.89E-06	3.67E-06	5.21E-06
Lead (lb/hr)	0.00031	0.00041	0.00022	0.00031
<b>Cadmium Results</b>				
Cadmium Weight (ug)	4.78	5.11	3.54	4.48
Cadmium mg/dscm (dry)	0.0025	0.0029	0.0020	0.012
Cadmium mg/dscm (dry) @ 7% O <sub>2</sub>	0.0028	0.0032	0.0021	0.0027
Cadmium (gr/dscf)	1.09E-06	1.25E-06	8.59E-07	1.06E-06
Cadmium (lb/hr)	6.88E-05	7.58E-05	5.23E-05	6.56E-05
<b>Mercury Results</b>				
Mercury Weight (ug)	68.0	79.2	63.7	70.3
Mercury (mg/dscm) (dry)	0.035	0.044	0.035	0.038
Mercury (mg/dscm) (dry) @ 7% O <sub>2</sub>	0.040	0.050	0.039	0.043
Mercury (gr/dscf)	1.55E-05	1.94E-05	1.55E-05	1.68E-05
Mercury (lb/hr)	9.79E-04	1.17E-03	9.41E-04	1.03E-03

ROP Limit	% of ROP Limit
0.3	4.4%

ROP Limit	% of ROP Limit
0.095	2.9%

ROP Limit	% of ROP Limit
0.28	15.3%

FIGURES









Figure No. 1A: EU-INCINERATOR Traverse Point Schematic (CEMs)




**EU-INCINERATOR**  
City of Warren  
Warren Wastewater Treatment Plant  
Warren, Michigan

Date:  
June 27th & 28th, 2023

**RWDI USA LLC**  
2239 Star Court  
Rochester Hills, MI 48309



Figure No. 1B: EU-INCINERATOR Traverse Point Schematic (Method 5/26A/23/29)



**EU-INCINERATOR**  
City of Warren  
Warren Wastewater Treatment Plant  
Warren, Michigan

Date:  
June 27th & 28th, 2023

**RWDI USA LLC**  
2239 Star Court  
Rochester Hills, MI 48309

Figure 2  
USEPA Method 26A/5  
City of Warren Wastewater Treatment Plant









Figure No. 3: Schematic of USEPA Method 29



## USEPA Method 29

City of Warren

Warren Wastewater Treatment Plant

Warren, Michigan

Project 2304506

Date: June 27th to 28th, 2023



Figure 4  
USEPA Method 23  
City of Warren Wastewater Treatment Plant





Figure 23-1. Method 23 Sampling Train



Figure No. 5: USEPA Method 3A,6C,7E,10 Schematic



### USEPA Method 3A,6C,7E,10

#### City of Warren

Warren Wastewater Treatment Plant

Incinerator

Warren, Michigan

Project# 2304506

Date: June 27 to 28, 2023

