



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
SOUTHEAST MICHIGAN DISTRICT OFFICE



C. HEIDI GREYER
DIRECTOR

January 24, 2018

Mr. Michael Daniels
Chief WRC Wastewater Treatment
Clinton River WRRF-Pontiac WWTP
155 North Opdyke Road
Pontiac, Michigan 48342

SRN: B1950, Oakland County

Dear Mr. Daniels:

VIOLATION NOTICE

On December 13, 2016, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), conducted an inspection of Clinton River WRRF-Pontiac WWTP located at 155 North Opdyke Road, Pontiac, Michigan. The purpose of this inspection was to determine Clinton River WRRF-Pontiac WWTP's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and the conditions of Permit to Install (PTI) number 195-15A;

During the inspection, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
EUWUKENG1	PTI No. 195-15A, SC IX.2	Facility did not verify compliance with the emission limits specified in 40 CFR 60, Subpart JJJJ.
EUWUKENG2	PTI No. 195-15A, SC IX.2	Facility did not verify compliance with the emission limits specified in 40 CFR 60, Subpart JJJJ.
EGENGINEGEN5	PTI No. 195-15A, SC IX.2	Facility did not verify compliance with the emission limits specified in 40 CFR 60, Subpart JJJJ.
EUENGINEGEN6	PTI No. 195-15A, SC IX.2	Facility did not verify compliance with the emission limits specified in 40 CFR 60, Subpart JJJJ.

These engines are subject to the federal Standards of Performance for New Sources (NSPS) for Spark Ignition Internal Combustion Engines. These standards are found in Title 40 of the Code of Federal Regulations (CFR) Part 60, Subpart JJJJ.

Mr. Michael Daniels

Page 2

January 24, 2018

These engines are subject to the federal National Emission Standards for Hazardous Air Pollutants (NESHAP) for Reciprocating Internal Combustion Engines. These standards are found in 40 CFR Part 63, Subpart ZZZZ.

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by February 14, 2018 **(which coincides with 21 calendar days from the date of this letter)**. The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Clinton River WRRF-Pontiac WWTP believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during my inspection of Clinton River WRRF-Pontiac WWTP. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Sebastian Kallumkal
Senior Environmental Engineer
Air Quality Division
586-753-3738

cc/via e-mail: Ms. Lynn Fiedler, DEQ
Ms. Mary Ann Dolehanty, DEQ
Mr. Christopher Ethridge, DEQ
Mr. Thomas Hess, DEQ
Ms. Joyce Zhu, DEQ