

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

DTE-St. Clair Power Plant (SCPP) (State Registration Number: B2796) contracted Montrose Air Quality Services, LLC (Montrose) to perform a compliance test program on the Coal-Fired Boiler No. 7 (EU-BOILER7-SC) at the DTE-SCPP facility located in East China Township, Michigan. Testing was performed on September 28, 2021, for the purpose of satisfying the emission testing requirements pursuant to Michigan Department of Environment, Great Lakes, and Energy (EGLE) Renewable Operating Permit No. MI-ROP-B2796-2015c and 40 CFR Part 63, Subpart UUUUU.

The specific objectives were to:

- Verify the emissions of hydrogen chloride (HCl) at the electrostatic precipitator (ESP) serving EU-BOILER7-SC
- Conduct the test program with a focus on safety

Montrose performed the tests to measure the emission parameters listed in Table 1-1.

**TABLE 1-1
SUMMARY OF TEST PROGRAM**

Test Date(s)	Unit ID/ Source Name	Activity/ Parameters	Test Methods	No. of Runs	Duration (Minutes)
9/28/2021	EU-BOILER7-SC	Moisture	EPA 4	3	60
9/28/2021	EU-BOILER7-SC	HCl	EPA 26	3	60

To simplify this report, a list of Units and Abbreviations is included in Appendix D.1. Throughout this report, chemical nomenclature, acronyms, and reporting units are not defined. Please refer to the list for specific details.

This report presents the test results and supporting data, descriptions of the testing procedures, descriptions of the facility and sampling locations, and a summary of the quality assurance procedures used by Montrose. The average emission test results are summarized and compared to their respective permit limits in Table 1-2. Detailed results for individual test runs can be found in Section 4.0. All supporting data can be found in the appendices.

**TABLE 1-2
SUMMARY OF AVERAGE COMPLIANCE RESULTS -
EU-BOILER7-SC
SEPTEMBER 28, 2021**

Parameter/Units	Average Results	Emission Limits
Hydrogen Chloride (HCl) lb/MMBtu	0.0022	0.0020

1.2 KEY PERSONNEL

A list of project participants is included below:

Facility Information

Source Location: DTE-St. Clair Power Plant
4400 River Road
East China, MI 48054

Project Contact: Mark Grigereit	Fred Meinecke
Role: Principal Engineer	Sr. Environmental Technician
Company: DTE	DTE
Telephone: 313-412-0305	313-897-0214
Email: Mark.grigereit@dteenergy.com	fred.meinecke@dteenergy.com

Agency Information

Regulatory Agency: EGLE
Agency Contact: Karen Kajiya-Mills
Telephone: 517-335-3122
Email: kajiya-millk@michigan.gov

Testing Company Information

Testing Firm: Montrose Air Quality Services, LLC	
Contact: Todd Wessel	David Trahan
Title: Client Project Manager	Field Project Manager
Telephone: 248-548-8070	248-548-8070
Email: twessel@montrose-env.com	dtrahan@montrose-env.com

Laboratory Information

Laboratory: Enthalpy Analytical, LLC
City, State: Durham, NC 27713
Method: EPA Method 26A

DTE-Saint Clair Power Plant
2021 Compliance Source Test Report

Test personnel and observers are summarized in Table 1-3.

**TABLE 1-3
TEST PERSONNEL AND OBSERVERS**

Name	Affiliation	Role/Responsibility
David Trahan	Montrose	Field Project Manager, QI
Michael Nummer	Montrose	Senior Field Technician
Mark Grigereit	DTE	Observer/Client Liaison

2.0 PLANT AND SAMPLING LOCATION DESCRIPTIONS

2.1 PROCESS DESCRIPTION, OPERATING, AND CONTROL EQUIPMENT

The DTE-SCPP employs the use of four coal-fired boilers (EU-BOILER2-SC, EU-BOILER6-SC, and EU-BOILER7-SC) to produce power throughout SE Michigan. Boiler No. 7 (EU-BOILER7-SC) is a combustion engineering boiler which operates as a base loaded unit capable of producing 3,580,000 pounds of steam per hour. The boiler's turbine generator was manufactured by Westinghouse and has a nominally rated capability of 460 MW.

EU-BOILER7-SC emissions are controlled by an American Standard ESP which has a collection efficiency of 99.6%. EU-BOILER7-SC was in operation for this test event.

2.2 FLUE GAS SAMPLING LOCATION

Information regarding the sampling location is presented in Table 2-1.

**TABLE 2-1
SAMPLING LOCATION**

Sampling Location	Stack Inside Diameter (in.)	Distance from Nearest Disturbance		Number of Traverse Points
		Downstream EPA "B" (in./dia.)	Upstream EPA "A" (in./dia.)	
EU-BOILER7-SC ESP Exhaust Stack	192.0	3,384 / 17.6	3,192 / 16.6	Gaseous: 1

See Appendix A.1 for more information.

2.3 OPERATING CONDITIONS AND PROCESS DATA

Emission tests were performed while EU-BOILER7-SC and the ESP were operating at the conditions required by the permit.

Plant personnel were responsible for establishing the test conditions and collecting all applicable unit-operating data. The process data that was provided is presented in Appendix B.

3.0 SAMPLING AND ANALYTICAL PROCEDURES

3.1 TEST METHODS

The test methods for this test program were presented previously in Table 1-1. Additional information regarding specific applications or modifications to standard procedures is presented below.

3.1.1 EPA Method 4, Determination of Moisture Content in Stack Gas

EPA Method 4 is a manual, non-isokinetic method used to measure the moisture content of gas streams. Gas is sampled at a constant sampling rate through a probe and impinger train. Moisture is removed using a series of pre-weighed impingers containing methodology-specific liquids and silica gel immersed in an ice water bath. The impingers are weighed after each run to determine the percent moisture.

The typical sampling system is detailed in Figure 3-1.

3.1.2 EPA Method 19, Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates

EPA Method 19 is a manual method used to determine (a) PM, SO₂, and NO_x emission rates; (b) sulfur removal efficiencies of fuel pretreatment and SO₂ control devices; and (c) overall reduction of potential SO₂ emissions. This method provides data reduction procedures, but does not include any sample collection or analysis procedures.


EPA Method 19 is used to calculate mass emission rates in units of lb/MMBtu. EPA Method 19, Table 19-2 contains a list of assigned fuel factors for different types of fuels, which can be used for these calculations.

3.1.3 EPA Method 26, Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources Non-Isokinetic Method

An integrated sample is extracted from the source and passed through a pre-purged heated probe and filter into dilute sulfuric acid and dilute sodium hydroxide solutions which collect the gaseous hydrogen halides and halogens, respectively. The filter collects particulate matter including halide salts but is not routinely recovered and analyzed. The hydrogen halides are solubilized in the acidic solution and form chloride (Cl⁻), bromide (Br⁻), and fluoride (F⁻) ions. The halogens have a very low solubility in the acidic solution and pass through to the alkaline solution where they are hydrolyzed to form a proton (H⁺), the halide ion, and the hypohalous acid (HClO or HBrO). Sodium thiosulfate is added in excess to the alkaline solution to assure reaction with hypohalous acid to form a second halide ion such that 2 halide ions are formed for each molecule of halogen gas. The halide ions in the separate solutions are measured by ion chromatography (IC).

For the purpose of this test, non-isokinetic sampling was performed. The typical sampling system is detailed in Figure 3-1.

**FIGURE 3-1
EPA METHOD 26 (HALIDES) SAMPLING TRAIN**



3.2 PROCESS TEST METHODS

Process samples of coal were taken by DTE personnel and analyzed for Proximate and Ultimate fuel analysis.

4.0 TEST DISCUSSION AND RESULTS

4.1 FIELD TEST DEVIATIONS AND EXCEPTIONS

Initially, EPA Method 3A was performed during this test event. However, the Run 3 oxygen (O₂) and carbon dioxide (CO₂) results were determined to be outside of the acceptable ratio. It was then decided that Montrose would use CO₂ data provided by DTE-Saint Clair Power Plant CEMS to determine the HCl emissions (lb/MMBtu).

4.2 PRESENTATION OF RESULTS

The average results are compared to the permit limits in Table 1-2. The results of individual compliance test runs performed are presented in Table 4-1. Emissions are reported in units consistent with those in the applicable regulations or requirements. Additional information is included in the appendices as presented in the Table of Contents.

**TABLE 4-1
 HCl EMISSIONS RESULTS -
 EU-BOILER7-SC**

Run Number	1	2	3	Average
Date	9/28/2021	9/28/2021	9/28/2021	--
Time	11:10-12:10	12:25-13:25	13:35-14:35	--
Process Data				
F-Factor, scf/MMBtu	1843.2	1843.2	1843.2	1843.2
Flue Gas Parameters				
CO ₂ , % volume wet*	10.67	10.64	10.63	10.65
flue gas temperature, °F	276.0	275.4	275.0	275.5
moisture content, % volume	8.52	9.12	9.17	8.94
Hydrogen Chloride (HCl)				
ppmvw	1.35	1.24	1.37	1.32
lb/MMBtu	0.0022	0.0020	0.0023	0.0022

* The CO₂ % volume wet data was provided by facility personnel

5.0 INTERNAL QA/QC ACTIVITIES

5.1 QA/QC AUDITS

The meter box and sampling train used during sampling performed within the requirements of their respective methods. All post-test leak checks, minimum metered volumes met the applicable QA/QC criteria.

EPA Method 26A analytical QA/QC results are included in the laboratory report. The method QA/QC criteria were met.

5.2 QA/QC DISCUSSION

All QA/QC criteria were met during this test program.


5.3 QUALITY STATEMENT

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is included in the report appendices. The content of this report is modeled after the EPA Emission Measurement Center Guideline Document (GD-043).

APPENDIX A FIELD DATA AND CALCULATIONS

Appendix A.1 Sampling Locations

EU-BOILER7-SC SAMPLING LOCATION SCHEMATIC



THIS PAGE LEFT INTENTIONALLY BLANK.

Appendix A.2

EU-BOILER7-SC ESP Exhaust Stack Data Sheets

TEST DATA

Number of Test Runs	3			
Traverse Points	12			
	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Stack Cross-Sectional Diameter 1 (circular) (in)	192.0	192.0	192.0	192.0
Stack Cross-Sectional Diameter 2 (circular) (in)	192.0	192.0	192.0	192.0
Barometric Pressure at Ground Level (Pbar) (in Hg)	30.01	30.03	30.02	30.02
Elevation Difference Between Ground Level and Meter Box Locations (ft)	580	580	580	580
Elevation Difference Between Ground Level and Sampling Locations (ft)	880	880	880	880
Initial Dry Gas Meter Reading (ft3)	454.880	500.190	546.100	
Final Dry Gas Meter Reading (ft3)	500.050	545.920	591.670	
Dry Gas Meter Calibration Factor (Gamma)	1.026	1.026	1.026	1.026
Dry Gas Meter Calibration Coefficient (Delta H@)	1.84	1.84	1.84	1.84
Total Sampling Run Time (Theta) (min)	60	60	60	60
Volume of Water Vapor Condensed in the Impingers (g)	80.0	81.8	85.7	82.5
Weight of Water Vapor Collected in Silica Gel (g)	8.3	13.8	9.9	10.7
Test Run Start Time (hrmin)	9/28/2021 11:10	9/28/2021 12:25	9/28/2021 13:35	
Test Run Stop Time (hrmin)	9/28/2021 12:10	9/28/2021 13:25	9/28/2021 14:35	

DETAILED RESULTS

Stack Gas Conditions	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Stack Cross-Sectional Area (A) (ft2)	201.06	201.06	201.06	201.06
Barometric Pressure at Sampling Location (in Hg)	29.13	29.15	29.14	29.14
Average Stack Gas Temperature (ts) (°F)	276.0	275.4	275.0	275.5
Average Stack Gas Temperature (Ts) (°R)	736.0	735.4	735.0	735.5
Percent by Volume Moisture as measured in Stack Gas (%H2O)	8.52	9.12	9.17	8.94

Test Results	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Volume of Dry Gas Sampled at Standard Conditions (Vmstd) (dscf)	44.691	44.950	44.648	44.763
Rate of Dry Gas Sampled at Standard Conditions (dscfm)	0.745	0.749	0.744	0.746
Dry Mole Fraction of Flue Gas (Mfd)	0.915	0.909	0.908	0.911
Average Pressure Differential of Orifice Meter (Delta H) (in H2O)	2.00	2.00	2.00	2.00
Average DGM Temperature (tm) (°F)	80.9	84.8	86.4	84.1
Average Dry Gas Meter Temperature (Tm) (°R)	540.9	544.8	546.4	544.1
Volume of Metered Gas Sample (Vm) (dry) (acf)	45.170	45.730	45.570	45.490

SAMPLING QA

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Post-Test Meter Calibration Check Value (Yqa)	1.048	1.038	1.043	1.043
Post-Test/Pre-Test Calibration Factor Difference (%)	-2.10	-1.18	-1.70	-1.66
Allowable Post-Test Leak Rate (dscfm)	0.020	0.020	0.020	0.020
Current Sampling Rate Status	OK	OK	OK	
1-Hour Sample Volume Based on Current Sampling Rate (dscf)	44.691	44.950	44.648	44.763

FUEL ANALYSIS

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Enter Fuel Type	Coal	Coal	Coal	
Examples: (Coal, NG, Wood, NA)	Valid Fuel Type	Valid Fuel Type	Valid Fuel Type	

Ultimate F Factor

Ultimate Analysis (Fuel) (Dry)	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Percent Hydrogen (%H)	4.74	4.74	4.74	4.74
Percent Carbon (%C)	72.70	72.70	72.70	72.70
Percent Sulfur (%S)	0.91	0.91	0.91	0.91
Percent Nitrogen (%N)	1.02	1.02	1.02	1.02
Percent Oxygen (%O)	14.85	14.85	14.85	14.85
Percent Ash	5.78	5.78	5.78	5.78
Gross Caloric Value (GCV) (dry)	12661	12661	12661	12661
Determined Fc Factor (scf/million BTU)	1843.2	1843.2	1843.2	1843.2

MEASURED DATA FROM TEST RUNS

Point Count	Run #	Run Time (min)	Orifice Delta H (in H2O)	DGM Temp OUT (°F)	Average DGM Temp (°F)	Stack Temp (°F)
1	1	0	2.00	79	79.00	277
2	1	5	2.00	79	79.00	277
3	1	10	2.00	79	79.00	276
4	1	15	2.00	80	80.00	276
5	1	20	2.00	80	80.00	276
6	1	25	2.00	80	80.00	276
7	1	30	2.00	81	81.00	276
8	1	35	2.00	82	82.00	276
9	1	40	2.00	82	82.00	276
10	1	45	2.00	82	82.00	276
11	1	50	2.00	83	83.00	276
12	1	55	2.00	84	84.00	274
13	2	0	2.00	84	84.00	275
14	2	5	2.00	84	84.00	276
15	2	10	2.00	84	84.00	276
16	2	15	2.00	84	84.00	276
17	2	20	2.00	84	84.00	276
18	2	25	2.00	85	85.00	275
19	2	30	2.00	85	85.00	276
20	2	35	2.00	85	85.00	274
21	2	40	2.00	85	85.00	276
22	2	45	2.00	86	86.00	275
23	2	50	2.00	86	86.00	275
24	2	55	2.00	86	86.00	275
25	3	0	2.00	86	86.00	275
26	3	5	2.00	86	86.00	275
27	3	10	2.00	86	86.00	276
28	3	15	2.00	86	86.00	276
29	3	20	2.00	86	86.00	276
30	3	25	2.00	86	86.00	275
31	3	30	2.00	86	86.00	275
32	3	35	2.00	87	87.00	275
33	3	40	2.00	87	87.00	275
34	3	45	2.00	87	87.00	274
35	3	50	2.00	87	87.00	274
36	3	55	2.00	87	87.00	274

TEST DATA - CO₂

CONCENTRATION CALCULATIONS - WET SYSTEM

Calculate the Average Effluent Carbon Dioxide CO₂ Concentration*

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Average CO ₂ Concentration Indicated by Gas Analyzer, wet basis (%-wet)	10.67	10.64	10.63	10.65

* Provided by facility personnel

TEST DATA - EPA Method 26A

DETAILED RESULTS

Emission Results:

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Hydrogen Chloride (HCl) Emission Rate (lb/MMBtu)	0.00221	0.00204	0.00225	0.00217

LAB RESULTS HCL

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
HCl Total Mass in sample, (mHCl) (mg)	2.83	2.64	2.90	2.79
Volume of Dry Gas Sampled at Standard Conditions (Vmstdm) (dscm)	1.27	1.27	1.26	1.27
HCl Concentration, dry basis (ConcHCl) (mg/dscm)	2.24	2.07	2.29	2.20
HCl Concentration (ppmvd) Dry @ 68°F	1.48	1.37	1.51	1.45
HCl Concentration (ppmw) Wet @ 68°F	1.35	1.24	1.37	1.32

US EPA Method 1 Traverse Point Determination

Relative Port Location	Left	Right
From Far Wall to Outside of Port (in.)	200.0	200.0
Nipple Length or Wall Thickness (in.)	8.0	8.0
Port Protrusion Length (opt) (in.)	0.0	0.0
Depth of Stack or Duct (in.)	192.0	192.0
Stack or Duct Type	Circular	
Port Hole Inner Diameter (in.)	-	
Stack or Duct Width (If Rectangular) (in.)		
Stack Outer Circumference (in.)		
Number of Ports Traversed	4	
Elevation of Meter Box from Ground Level (ft)	580	
Elevation of Ports from Ground Level (ft)	880	
Stack Build-up (in.)	0.0	
Stack Cross-Sectional Diameter 1 (in)	192.0	
Stack Cross-Sectional Diameter 2 (in)	192.0	

"Vertical" or "Horizontal" Flow Direction of Flow	Vertical
"Velocity" or "Isokinetic" Traverse	Up
	Isokinetic

Port Distance Upstream from Flow Disturbance (in.)	3192.0
Diameters Upstream from Flow Disturbance (* 0.5 De)	16.6
Minimum Traverse Points Needed for a Velocity Traverse *	12
Minimum Traverse Points Needed for a Isokinetic Traverse *	12

Port Distance Downstream from Flow Disturbance (in.)	3384.0
Diameters Downstream from Flow Disturbance (* 2.0 De)	17.6
Minimum Traverse Points Needed for a Velocity Traverse *	12
Minimum Traverse Points Needed for a Isokinetic Traverse *	12

Minimum Traverse Points per Method 1	12
Number of Traverse Points for this Circular Stack or Duct	12
Point Override	

Duct Area - in² **28952.92**
 Duct Area - ft² **201.0619**

Note:

Add nipple protrusion length to Point 1 only.
 Actual nipple length = (length - protrusion)

Relocate to a distance equal to the inside diameter of the nozzle being used or to the above minimum distances, whichever is larger.

This Stack having a diameter greater than 24-inches, shall have no traverse points located within 1.0-inch of the stack wall.

New Method 1 verified on 8/11/2021 by: **MN/MY**

Port	Point	% of Duct Depth	Dist. From Inside Wall (Decimal)	Dist. From Outside Wall (Decimal)
1	1	4.4	8.4	16.4
1	2	14.6	28.0	36.0
1	3	29.6	56.8	64.8
2	1	4.4	8.4	16.4
2	2	14.6	28.0	36.0
2	3	29.6	56.8	64.8
3	1	4.4	8.4	8.4
3	2	14.6	28.0	28.0
3	3	29.6	56.8	56.8
4	1	4.4	8.4	8.4
4	2	14.6	28.0	28.0
4	3	29.6	56.8	56.8

Project Information Date: <u>9-28-21</u> Project #: <u>PROJ-008915</u> Customer / Facility: <u>DTI SCPP</u> Unit ID / Sample Location: <u>UNIT 7</u> Run #: <u>1, 2, 3</u> Operator: <u>DT</u>	Equipment Identification Ref. Thermometer: <u>CAL KFT 4</u> Hygrometer: _____ Field Balance: <u>SCALE 3</u> Check Weights: <u>CAL KFT 4</u> Calipers: _____
---	---

Balance Audit: (Field balance must be within 0.5g of check weight mass) Date: <u>9-28-21</u> <table border="1" style="width:100%"> <tr> <td>Standard mass, g</td> <td><u>500.0</u></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Field balance mass, g</td> <td><u>500.0</u></td> <td></td> <td></td> <td></td> </tr> </table>	Standard mass, g	<u>500.0</u>				Field balance mass, g	<u>500.0</u>				Ambient Conditions (Mobile Lab) Relative humidity, %: _____ Temperature, °F: _____ Mobile lab #: _____
Standard mass, g	<u>500.0</u>										
Field balance mass, g	<u>500.0</u>										

Contents	Run 1			Run 2			Run 3		
	Initial	Final	Net Gain	Initial	Final	Net Gain	Initial	Final	Net Gain
Knockout									
Impinger 1 <i>In H₂SO₄</i>	<u>707.8</u>	<u>754.0</u>	<u>51.2</u>	<u>715.0</u>	<u>773.4</u>	<u>58.4</u>	<u>711.9</u>	<u>776.8</u>	<u>64.9</u>
Impinger 2 <i>In H₂SO₄</i>	<u>726.1</u>	<u>748.1</u>	<u>22.0</u>	<u>731.8</u>	<u>747.8</u>	<u>16.0</u>	<u>739.8</u>	<u>755.3</u>	<u>15.5</u>
Impinger 3	<u>654.5</u>	<u>661.3</u>	<u>6.8</u>	<u>659.2</u>	<u>666.6</u>	<u>7.4</u>	<u>660.2</u>	<u>665.5</u>	<u>5.3</u>
Impinger 4			<u>= 80</u>			<u>= 81.8</u>			<u>= 85.7</u>
Impinger 5									
Impinger 6									
Impinger 7									
Impinger 8									
Silica Gel	<u>942.0</u>	<u>950.3</u>	<u>8.3</u>	<u>909.7</u>	<u>923.5</u>	<u>13.8</u>	<u>936.5</u>	<u>946.4</u>	<u>9.9</u>
Train Net Gain (Vlc)			<u>88.3</u>			<u>95.6</u>			<u>95.6</u>

Nozzle Measurements (Difference between any two measurements must not be more than 0.004 in (0.1 mm))

Nozzle 1 diameters: _____ D1 _____ D2 _____ D3 _____ Average

Nozzle 2 diameters: _____ D1 _____ D2 _____ D3 _____ Average

Nozzle 3 diameters: _____ D1 _____ D2 _____ D3 _____ Average

Nozzle Material: quartz glass steel titanium Inconel other NONE

Probe Type: heated unheated air-cooled water-cooled other _____

Probe Liner: quartz glass steel Teflon other _____

Filter Information

Front Half: Quartz Fiber Glass Fiber Teflon Teflon/Quartz Other: _____

Filter Number: Run 1: _____ Run 2: _____ Run 3: _____ Run _____: _____

Back Half: Quartz Fiber Glass Fiber Teflon Teflon/Quartz Other: _____

Reagent Information	Sample Observations
Type	Lot Number
	Run 1 _____
	Run 2 _____
	Run 3 _____

QA/QC Check: Completeness: Legibility: Accuracy: Specifications:

Checked by: DT Team Leader: DT

**US EPA Method 4 Gravimetric Determination for Moisture
 US EPA Method 26 Sampling Train**

RUN 1			
	Initial Tare	Final Tare	Net Weights
Impinger No. 1	707.8	759.0	51.2
Impinger No. 2	726.1	748.1	22.0
Impinger No. 3	654.5	661.3	6.8
Total Condensed:			80.0
Silica Gel	942.0	950.3	8.3
Total Absorbed:			8.3
Overall Total:			88.3

RUN 2			
	Initial Tare	Final Tare	Net Weights
Impinger No. 1	715.0	773.4	58.4
Impinger No. 2	731.8	747.8	16.0
Impinger No. 3	659.2	666.6	7.4
Total Condensed:			81.8
Silica Gel	909.7	923.5	13.8
Total Absorbed:			13.8
Overall Total:			95.6

RUN 3			
	Initial Tare	Final Tare	Net Weights
Impinger No. 1	711.9	776.8	64.9
Impinger No. 2	739.8	755.3	15.5
Impinger No. 3	660.2	665.5	5.3
Total Condensed:			85.7
Silica Gel	936.5	946.4	9.9
Total Absorbed:			9.9
Overall Total:			95.6

Project Information			Sampling Conditions					ALT 011 TC ID: Ambient °F Ref. °F						
Date <u>9-28-21</u> Project # <u>008915</u>			Static Pressure, in. H ₂ O <u>-</u> Ambient Temp, °F <u>67</u>					Stack						
Customer/Facility <u>DTE SCPP</u>			Barometric Pressure, in. Hg <u>30.03</u> Ref. Barometer ID <u>NJAA</u>					Probe						
Unit ID/Sample Location <u>Unit 7</u>			Wind Speed / Direction <u>N 6 mph</u> Precipitation, Y/N <u>No</u>					Filter Box						
Run # <u>2</u> Operator <u>Mike Nummer</u>			Probe / Filter Temp Range, °F <u>248 + 25</u>					Filter Exit						
Sampling Equipment IDs		Calibration		Equipment Checks			Pre		Mid		Post		Meter outlet	
Meterbox ID <u>MB 12</u>		Meterbox Y <u>1.026</u>		Pitot (+), pass @ in. H ₂ O <input type="checkbox"/> @			<input type="checkbox"/> @		<input type="checkbox"/> @		<input type="checkbox"/> @		Impinger Exit	
Umbilical ID <u>UMB 15</u>		Meterbox ΔH@, in. H ₂ O <u>1.84</u>		Pitot (-), pass @ in. H ₂ O <input type="checkbox"/> @			<input type="checkbox"/> @		<input type="checkbox"/> @		<input type="checkbox"/> @		Other	
Nozzle ID <u>-</u>		Nozzle diameter, Dn, in. <u>-</u>		Pitot visual inspection <input checked="" type="checkbox"/> pass			<input type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		Ref. Thermometer ID	
Pitot / Probe ID <u>S'K</u>		Pitot coefficient, Cp <u>-</u>		Nozzle visual inspection <input type="checkbox"/> pass			<input type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		<input type="checkbox"/> pass		Continuity Check <input type="checkbox"/> Continuity w/ Proper Polarity	
Manometer ID <u>MB 12</u>		Manometer zero and level <input checked="" type="checkbox"/> yes		Meter, cfm @ in. Hg <u>0.000 @ 15</u>			<input type="checkbox"/> @		<input type="checkbox"/> @		<u>0.000 @ 6</u>		Notes:	
Sensitivity <u>0-10"</u>		K-Factor <u>-</u>		Intermediate leak check volume, ft ³ <u>1</u>			<u>1</u>		<u>1</u>					
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg
					Target	Actual			Box	Exit		Inlet	Outlet	
	0	12:25	500.19			2.0	275	261	261		66		84	2
	5		504.03			2.0	276	259	262		62		84	2
	10		507.85			2.0	276	260	261		58		84	2
	15		511.74			2.0	276	260	259		58		84	2
	20		515.48			2.0	276	261	260		58		84	2
	25		519.28			2.0	275	261	261		59		85	2
	30		523.10			2.0	276	261	260		60		85	2
	35		526.90			2.0	274	261	260		60		85	2
	40		530.70			2.0	276	260	259		61		85	2
	45		534.50			2.0	275	260	259		61		86	2
	50		538.31			2.0	275	260	261		60		86	2
	55		542.10			2.0	275	260	261		61		86	2
	60	13:25	545.92											
Averages														

QA/QC Check: Completeness Legibility Accuracy Specifications Checked By Mike Nummer Team Leader Dave Trahan

001AS-QMS-FM-225RB

Project Information				Sampling Conditions				ALT 011 TC ID: Ambient °F Ref. °F						
Date <u>9-28-21</u> Project # <u>008915</u>				Static Pressure, in. H ₂ O <u>-</u> Ambient Temp, °F <u>68</u>				Stack						
Customer/Facility <u>DTE SCPP</u>				Barometric Pressure, in. Hg <u>30.07</u> Ref. Barometer ID <u>NOAA</u>				Probe						
Unit ID/Sample Location <u>Unit 7</u>				Wind Speed / Direction <u>NNE 6 mph</u> Precipitation, Y/N, type				Filter Box						
Run # <u>3</u> Operator <u>Mike Nummer</u>				Probe / Filter Temp Range, °F <u>243 + 25</u>				Filter Exit						
Sampling Equipment IDs		Calibration		Equipment Checks		Pre		Mid		Post		Meter outlet		
Meterbox ID <u>MB 12</u>		Meterbox Y <u>1.026</u>		Pitot (+), pass @ in. H ₂ O <input type="checkbox"/> @		<input type="checkbox"/> @		<input type="checkbox"/> @		Impinger Exit		Other		
Umbilical ID <u>UMB 15</u>		Meterbox ΔH@, in. H ₂ O <u>1.84</u>		Pitot (-), pass @ in. H ₂ O <input type="checkbox"/> @		<input type="checkbox"/> @		<input type="checkbox"/> @		Ref. Thermometer ID		Continuity Check <input type="checkbox"/> Continuity w/ Proper Polarity		
Nozzle ID <u>-</u>		Nozzle diameter, Dn, in. <u>-</u>		Pitot visual inspection <input checked="" type="checkbox"/> pass		<input type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		Notes:				
Pitot / Probe ID <u>S'K</u>		Pitot coefficient, Cp <u>-</u>		Nozzle visual inspection <input type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		<input type="checkbox"/> pass						
Manometer ID <u>MB 12</u>		Manometer zero and level <input checked="" type="checkbox"/> yes		Meter, cfm @ in. Hg <u>0.00 @ 15</u>		<input type="checkbox"/> @		<u>0.00 @ 6</u>						
Sensitivity <u>0-10"</u>		K-Factor <u>-</u>		Intermediate leak check volume, ft ³		<u>1</u>		<u>1</u>						
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Onifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg
					Target	Actual			Box	Exit		Inlet	Outlet	
	0	13:35	546.10			2.0	275	261	260		60		86	2
	5		550.01			2.0	275	260	261		60		86	2
	10		553.83			2.0	276	260	259		52		86	2
	15		557.60			2.0	276	260	258		51		86	2
	20		561.37			2.0	276	260	261		50		86	2
	25		565.13			2.0	275	259	261		51		86	2
	30		568.92			2.0	275	260	259		51		86	2
	35		572.73			2.0	275	259	260		51		87	2
	40		576.51			2.0	275	259	263		51		87	2
	45		580.29			2.0	274	260	261		52		87	2
	50		584.07			2.0	274	260	262		52		87	2
	55		587.87			2.0	274	259	260		52		87	2
	60	14:35	591.67											
Averages														

QA/QC Check: Completeness Legibility Accuracy Specifications Checked By Mike Nummer Team Leader Dave Tishan

001AS-QMS-FM-225RB

Appendix A.3 Example Calculations

EPA Methods 4 and 26 Nomenclature and Sample Calculations

Run No. - 1

Constants

CO ₂ F _{wt} = 44.0	in wg= 0.073529	NO ₂ F _{wt} = 46.01	HClF _{wt} = 36.46
O ₂ F _{wt} = 32.0	gr= 0.000142857	COF _{wt} = 28.01	SO ₂ F _{wt} = 64.06
CON ₂ F _{wt} = 28.0	mmBtu= 1000000 Btu	H ₂ SO ₄ F _{wt} = 98.08	Cl ₂ F _{wt} = 70.91
H ₂ O F _{wt} = 18.015	CF _{wt} = 12.011	T _{std} = 527.67	P _{std} = 29.92
ArF _{wt} = 40.0	PF _{wt} = 44.0962		

Stack Variables

P _{bar} =	30.01 in. Hg	barometric pressure
E _{box} =	580 ft	elevation difference between ground level and meter box
E _{sam} =	880 ft	elevation difference between ground level and sampling ports
γ =	1.0260	gamma, dry gas meter calibration factor (dimensionless)
θ =	60.0 min	net run time (minutes)
V _{lc} =	88.3 g	total mass of liquid collected in impingers (g)
%CO ₂ =	10.67 %	percent CO ₂ by volume (wet basis) (dimensionless)
A =	201.0619 ft ²	stack cross-sectional area
T _{avg} =	736.00 R	average absolute flue gas temperature (460R+tsavg °F)
ΔH =	2.00 in. wg	average pressure differential of orifice meter
T _m =	540.92 R	dry gas meter temperature (460R+tsavg °F)
V _m =	45.17 ft ³	volume of metered gas sample (dry actual cubic feet)
Fc =	1843.1956 ft ³ /mmBtu	F-factor, standard cubic feet per million BTU

Calculated Stack Variables**Barometric pressure at sampling location**

NOTE: Barometric pressure recorded at ground level

$$P_{sam} = P_{bar} - [(E_{sam} / 100 \text{ ft}) * 0.1 \text{ in. Hg}]$$

$$P_{sam} = 30.01 - ((880.0 / 100) * 0.1)$$

$$P_{sam} = 29.13 \text{ in. Hg}$$

Volume of dry gas sampled at standard conditions (dscf)

$$V_{mstd} = \gamma * V_m * [P_{bar} - ((E_{box} / 100 \text{ ft}) * 0.1 \text{ in. Hg}) + (\Delta H / 13.6)] / P_{std} * (T_{std} / T_m)$$

$$V_{mstd} = 1.0260 * 45.170 * ((30.01 - ((580.0 / 100) * 0.1) + (2.0000 / 13.6)) / 29.92) * (527.7 / 540.917)$$

$$V_{mstd} = 44.691 \text{ ft}^3$$

Volume of water vapor at standard conditions (68 °F, scf)

$$V_{wstd} = (0.04716 \text{ ft}^3/\text{g}) * V_{lc}$$

$$V_{wstd} = (0.04716 * 88.3)$$

$$V_{wstd} = 4.2 \text{ ft}^3$$

Percent moisture by volume as measured in flue gas

$$\%H_2O \text{ (Measured)} = 100 * [V_{wstd} / (V_{wstd} + V_{mstd})]$$

$$\%H_2O \text{ (Measured)} = 100 * (4.164 / (4.164 + 44.691))$$

$$\%H_2O \text{ (Measured)} = 8.52$$

$$\%H_2O = 8.52$$

Dry mole fraction of flue gas (dimensionless)

$$M_{fd} = 1 - (\%H_2O / 100)$$

$$M_{fd} = 1 - (8.52 / 100)$$

$$M_{fd} = 0.915$$

Method 26A Calculations**HCl concentration (ppmvd)**

$$HCl_{ppmvd} = 1.48 \text{ ppmvd}$$

HCl concentration (ppmvw)

$$HCl_{ppmvw} = HCl_{ppmvd} * M_{fd}$$

$$HCl_{ppmvw} = 1.35 \text{ ppmvw}$$

HCl mass emission rate (lb/MMBtu)

$$MER_{HCl_{lbMMBtu}} = (((\text{Conc}_{HCl_{ppvw}} * 36.461 * \text{ult}_{Fc_1}) / (385.3 * 10^6)) * (100 / \%CO_2))$$

$$MER_{HCl_{lbMMBtu}} = 0.00221 \text{ lb/MMBtu}$$