

RELATIVE ACCURACY TEST AUDIT TEST REPORT No. 191-004

a Paba (195⊛) on Conservative [Stark (1) also as conservative [Paba (2)]

MIDLAND COGENERATION VENTURE MIDLAND MICHIGAN

EU TURBINE 13 & BOILERS 16-20

Prepared for:

Midland Cogeneration Venture 100 Progress Place Midland, Michigan 48640

Prepared by:

Coastal Air Consulting, Inc. 1531 Wyngate Dr. DeLand, FL 32724 (386) 451-0169

Completed On:

October 25 - 29, 2022

All testing activities and results represented herein were conducted and obtained in accordance with the approved EPA protocols listed in 40 CFR Parts 60 & 75. The contents have been reviewed and verified to be true and correct.

Stephen C. Webb



President Coastal Air Consulting, Inc.

TABLE OF CONTENTS

LETTER OF TRANSMITTAL

TITLE PAGE

EXECUTIVE SUMMARY

PROJECT STATISTICS

TABLE OF CONTENTS

- 1 Introduction
- 2 Test Program Summary
- Results of testing 3
- 4 Description of Source
- 5 Sampling Procedures
- Operating Conditions Quality Assurance 6
- 7

APPENDICES

- Reference Data 1
- 2 Plant Data
- 3 **Quality Assurance**
- Sample Calculations 4
- Figures 5
- 6 QSTI

PROJECT STATISTICS

Client:	Midland Cogeneration Venture (MCV)	
Facility:	Midland Michigan Generating Station	
Location:	100 ProgressPlace Midland, Michigan 48640	
Type of Process Tested:	EU Turbine 13 & EU Boilers 1,2,3,4,5 Units 16,17,18,19 & 20	
Test Protocols Performed:	Oxygen/Carbon Dioxide-EPA Method 3A Nitrogen Oxide -EPA Method 7E Carbon Monoxide – EPA Method 10	
Testing Firm:	Coastal Air Consulting, Inc. 1531 Wyngate Dr. DeLand, FL 32724	
Test Personnel:	Stephen Webb James Garrett QSTI	
Test Dates:	October 25 - 29, 2022	
Client Representative:	Jim Lazzaro	
Observers:	None	

1.0 Introduction

Coastal Air Consulting, Inc. (Coastal) was contracted by Midland Cogeneration Venture (MCV) to perform the annual RATA testing for NOx & CO. Testing was performed to satisfy the requirements contained in the Michigan Department of Environmental Quality (MDEQ) Renewable Operating Permit (ROP) No. MI-ROP-B6527a. The testing was performed by Coastal personnel, with the assistance of personnel assigned by Midland Cogeneration Venture (MCV).

2.0 Test Program Summary

A summary of test results developed by this source sampling program is presented in Table 1.

	Refuti	re noodrady oun	in in y		
UNIT	DATE	PARAMETERS	RELATIVE ACCURACY	BIAS	ALLOWABLE ANNUAL
EU-13	10/25/2022	NOx (lb/mmBtu)	3.54 %	NB	7.5%
EU Boiler 1	8/27/2022	NOx (lb/mmBtu)	6.97%	NB	7.5%
	8/27/2022	CO ppm	1.83 ppm	NA	<u><</u> 5 ppm
EU Boiler 2	8/27/2022	NOx (lb/mmBtu)	5.17%	NB	7.5%
	8/27/2022	CO ppm	1.09 ppm	NA	<u><</u> 5 ppm
EU Boiler 3	8/27/2022	NOx (lb/mmBtu)	2.74 %	NB	7.5%
	8/27/2022	CO ppm	4.30 ppm	NA	<u><</u> 5 ppm
EU Boiler 4	8/28&29/2022	NOx (lb/mmBtu)	1.90%	NB	7.5%
	8/28&29/2022	CO ppm	1.88 ppm	NA	<u><</u> 5 ppm
EU Boiler 5	8/27/2022	NOx (lb/mmBtu)	6.84%	NB	7.5%
	8/27/2022	CO ppm	1.89 ppm	NA	<u><</u> 5 ppm

TABLE 1 Relative Accuracy Summary

3.0 Results of Testing

The tests were conducted according to the procedures outlined in the Code of Federal Regulations, Appendix A of Title 40, Part 75 (40CFR75) and Appendix B of Title 40, Part 60 (40CFR60), including Performance Specifica Research, ED

DEC 05 2022

AIR QUALITY DIVISION

and 4A, and using sampling and calibration procedures specified in U.S. EPA Methods 3A, 7E, and 10.

The testing was conducted October 25-29 2022 by Stephen Webb and James Garrett of Coastal Aie Consulting, Inc. (CAC). Mr. Jim Lazzaro of MCV coordinated the test events and collected the process data. A representative from MDEQ was not on site to observe testing.

These results indicate that Unit EU TO13 Boilers EU 16-20 passed the RATA testing at the time of testing under normal operating conditions.

4.0 Description of Source

The MCV Unit 13 is operated as a cycling facility, in that they are expected to be brought on-line and off-line several times per day, most often during the summer months. The plant may also be dispatched at other appropriate times whenever system demand, capacity/steam and commercial energy availability, market, and/or as emergency conditions dictate. The unit is a combined-cycle natural gas-fired turbine rated brought on-line and off-line several times per day, most often during the summer at 249 MMBtu/hr at ISO conditions. Each turbine is equipped with steam injection for NO_x control.

The following serial numbers are associated with each dedicated CEMS.

Emission Unit	Pollutant	Serial Number
Unit 13 EUTURBINE 13	NOx	1207251992
	CO ₂	N1-ND-0858

The MCV Units 16-21 (EUBOILER1-EUBOILER6) are operated as a cycling facility, in that they are expected to be brought on-line and off-line several times per day, most often during the summer months. The plant may also be dispatched at other appropriate times whenever system demand, capacity/steam and commercial energy availability, market, and/or as emergency conditions dictate. Each boiler is rated at 370 MMBtu/hr and is fired on natural gas exclusively. Each boiler is equipped with low-NO_x burner technology and flue gas recirculation, and is capable of supplying 250,000 pounds per hour of steam at 800 psig and 750 degrees Fahrenheit.

The following serial numbers are associated with each dedicated CEMS.

Emission Unit	Pollutant	Serial Number
Unit 16 EUBOILER 1	NOx	0809828287
	СО	CM08090018
	O2	0803292
Unit 17 EUBOILER 2	NOx	0809828295
	СО	CM08020018
	O2	0803290
Unit 18 EUBOILER 3	NOx	0809828290
	СО	CM08020019
	O2	0803297
Unit 19 EUBOILER 4	NOx	0809828284
	СО	CM08020017
	O2	0803298
Unit 20 EUBOILER 5	NOx	0809828299
	СО	CM08090022
	O2	0803294
Unit 21 EUBOILER 6 *not tested	NOx	0809828292
	CO	CM08090020
did not run	O2	0803304

5.0 Sampling Procedures

6.0

EPA testing methods utilized during this test program include the following;

EPA Method 3A	Gas Analysis for CO ₂ , O ₂ , Excess Air and Dry Molecular Weight (Instrumental Analyzer Method)	
EPA Method 7E	Determination of Nitrogen Oxides Emissions From Stationary Sources	
EPA Method 10	Determination of Carbon Monoxide Emissions From Stationary Sources	
Operating Condi	tions	

MCV personnel monitored operating conditions throughout the duration of the sampling program. The data is included in Appendix 2 "Plant Data".

7.0 Quality Assurance Procedures

Quality assurance procedures followed during these testing activities were applied consistent with the requirements outlined by the EPA methods referenced in 40 CFR Parts 60 & 75.

RECEIVED DEC 05 2022 AIR QUALITY DIVISION