

RECEIVED

FEB 08 2016

AIR QUALITY DIVISION

Boiler No. 4 Particulate Matter Summary Report Central Michigan University

Prepared for:

Central Michigan University

Mount Pleasant, Michigan

Central Energy Facility 1720 South East Campus Drive Mount Pleasant, Michigan

> Project No. 15-4790.00 February 1, 2015

BT Environmental Consulting, Inc. 4949 Fernlee Ave Royal Oak, Michigan 48073 (248) 548-8070



EXECUTIVE SUMMARY

BT Environmental Consulting, Inc. (BTEC) was retained by Central Michigan University (CMU) to evaluate particulate matter (PM) concentrations and emission rates from Boiler No. 4 (EU-BLR4). The boiler is located on the CMU campus in Mt. Pleasant, Michigan. The emissions test program was conducted on January 22, 2016.

Testing of the boiler consisted of triplicate 60-minute test runs. The emissions test program was required by MDEQ Air Quality Division Renewable Operating Permit (ROP) No. MI-ROP-K2460-2015. The results of the emission test program are summarized by Table I.

Table I Boiler No. 4 Overall Emission Summary Test Date: January 22, 2016

Source	Permit Limit	Average Test Result
Boiler 4	0.15 lb / 1,000 lb exhaust gas,	0.11 lb / 1,000 lb exhaust gas,
	corrected to 50% excess air	corrected to 50% excess air





TABLE OF CONTENTS

1. IN	NTRODUCTION	1
1.A 1.B 1.C 1.D	IDENTIFICATION, LOCATION, AND DATES OF TEST PURPOSE OF TESTING SOURCE DESCRIPTION TEST PROGRAM CONTACTS	1 1
2. SI	UMMARY OF RESULTS	2
2.A	OPERATING DATA	3
2.в	APPLICABLE PERMIT	
2.C	Results	
3. S	OURCE DESCRIPTION	3
3.A	PROCESS DESCRIPTION	.3
3.B	PROCESS FLOW DIAGRAM	
3.C	RAW AND FINISHED MATERIALS	
3.D	PROCESS CAPACITY	
3.E	PROCESS INSTRUMENTATION	
4. S	AMPLING AND ANALYTICAL PROCEDURES	4
4.A	SAMPLING TRAIN AND FIELD PROCEDURES	4
4.B	RECOVERY AND ANALYTICAL PROCEDURES	5
4.C	SAMPLING PORTS	5
4.D	Traverse Points	5
5. T	EST RESULTS AND DISCUSSION	5
5.A	Results Tabulation	5
5.B	DISCUSSION OF RESULTS	
5.C	SAMPLING PROCEDURE VARIATIONS	6
5.D	PROCESS OR CONTROL DEVICE UPSETS	
5.E	Control Device Maintenance	
5.F	RE-TEST	
5.G	AUDIT SAMPLE ANALYSES	
5.H	CALIBRATION SHEETS	
5.I	SAMPLE CALCULATIONS	
5.J	FIELD DATA SHEETS	7
5 v	I ADODATORY DATA	



TABLE OF CONTENTS (continued)

SUMMARY TABLES

- Table 1 Test Personnel Summary
- Table 2 Overall Emissions Summary
- Table 3 Boiler 4 Particulate Matter Emission Rates

FIGURES

- Figure 1 USEPA Method 5 Sampling Diagram
- Figure 2 Boiler No. 4 Exhaust Stack Traverse Point Diagram
- Figure 3 USEPA Method 3A Sampling Diagram

APPENDIX

Appendix A	Field and Computer Generated Raw Data and Field Notes
Appendix B	Equipment Calibration and Span Gas Documents
Appendix C	Example Calculations

Appendix D Laboratory Analytical Results
Appendix E Raw CEM Data and Process Data



1. Introduction

BT Environmental Consulting, Inc. (BTEC) was retained by Central Michigan University (CMU) to evaluate particulate matter (PM) concentrations and emission rates from Boiler No. 4 (EU-BLR4). The boiler is located on the CMU campus in Mt. Pleasant, Michigan. The emissions test program was conducted on January 22, 2016. The purpose of this report is to document the results of the test program.

Testing of the boiler consisted of triplicate 60-minute test runs. The emissions test program was required by MDEQ Air Quality Division Renewable Operating Permit (ROP) No. MI-ROP-K2460-2015.

AQD has published a guidance document entitled "Format for Submittal of Source Emission Test Plans and Reports" (December 2013). The following is a summary of the emissions test program and results in the format suggested by the aforementioned document.

1.a Identification, Location, and Dates of Test

Sampling and analysis for the emission test program was conducted on January 22, 2016 at the Central Michigan University power house located in Mt. Pleasant, Michigan. The test program included evaluation of PM emissions from Boiler 4.

1.b Purpose of Testing

AQD issued Renewable Operating Permit No. MI-ROP-K2460-2015 to CMU January 7, 2015 and limits PM emissions from EU-BLR4 to not more than 0.15 pounds per 1,000 pounds of exhaust gas, corrected to 50% excess air.

1.c Source Description

Wood Boiler #4, a 68.5 MMBtu/hr. steam boiler, wood-fired for campus heat and electricity, equipped with ash handling system. The electricity is generated by steam coming from EU-BLR4 at 450 psi. After a small turbine (approx. 1 MW or 3.413 MMBtu), the steam pressure is down to 60 psi suitable for campus piping. The boiler emissions are controlled by a multi-cyclone collector and a wet scrubber. Emissions from chip unloading, wood feed, and ash handling are controlled by three individual baghouses.

1.d Test Program Contacts

The contact for the source and test report is:



Mr. John Fernandez SPV/Utility Operations Central Michigan University 1730 E. Campus Drive Mt. Pleasant, Michigan 48859 (989) 774-4437

Mr. Todd Wessel Senior Project Manager BT Environmental Consulting 4949 Fernlee Avenue Royal Oak, MI 48073 (616) 885-4013

Names and affiliations for personnel who were present during the testing program are summarized by Table 1.

Table 1
Test Personnel

1 est 1 ersonner			
Name and Title	Affiliation	Telephone	
Mr. John Fernandez SPV/Utility Operations	Central Michigan University 1730 E. Campus Drive Mt. Pleasant, Michigan 48859	(989)-774-4437	
Mr. Steve Smith Project Manager	BTEC 4949 Fernlee Avenue Royal Oak, MI 48073	(248) 548-8070	
Mr. Paul Diven Environmental Technician	BTEC 4949 Fernlee Avenue Royal Oak, MI 48073	(248) 548-8070	
Mr. Mason Sakshaug Environmental Technician	BTEC 4949 Fernlee Avenue Royal Oak, MI 48073	(248) 548-8070	
Mr. Dave Patterson	MDEQ Air Quality Division	(517) 284-6782	

2. Summary of Results

Sections 2.a through 2.d summarize the results of the emissions compliance test program.



2.a Operating Data

Process data monitored during the emissions test program included boiler load, pressure drops, water flow rate, and wood fuel usage.

2.b Applicable Permit

The applicable permit for this emissions test program is Renewable Operating Permit (ROP) No. MI-ROP-K2460-2015, with a SRN # of K2460. The boiler emission unit ID is EU-BLR4.

2.c Results

The overall results of the emission test program are summarized by Table 2 (see Section 5.a).

3. Source Description

Sections 3.a through 3.e provide a detailed description of the process.

3.a Process Description

Wood Boiler #4, a 68.5 MMBtu/hr. steam boiler, wood-fired for campus heat and electricity, equipped with ash handling system. The electricity is generated by steam coming from EU-BLR4 at 450 psi. After a small turbine (approx. 1 MW or 3.413 MMBtu), the steam pressure is down to 60 psi suitable for campus piping. The boiler emissions are controlled by a multi-cyclone collector and a wet scrubber. Emissions from chip unloading, wood feed, and ash handling are controlled by three individual baghouses.

3.b Process Flow Diagram

Due to the simplicity of the boiler a process flow diagram is not necessary.

3.c Raw and Finished Materials

The raw material used by the process is wood.

3.d Process Capacity

Boiler No. 4 (EU-BLR4) is a 68.5 mmbtu/hr.

3.e Process Instrumentation

Process data monitored during the emissions test program included boiler load, pressure drops, water flow rate, and wood fuel usage.



4. Sampling and Analytical Procedures

Sections 4.a through 4.d provide a summary of the sampling and analytical procedures used.

4.a Sampling Train and Field Procedures

The emissions test program utilized the following test methods codified at Title 40, Part 60, Appendix A of the Code of Federal Regulations (40 CFR 60, Appendix A):

- Method 1 "Sample and Velocity Traverses for Stationary Sources"
- Method 2 "Determination of Stack Gas Velocity and Volumetric Flowrate"
- Method 3A "Determination of Molecular Weight of Dry Stack Gas" (Analyzer)
- Method 4 "Determination of Moisture Content in Stack Gases"
- Method 5 "Determination of Particulate Matter Emissions from stationary sources"

Stack gas velocity traverses were conducted in accordance with the procedures outlined in Method 1 and Method 2. S-type pitot tubes with thermocouple assemblies, calibrated in accordance with Method 2, Section 4.1.1, were used to measure exhaust gas velocity pressures (using a manometer) and temperatures during testing. The S-type pitot tube dimensions outlined in Sections 2-6 through 2-8 are within specified limits, therefore, a baseline pitot tube coefficient of 0.84 (dimensionless) is assigned. A diagram of the sample points is provided in Figure 2.

Cyclonic flow checks were performed at each sampling location. The existence of cyclonic flow is determined by measuring the flow angle at each sample point. The flow angle is the angle between the direction of flow and the axis of the stack. If the average of the absolute values of the flow angles is greater than 20 degrees, cyclonic flow exists.

Boiler exhaust O_2/CO_2 content was measured using a Severomex 4100 O_2/CO_2 gas analyzer. A sample of the gas stream was drawn through an insulated stainless-steel probe with an in-line glass fiber filter to remove any particulate, a heated Teflon sample line, and through an electronic sample conditioner to remove the moisture from the sample before it enters the analyzer. Data was recorded at 4-second intervals on a PC equipped with data acquisition software.

Exhaust gas was extracted as part of the Method 5 sampling train. Exhaust gas moisture content was determined gravimetrically.



40 CFR 60, Appendix A, Method 5, "Determination of Particulate Emissions from Stationary Sources" was used to measure PM concentrations and calculate PM emission rates (see Figure 1 for a schematic of the sampling train).

BTEC's Nutech® Model 2010 modular isokinetic stack sampling system consists of (1) a steel nozzle, (2) a glass probe, (3) a Teflon connecting line to the impingers, (4) a set of four Greenburg-Smith (GS) impingers with the first two with 100 ml of deionized water (ii) an empty impinger, (iii) and an impinger filled with approximately 300 grams of silica gel. (5) a length of sample line, and (6) a Nutech® control case equipped with a pump, dry gas meter, and calibrated orifice.

Upon completion of the final leak test for each test run, the filter was recovered, and the nozzle, probe, and the front half of the filter holder assembly were brushed and triple rinsed with acetone which was collected in a pre-cleaned sample container.

BTEC labeled each container with the test number, test location, and test date, then marked the level of liquid on the outside of the container. Blank samples of the filter and acetone were collected. BTEC personnel transported all samples to BTEC's laboratory in Royal Oak, Michigan, for analysis.

4.b Recovery and Analytical Procedures

See section 4.a.

4.c Sampling Ports

A diagram of the stack showing sampling ports in relation to upstream and downstream disturbances is included as Figure 2.

4.d Traverse Points

A diagram of the stack indicating traverse point locations and stack dimensions is included as Figure 2.

5. Test Results and Discussion

Sections 5.a through 5.k provide a summary of the test results.

5.a Results Tabulation

The overall results of the emissions test program are summarized by Table 2. Detailed results for the emissions test program are summarized by Table 3.



Table 2 Boiler No. 4 Overall Emission Summary Test Date: January 22, 2016

Source	Permit Limit	Average Test Result
Boiler 4	0.15 lb / 1,000 lb exhaust gas,	0.11 lb / 1,000 lb exhaust gas,
	corrected to 50% excess air	corrected to 50% excess air

5.b Discussion of Results

The overall results of the emission test program are summarized by Table 2 (see Section 5.a). PM emissions from the boiler were 0.11 lb / 1,000 lb exhaust gas, corrected to 50% excess air which is below the corresponding limit of 0.15 lb / 1,000 lb exhaust gas, corrected to 50% excess air.

5.c Sampling Procedure Variations

There were no sampling variations used during the emission compliance test program.

5.d Process or Control Device Upsets

No upset conditions occurred during testing.

5.e Control Device Maintenance

There was no control equipment maintenance performed during the emissions test program.

5.f Re-Test

The emissions test program was not a re-test.

5.g Audit Sample Analyses

No audit samples were collected as part of the test program.

5.h Calibration Sheets

Relevant equipment calibration documents are provided in Appendix B.

5.i Sample Calculations

Sample calculations are provided in Appendix C.



5.j Field Data Sheets

Field documents relevant to the emissions test program are presented in Appendix A

5.k Laboratory Data

Laboratory analytical results are available in Appendix D.

Table 3
Boiler 4 Particulate Matter Emission Rates


Company Source Designation Test Date	CMU Boiler 4 1/22/2016	1/22/2016	1/22/2016	
Meter/Nozzle Information	P-1	P-2	P-3	Average
Moter Temperature Tm (F)	67.0	82.3	81.6	77.0
Meter Pressure - Pm (in. Hg)	29.6	82.3 29.6	29.6	29.6
Measured Sample Volume (Vm)	44.3	44.7	44.6	44.5
Sample Volume (Vm-Std ft3)	44.1	43.2	43,26	43.5
Sample Volume (Vm-Std m3)	1.25	1.22	1.22	1.23
Condensate Volume (Vm-std)	14.475	15.277	16.125	15.292
Gas Density (Ps(std) lbs/ft3) (wet)	0.0711	0.0708	0.0704	0.0708
				0.0708
Gas Density (Ps(std) lbs/ft3) (dry)	0.0792	0.0794	0.0793	
Total weight of sampled gas (m g lbs) (wet)	4.17	4.14	4.18	4.16 3.45
Total weight of sampled gas (m g lbs) (dry)	3.50	3,43	3.43	0.000830
Nozzle Size - An (sq. ft.)	0.000830	0.000830	0.000830	
Isokinetic Variation - I	102.8	102.7	105.5	103.7
Stack Data				
Average Stack Temperature - Ts (F)	174.8	168.9	172.2	172.0
Molecular Weight Stack Gas- dry (Md)	30.6	30.7	30.7	30.7
Molecular Weight Stack Gas-wet (Ms)	27.5	27.4	27.2	27.4
Stack Gas Specific Gravity (Gs)	0.950	0,946	0.941	0.946
Percent Moisture (Bws)	24.69	26.10	27.16	25.98
Water Vapor Volume (fraction)	0,2469	0.2610	0.2716	0.2598
Pressure - Ps ("Hg)	29.4	29.4	29.4	29.4
Average Stack Velocity -Vs (ft/sec)	23.4	23.1	23.0	23.2
Area of Stack (ft2)	19.8	19.8	19.8	19.8
Oxygen (%)	5.4	4.9	5.0	5.1
Carbon Dioxide (%)	15.1	15.8	15.5	15.5
Carbon Monoxide (%)	0.0	0.0	0.0	0.0
Nitrogen (%)	79.5	79.4	79.5	79.5
% Excess Air	34.5	30.2	31.4	32.0
Exhaust Gas Flowrate				
Flowrate ft³(Actual)	27.760	27 472	27 205	27,506
Flowrate ft ³ (Standard Wet)	27,760 22,673	27,473 22,649	27,285 22,377	22,567
Flowrate ft (Standard Wer) Flowrate ft ³ (Standard Dry)	17,074	16,737	16,301	16,704
Flowrate m ³ (standard dry)	483	474	462	473
Total Particulate Weights (mg)				
	151 2	257.2	284,9	227.0
Nozzle/Probe/Filter	171.3	257.2	204.Y	237.8
Total Particulate Concentration				
1b/1000 lb (wet)	0.091	0.137	0.150	0.13
lb/1000 lb (wet) corrected to 50% Excess Air	0.083	0.122	0.135	0.11
lb/1000 lb (dry)	0.108	0.165	0.183	0.15
mg/dscm (dry)	137.0	210.0	232.6	193.2
gr/dscf	0.0599	0.0918	0.1017	0.0844
Total Particulate Emission Rate		-		
lb/ hr	8.80	13.22	14,25	12.09

Figures

RECEIVED


FEB 0 8 2016


AIR QUALITY DIVE





diameter = 60.25"





Not to Scale

Points	Distance "
1	4.26
2	7.0
3	10.1
4	13.7
5	18.1
6	24.4
7	41.8
8	48.2
9	52.6
10	56.1
11	59.2
12	62.0
	I

Figure 2

Site: CMU MT. Pleasant, Michigan Sampling Dates: January 22,2016

BT Environmental Consulting,

<u>inc.</u>

4949 Fernlee Royal Oak, Michigan

BTEC Inc. \bigcirc Heated Sample Line Pump Moisture Removal System Servomex 4100 Vent O₂/CO₂ Analyzer Calibration Line Flow Controller шишшш Data Acquisition System, Laptop PC, & Pdaq Software Mid High Zero Calibration Gas Figure No. 3 Site: Sampling Date: BT Environmental Consulting Inc. January 22, 2016 **USEPA Method 3A** 4949 Fernlee Avenue Central Michigan University Royal Oak, MI 48073 Mount Pleasant, Michigan