



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
JACKSON DISTRICT OFFICE



LIESL EICHLER CLARK  
DIRECTOR

March 8, 2022

**EMAIL and CERTIFIED MAIL**

Pierre Gonyon  
St. Joseph Mercy Hospital  
5301 East Huron River Drive  
PO Box 995  
Ann Arbor, MI 48106-0995

SRN: M3431, Washtenaw County

Dear Pierre Gonyon:

**VIOLATION NOTICE**

On March 3, 2022, the Department of Environment, Great Lakes and Energy (EGLE), Air Quality Division (AQD), conducted an announced compliance inspection of St. Joseph Mercy Hospital (Hospital) located at 5301 East Huron River Drive, Ann Arbor Michigan. The purpose of this inspection was to determine the Hospital's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451) and the associated Air Pollution Control Rules, and conditions of Permit to Install (PTI) 318-74C.

During the inspection and subsequent records review, AQD staff determined the following:

Process Description	Rule/Permit Condition Violated	Comments
FGENGINES- Four diesel fuel-fired reciprocating engines driving electric generators.	PTI 318-74C Special Condition VIII. STACK/VENT RESTRICTION(S)- 1. SVENGINE1, 2. SVENGINE2, 3. SVENGINE3, 4. SVENGINE4.	4 stacks do not vent unobstructed vertically upward; have flipper style caps on top of exhaust stacks.

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by March 30, 2022. The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit written response to the EGLE, AQD Jackson District, at 301 East Louis B Glick Highway, Jackson, Michigan 49201, and submit copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at the DEQ, AQD P.O. Box 30260, Lansing, Michigan 48909-7760.

Pierre Gonyon  
St. Joseph Mercy Hospital  
March 8, 2022  
Page 2

If the Hospital believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during my recent inspection. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

A handwritten signature in blue ink that reads "Mike Kovalchick".

Mike Kovalchick  
Senior Environmental Engineer  
Air Quality Division  
517-416-5025

cc: Chris Ethridge, EGLE  
Jenine Camillari, EGLE  
Jeff Rathbun, EGLE  
Scott Miller, EGLE