



AT&T Services, Inc.
PO Box 5095
Rm 4W200M
San Ramon, CA 94583

T: 214.741.0351
www.att.com



March 10, 2017

State of Michigan – Dept. of Env. Quality
Air Quality Division
Cadillac Place
3058 West Grand Boulevard, Suite 2-300
Detroit, MI 48202-6058
Ph. 313.456.4700
Attn: Katherine Koster – Senior Env. Engineer

RE: Violation Notice – October 20, 2016

Dear Ms. Koster:

In response to the Violation Notice dated October 20, 2016, please find attached the following:

The notification of installation for the two (2) engines at 445 State Street and the three (3) engines installed at 444 Michigan Ave. The 445 State Street notification also includes confirmation that the two engines at this site are in fact operated in a certified manner.

A spreadsheet listing all of the maintenance records for all three locations for the time period specified in the Violation Notice.

The Notice of Violation also references documentation of fuel sample records. The fuel samples are something we wish to discuss with you over the phone, and we are hoping to coordinate a time that works for you to do so. Please let me know your availability for March 21st through March 24th.

Thank you for your time and patience in this matter.

Sincerely,
AT&T Services, Inc.



Julianne Barnum
Area Manager EH&S Air Team
G43913@att.com
(214) 741-0270



AT&T Services, Inc.
PO Box 5095
Rm 4W200M
San Ramon, CA 94583

T: 214.741.0351
www.att.com

March 10, 2017

State of Michigan – Dept. of Env. Quality
Air Quality Division
Cadillac Place
3058 West Grand Boulevard, Suite 2-300
Detroit, MI 48202-6058
Ph. 313.456.4700
Attn: Katherine Koster – Senior Env. Engineer

RE: New Engine Install – 445 State Street, Detroit, MI 48226

Dear Ms. Koster:

AT&T Communications of Michigan, Inc. (AT&T) currently owns and operates a multi-building campus under the Department of Environmental Quality (DEQ), Air Quality Division (AQD) jurisdiction. On 11/30/2011 and 01/01/2012 respectively, two (2) new 1,500 kW diesel WA-528828-0701 and WA-528823-0701 MTU emergency generators equipped with 2,328-hp Detroit Diesel model 12V4000 engines, as listed in Permit to Install (PTI) 153-10A, were installed at 445 State Street, Detroit, MI. This letter serves as the written notice of installation and the notification that each engine will be operated in a certified manner as required by PTI 153-10A Subsection VII.

If you have any questions, or need further information, please do not hesitate to contact me at (214) 741-0270

Sincerely,
AT&T Services, Inc.

Julianne Barnum
Area Manager EH&S Air Team



AT&T Services, Inc.
PO Box 5095
Rm 4W200M
San Ramon, CA 94583

T: 214.741.0351
www.att.com

March 10, 2017

State of Michigan – Dept. of Env. Quality
Air Quality Division
Cadillac Place
3058 West Grand Boulevard, Suite 2-300
Detroit, MI 48202-6058
Ph. 313.456.4700
Attn: Katherine Koster – Senior Env. Engineer


RE: New Engine Install – 444 Michigan Avenue, Detroit, MI 48226

Dear Ms. Koster:

AT&T Communications of Michigan, Inc. (AT&T) currently owns and operates a multi-building campus under the Department of Environmental Quality (DEQ), Air Quality Division (AQD) jurisdiction. On 11/30/2013 a new 2,250 kW diesel WA-580793-0812 MagnaMax emergency generator equipped with a 3,353-hp Detroit Diesel model 16V4000G83 engine, as listed in Permit to Install (PTI) 85-12 was installed at 444 Michigan Avenue, Detroit, MI. This letter serves as the written notice of installation as required by PTI 85-12 Subsection VII.

If you have any questions, or need further information, please do not hesitate to contact me at (214) 741-0270

Sincerely,
AT&T Services, Inc.



Julianne Barnum
Area Manager EH&S Air Team



AT&T Services, Inc.
PO Box 5095
Rm 4W200M
San Ramon, CA 94583

T: 214.741.0351
www.att.com

March 10, 2017

State of Michigan – Dept. of Env. Quality
Air Quality Division
Cadillac Place
3058 West Grand Boulevard, Suite 2-300
Detroit, MI 48202-6058
Ph. 313.456.4700
Attn: Katherine Koster – Senior Env. Engineer


RE: New Engine Install – 444 Michigan Avenue, Detroit, MI 48226

Dear Ms. Koster:

AT&T Communications of Michigan, Inc. (AT&T) currently owns and operates a multi-building campus under the Department of Environmental Quality (DEQ), Air Quality Division (AQD) jurisdiction. On 04/15/2015 two (2) new 2,250 kW diesel WA-580620-0812 and WA-581091-0812 Detroit Diesel emergency generators equipped with 3,351-hp MTU model 16V4000G83 engines, as listed in Permit to Install (PTI) 85-12 were installed at 444 Michigan Avenue, Detroit, MI. This letter serves as the written notice of installation as required by PTI 85-12 Subsection VII.

If you have any questions, or need further information, please do not hesitate to contact me at (214) 741-0270

Sincerely,
AT&T Services, Inc.


Julianne Barnum
Area Manager EH&S Air Team

| LWTR DATE | EMPLOYEE NAME | Job Type Desc | CLLI |
|-----------|-------------------|--|------------------|
| 5/27/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 445 STATE STREET |
| 5/27/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 445 STATE STREET |
| 5/24/2016 | LYSSE, JOREL | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 445 STATE STREET |
| 5/24/2016 | LYSSE, JOREL | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 445 STATE STREET |
| 5/19/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 445 STATE STREET |
| 5/19/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 445 STATE STREET |
| 5/19/2016 | LYSSE, JOREL | EMER ENGINES PERFORM ANNUAL DAY TANK SYSTEM TESTING AND MAINTENANCE. DOCUMENT RESULTS. | 445 STATE STREET |
| 6/19/2015 | YATES, TURRAN | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 445 STATE STREET |
| 6/18/2015 | YATES, TURRAN | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 445 STATE STREET |
| 6/17/2015 | YATES, TURRAN | EMER ENGINES PERFORM ANNUAL DAY TANK SYSTEM TESTING AND MAINTENANCE. DOCUMENT RESULTS. | 445 STATE STREET |
| 6/11/2015 | LIANGOS, CHRISTOS | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 445 STATE STREET |
| 6/11/2015 | YATES, TURRAN | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 445 STATE STREET |
| 6/8/2015 | LIANGOS, CHRISTOS | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 445 STATE STREET |
| 6/5/2015 | LIANGOS, CHRISTOS | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 445 STATE STREET |
| 6/4/2015 | LIANGOS, CHRISTOS | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 445 STATE STREET |
| 6/4/2015 | LIANGOS, CHRISTOS | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 445 STATE STREET |
| 6/1/2015 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 445 STATE STREET |
| 6/1/2015 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 445 STATE STREET |

| LWTR DATE | EMPLOYEE NAME | Job Type Desc | CLLI |
|------------|--------------------|--|------------------|
| 5/28/2015 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 445 STATE STREET |
| 5/20/2015 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 445 STATE STREET |
| 5/20/2015 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 445 STATE STREET |
| 5/30/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 445 STATE STREET |
| 5/30/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 445 STATE STREET |
| 5/29/2014 | LIANGOS, CHRISTOS | EMER ENGINES /TURBINES VERIFY RECORDS SHOW THAT ALL SPECIFIED CONTRACTED EMER. ENG. ETLS ARE CURRENTLY PERFORMED | 445 STATE STREET |
| 5/29/2014 | LIANGOS, CHRISTOS | EMER ENGINES /TURBINES VERIFY RECORDS SHOW THAT ALL SPECIFIED CONTRACTED EMER. ENG. ETLS ARE CURRENTLY PERFORMED | 445 STATE STREET |
| 5/28/2014 | LIANGOS, CHRISTOS | P0276 EMER ENGINES ANNUAL INSP & INSP BRKR / ALTERNATOR & BREAKER / CONTROL PARALLELING SYSTEM | 445 STATE STREET |
| 5/28/2014 | RYAN, MARY E | P0276 EMER ENGINES ANNUAL INSP & INSP BRKR / ALTERNATOR & BREAKER / CONTROL PARALLELING SYSTEM | 445 STATE STREET |
| 5/28/2014 | YATES, TURRAN | EMER ENGINES PERFORM ANNUAL DAY TANK SYSTEM TESTING AND MAINTENANCE. DOCUMENT RESULTS. | 445 STATE STREET |
| 5/28/2014 | LIANGOS, CHRISTOS | EMER ENGINES /TURBINES ANALYZE FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT TEST RESULTS PERFORMED BY A CERTIFIED TESTING LABORATORY | 445 STATE STREET |
| 5/28/2014 | LIANGOS, CHRISTOS | EMER ENGINES /TURBINES ANALYZE FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT TEST RESULTS PERFORMED BY A CERTIFIED TESTING LABORATORY | 445 STATE STREET |
| 5/28/2014 | RYAN, MARY E | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 445 STATE STREET |
| 5/28/2014 | LIANGOS, CHRISTOS | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 445 STATE STREET |
| 10/30/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 444 MICHIGAN AVE |
| 10/10/2014 | MACDONELL, BRUCE R | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |
| 10/21/2015 | LIANGOS, CHRISTOS | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |
| 10/13/2014 | MACDONELL, BRUCE R | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |

| LWTR DATE | EMPLOYEE NAME | Job Type Desc | CLLI |
|------------|-------------------|--|------------------|
| 10/21/2015 | LIANGOS, CHRISTOS | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |
| 10/20/2015 | LIANGOS, CHRISTOS | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 444 MICHIGAN AVE |
| 10/20/2015 | LIANGOS, CHRISTOS | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 444 MICHIGAN AVE |
| 10/26/2015 | LIANGOS, CHRISTOS | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 444 MICHIGAN AVE |
| 11/7/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 444 MICHIGAN AVE |
| 11/7/2016 | YATES, TURRAN | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 444 MICHIGAN AVE |
| 11/10/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |
| 11/10/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |
| 10/25/2016 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 444 MICHIGAN AVE |
| 11/14/2016 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 444 MICHIGAN AVE |
| 11/10/2016 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |
| 11/10/2016 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 444 MICHIGAN AVE |
| 11/7/2016 | YATES, TURRAN | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 444 MICHIGAN AVE |
| 11/8/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 444 MICHIGAN AVE |
| 10/10/2014 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 10/10/2014 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRCTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 10/29/2014 | LYSSE, JOREL | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 10/28/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 10/31/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |

| LWTR DATE | EMPLOYEE NAME | Job Type Desc | CLLI |
|------------|---------------|---|---------------|
| 10/28/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 10/28/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 10/28/2014 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 11/17/2015 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 11/17/2015 | YATES, TURRAN | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 11/5/2015 | RYAN, MARY E | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 1365 CASS AVE |
| 11/5/2015 | RYAN, MARY E | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 1365 CASS AVE |
| 11/9/2015 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 10/26/2015 | GORDON, SONJA | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 11/5/2015 | YATES, TURRAN | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 10/27/2016 | LYSSE, JOREL | EMER ENGINES /TURBINES COLLECT FUEL, CRANKCASE OIL, GEARBOX OIL & COOLANT SAMPLES FOR ANALYSIS | 1365 CASS AVE |
| 11/22/2016 | LYSSE, JOREL | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 1365 CASS AVE |
| 11/23/2016 | LYSSE, JOREL | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 1365 CASS AVE |
| 11/21/2016 | LYSSE, JOREL | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 1365 CASS AVE |
| 10/24/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 1365 CASS AVE |
| 10/24/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 1365 CASS AVE |
| 10/14/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 10/14/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |

| LWTR DATE | EMPLOYEE NAME | Job Type Desc | CLLI |
|------------|---------------|---|---------------|
| 10/14/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 11/4/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 11/4/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 11/4/2016 | LYSSE, JOREL | EMER ENG/TURBINE ANNUAL RUN, START BATT TEST, EAR PRTCT INSP, ENGINE ROOM INSP, OREMIS DATA VALIDATION & LOAD TEST - 4 HR MIN WITH FULL LOAD. | 1365 CASS AVE |
| 11/4/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 1365 CASS AVE |
| 11/4/2016 | LYSSE, JOREL | ENGINE AND FUEL SYSTEM FUEL FILTER INSPECTION AND OR CHANGE | 1365 CASS AVE |
| 11/22/2016 | YATES, TURRAN | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 1365 CASS AVE |
| 11/21/2016 | YATES, TURRAN | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 1365 CASS AVE |
| 11/23/2016 | YATES, TURRAN | EMER ENGINES INSP & CHG OR CLN ALL ONSET FLTRS. CHG OIL BASED ON LAB RESULTS EVERY 3 YRS OR 150 HRS (EXCLUDES FUEL FLTRS & WATER SEPERATORS) | 1365 CASS AVE |