


RIETH-RILEY CONSTRUCTION Co., Inc.

100% Quality • 100% Employee Owned • Over 100 Years

Mr. Tyler Salamasick
Environmental Quality Analyst
Air Quality Division

August 25, 2017

RE: Response to August 4, 2017 Violation Notice



Mr. Salamasick:

Rieth-Riley Construction Co., Inc. ("Rieth-Riley") is in receipt of your Violation Notice ("NOV") dated August 4, 2017 concerning the Baghouse at the Rieth-Riley facility in Big Rapids, located at 20251 East 19 Mile Road, Big Rapids, MI. The notice indicated that a pressure gauge at our facility was indicating readings outside of the permitted range at the time of the inspection.

Rieth-Riley had the plugged line to the gauge cleaned before you returned to complete the inspection. Rieth-Riley expends considerable time and effort in training and monitoring to ensure compliance with all environmental rules. Our investigation was unable to determine on what date the line became plugged, but it was clean and the gauge working properly on June 27th.

Please contact me at (574) 875-5183 if you have any questions or wish to discuss this matter further. Thank you in advance for your time and consideration.

Respectfully,

A handwritten signature in cursive script that reads "John Berscheit".

John Berscheit

Technical Services Manager
Office 574-875-5183
Fax 574-875-8405
Cell 574-532-0032
jberscheit@rieth-riley.com

