



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
KALAMAZOO DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

August 11, 2022

Dan DeJonge
Hudsonville Ice Cream
345 East 48th Street
Holland, Michigan 49423

SRN: N2499, Allegan County

Dear Dan DeJonge:

VIOLATION NOTICE

On May 25, 2022, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted an inspection of Hudsonville Ice Cream located at 345 East 48th Street, Holland, Michigan. The purpose of this inspection was to determine Hudsonville Ice Cream compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules.

During the inspection, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
Engine Room 1&2 refrigeration equipment	Rule 201	Engine Room 1&2 were installed or modified after December 2016 to have refrigeration equipment that uses anhydrous ammonia over a storage capacity of 500 gallons. PTI exemption Rule 280(2)(a) only exempts cold storage refrigeration equipment using anhydrous ammonia that has a storage capacity of less than 500 gallons.

During this inspection, it was noted that Hudsonville Ice Cream had installed and commenced operation of unpermitted equipment at this facility. The AQD staff advised Hudsonville Ice Cream on August 11, 2022, that this is a violation of Rule 201 of the administrative rules promulgated under Act 451.

A program for compliance may include a completed PTI application for the Engine Room 1&2 refrigeration equipment systems that use anhydrous ammonia and have a storage capacity of over 500 gallons. process equipment. An application form is available by request, or at the following website: www.michigan.gov/air.

Dan DeJonge
Hudsonville Ice Cream
Page 2
August 11, 2022

Be advised that Rule 201 requires that a permit be obtained prior to installation, construction, operation, reconstruction, relocation, or alteration of any process or process equipment which may be a source of an air contaminant.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by October 1, 2022 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to EGLE, AQD, Kalamazoo District, at 7953 Adobe Road, Kalamazoo, Michigan 49009 and submit a copy to Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If Hudsonville Ice Cream believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection of Hudsonville Ice Cream. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Cody Yazzie
Environmental Engineer
Air Quality Division
269-312-2754

cc: Mary Ann Dolehanty, EGLE
Annette Switzer, EGLE
Christopher Ethridge, EGLE
Brad Myott, EGLE
Jenine Camilleri, EGLE
Rex Lane, EGLE