

**DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION  
ACTIVITY REPORT: On-site Inspection**

N519960130

<b>FACILITY:</b> West Shore Hospital		<b>SRN / ID:</b> N5199
<b>LOCATION:</b> 1465 E Parkdale Avenue, MANISTEE		<b>DISTRICT:</b> Cadillac
<b>CITY:</b> MANISTEE		<b>COUNTY:</b> MANISTEE
<b>CONTACT:</b> Dan Debano , Director of Plant Operations and Security		<b>ACTIVITY DATE:</b> 09/23/2021
<b>STAFF:</b> Rob Dickman	<b>COMPLIANCE STATUS:</b> Compliance	<b>SOURCE CLASS:</b> MINOR
<b>SUBJECT:</b> Scheduled inspection of this minor source.		
<b>RESOLVED COMPLAINTS:</b>		

Inspected this facility with respect to Permit to Install 159-94. This permit is for and ethylene oxide sterilizer at the facility. I met with Dan Debano, Director of Plant Operations at the facility. He was not aware of any such equipment at the facility but guided me to the laboratory section of the hospital. The supervisor there confirmed that this equipment was removed from the facility several years ago and replaced with a steam sterilizer. This type of sterilizer is exempt under Rule 336.1281(2)(i).

We also had opportunity to look at the emergency generators located at the site. One is a Generac and the other a Cummins. Both are compression fired with a maximum output of 500 kW and are at least 15 years old, probably older. These generators are exempt from permitting under Rule 336.1285(2)(g).

As the permitted equipment has been removed and replaced by exempt equipment, it is recommended that this permit be voided.

NAME Rob Dickman                      DATE \_\_\_\_\_                      SUPERVISOR \_\_\_\_\_