

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Great Lakes Gas - Farwell Compressor Station 12	SRN : N5581
Location : 3400 HICKORY RD	District : Bay City
	County : CLARE
City : LAKE GEORGE State: MI Zip Code : 48633	Compliance Status : Compliance
Source Class : MAJOR	Staff : Nathanael Gentle
FCE Begin Date : 12/1/2020	FCE Completion Date : 12/1/2021
Comments : FCE for FY2022	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
12/01/2021	On-site Inspection	Compliance	Scheduled Onsite Inspection. FY2022
09/09/2021	ROP Semi 1 Cert	Compliance	No deviations reported.
02/24/2021	Stack Test	Compliance	Compliance demonstrations for turbines EU Unit 1206. Testing required to establish operating loads the unit can operate while maintaining compliance with NOx emission limits. Test results demonstrate EU-UNIT1206 can be operated from 63% to 100% capacity while maintaining compliance with NOx emission limits.
12/17/2020	Stack Test Observation	Compliance	Observation of required testing of EU-UNIT1206.

Nathanael Gentle

Date: 12/13/2021

Supervisor: *Chris Hare*

Name: