

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : ZEELAND BOARD OF PUBLIC WORKS		SRN : N7506
Location : 8943 RILEY STREET		District : Grand Rapids
		County : OTTAWA
City : ZEELAND	State: MI	Zip Code : 49464
Source Class : SM OPT OUT		Staff : Kaitlyn DeVries
FCE Begin Date : 6/1/2021		FCE Completion Date : 5/31/2022
Comments : FY 2022 FCE		

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
05/10/2022	On-site Inspection	Compliance	The purpose of the inspection was to determine compliance with Permit to Install (PTI) No. 187-05.
04/28/2022	MAERS	Compliance	MAERS EF's used for some pollutants and stack test data used for CO and VOC emissions. All data was reproduceable and accurate based upon the the information that was provided. No changes were made to the report. 4.28.2022. KDeVries.
01/31/2022	MACT (Part 63)	Compliance	The Semi-Annual Compliance Report for 40 CFR Part 63 Subpart ZZZZ for Reciprocating Internal Combustion Engines was received on time and complete. No deviations were reported for the reporting period, and periodic stack testing was conducted during the reporting period. Testing showed CO reduction of 100% for all five (5) engines. The catalyst pressure drop ranged from 2.8 to 3.4 " WC for the five (5) engines.

Activity Date	Activity Type	Compliance Status	Comments
08/17/2021	MACT (Part 63)	Compliance	The Semi-Annual Compliance Report for 40 CFR Part 63 Subpart ZZZZ for Reciprocating Internal Combustion Engines was received on time and complete. AQD is not delegated for this area source MACT. No deviations were reported for the reporting period, and no periodic stack testing was conducted during the reporting period.

Name: Karlindin

Date: 05/31/2022

Supervisor: 