Source Test Report for 2023 Compliance Testing Engine EU-COMP Bluewater Gas Storage, LLC Bluewater Gas Storage Station Columbus, Michigan

Prepared For:

Bluewater Gas Storage, LLC 333 South Wales Center Road Ray Township, MI 48096

Prepared By:

Montrose Air Quality Services, LLC 1371 Brummel Avenue Elk Grove Village, IL 60007

For Submission To:

Michigan Department of Environment, Great Lakes and Energy 525 West Allegan Street Lansing, MI 48933

Document Number: MW023AS-024983-RT-1961 Test Dates: September 14, 2023 Submittal Date: November 6, 2023







Review and Certification

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature:	Brandon Check	Date:	10 / 10 / 2023	
Name:	Brandon Check	Title:	Client Project Manager	

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature:	Henry M. Taylor	Date:	10 / 10 / 2023
Name:	Henry M. Taylor, QSTO	Title:	Senior Reporting QC Specialist



Table of Contents

Section

č

4

Page

	and the second second	
1.0	Intro	duction5
	1.1	Summary of Test Program5
	1.2	Key Personnel7
2.0	Plant	t and Sampling Location Descriptions9
	2.1	Process Description, Operation, and Control Equipment9
	2.2	Flue Gas Sampling Locations9
	2.3	Operating Conditions and Process Data9
3.0	Sam	pling and Analytical Procedures
	3.1	Test Methods 10
		3.1.1 EPA Methods 3A and 10
		3.1.2 EPA Method 1912
		3.1.3 EPA Method 320
	3.2	Process Test Methods14
4.0	Test	Discussion and Results
	4.1	Field Test Deviations and Exceptions
	4.2	Presentation of Results
5.0	Inter	rnal QA/QC Activities
	5.1	QA/QC Audits
	5.2	QA/QC Discussion
	5.3	Quality Statement
Lis	st of	f Appendices
А	Field	Data and Calculations
	A.1	Sampling Locations
	A.2	Instrumental Test Method Data
	A.3	Calculations/Results

В	Facil	ity Process Data
С	Qua	lity Assurance/Quality Control
	C.1	Units and Abbreviations43
	C.2	QA/QC Data51
	C.3	Accreditation Information/Certifications

3 of 108



1-2	Summary of Average Compliance Results – EU-COMP
1-3	Test Personnel and Observers8
2-1	Sampling Locations9
4-1	CO and Formaldehyde Emissions Results - EU-COMP
Lis	t of Figures
3-1	US EPA Method 3A and 10 Sampling Train11
3-2	EPA Method 320 Sampling Train14

Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station 1

*



1.0 Introduction

-

1.1 Summary of Test Program

Bluewater Gas Storage, LLC (Bluewater) contracted Montrose Air Quality Services, LLC (Montrose) to perform a compliance emissions test on the engine EU-COMP at the Bluewater Booster Station facility located in Ray Township, MI.

The tests were conducted to determine compliance with the emission limits listed in the Permit to Install (PTI) 139-08A issued by the Michigan Department of Environment, Great Lakes, and Energy (EGLE), and emission limits listed in 40 CFR 63 Subpart ZZZZ.

The specific objectives were to:

- Determine the carbon monoxide (CO) and formaldehyde (HCHO) emissions from one natural gas fired, compressor engine at the Bluewater Booster Ray Township Facility.
- · Conduct the test program with a focus on safety

Montrose performed the tests to measure the emission parameters listed in Table 1-1.

Table 1-1 Summary of Test Program

Test Date(s)	Unit ID/ Source Name	Activity/Parameters	Test Methods	No. of Runs	Duration (Minutes)
9/14/2023	EU-COMP	Sampling Locations	EPA 1		
		O ₂ , CO ₂	EPA 3A	3	60
		СО	EPA 10	3	60
		CH ₂ O	EPA 320	3	60



To simplify this report, a list of Units and Abbreviations is included in Appendix C.1. Throughout this report, chemical nomenclature, acronyms, and reporting units are not defined. Please refer to the list for specific details.

This report presents the test results and supporting data, descriptions of the testing procedures, descriptions of the facility and sampling locations, and a summary of the quality assurance procedures used by Montrose. The average emission test results are summarized and compared to their respective permit limits in Table 1-2. Detailed results for individual test runs can be found in Section 4.0. All supporting data can be found in the appendices.

The testing was conducted by the Montrose personnel listed in Table 1-3. The tests were conducted according to the test plan (protocol) dated July 26, 2023 that was submitted to the Michigan EGLE.

Table 1-2 Summary of Average Compliance Results – EU-COMP

September 14, 2023

Parameter/Units	Average Results	Emission Limits	
Carbon Monoxide (CO)			
ppmvd @ 15% O2	< 0.72 ppmvd @ 15% O ₂	≤ 47 ppmvd @ 15% O ₂	
Formaldehyde (HCHO)			
lb/hr	0.005 lb/hr	≤ 0.22 lb/hr	

Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station 1



1.2 Key Personnel

A list of project participants is included below:

Facility Information

*

Source Location:	Bluewater Gas Storage, LLC
	24551 29 Mile Road
	Ray Township, MI 48096
Project Contact:	James Jensen
Company:	Bluewater Gas Storage, LLC
Telephone:	414-221-2530
Email:	James.Jensen@wecenergygroup.com

Agency Information

Regulatory Agency:Michigan Department of Environment, Great Lakes and Energy
Jeremy HoweTelephone:231-878-6687Email:Howej@michigan.gov

Testing Company Information

Testing Firm: Montrose Air Quality Services, LLC Contact: Brandon Check Title: Client Project Manager Telephone: 630-860-4740 Email: bcheck@montrose-env.com



Test personnel and observers are summarized in Table 1-3.

Table 1-3

Test Personnel and Observers

Name	Affiliation	Role/Responsibility
Brandon Check	Montrose	Project Manager/Field Team Leader
Sean Wheeler	Montrose	Project Manager/Qualified Individual (QI)/Trailer operator
Jeremy Devries	Montrose	Field Support
Levi Butler	Montrose	Calculations and report preparation
James Jensen	WEC Energy Group	Client Liaison/Test Coordinator
Regina Angellotti	Michigan EGLE	Observer

Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station

8 of 108

.



2.0 Plant and Sampling Location Descriptions

2.1 Process Description, Operation, and Control Equipment

EU-COMP is a Caterpillar G3516 natural gas fired, 4 stroke, lean burn, reciprocating internal combustion engine driving compressors and has a rated capacity of 10.1 MMBtu/hr heat input. The engine emissions are controlled with catalytic oxidation systems.

2.2 Flue Gas Sampling Locations

Information regarding the sampling locations is presented in Table 2-1.

Table 2-1 Sampling Locations

4

	Stack Inside	Distance from Nea		
Sampling Location	Diameter (in.)	Downstream EPA "B" (in./dia.)	Upstream EPA "A" (in./dia.)	Number of Traverse Points
EU-COMP	11	~ 32 / 2.91	~ 120 / 10.91	Gaseous: 3

The sample locations were verified in the field to conform to EPA Method 1. See Appendix A.1 for more information.

2.3 Operating Conditions and Process Data

Emission tests were performed while the units and air pollution control devices were operating at the conditions required by the permit.

Plant personnel were responsible for establishing the test conditions and collecting all applicable unit-operating data. The process data that was provided is presented in Appendix B.



3.0 Sampling and Analytical Procedures

3.1 Test Methods

The test methods for this test program have been presented in Table 1-1. Additional information regarding specific applications or modifications to standard procedures is presented below.

3.1.1 EPA Methods 3A and 10, Determination of Oxygen and Carbon Monoxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)

Concentrations of O_2 and CO are measured simultaneously using EPA Methods 3A and 10, which are instrumental test methods. Conditioned gas is sent to a series of analyzers to measure the gaseous emission concentrations. The performance requirements of the method must be met to validate the data.

Pertinent information regarding the performance of the method is presented below:

- Method Options:
 - A dry extractive sampling system is used to report emissions on a dry basis
 - A paramagnetic analyzer is used to measure O₂
 - A gas filter correlation nondispersive infrared analyzer is used to measure CO
- Method Exceptions:
 - For gaseous emissions sampling, MDL are calculated for each analyzer.
 The ISDL is equal to the sensitivity of the instrumentation, which is 2% of the span value.
- Target and/or Minimum Required Sample Duration: 60 minutes
- Target Analytes: O2 and CO

The typical sampling system is detailed in Figure 3-1.



.

.





Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station



3.1.2 EPA Method 19, Measurement of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates

EPA Method 19 is a manual method used to determine (a) PM, SO₂, and NO_x emission rates; (b) sulfur removal efficiencies of fuel pretreatment and SO₂ control devices; and (c) overall reduction of potential SO₂ emissions. This method provides data reduction procedures, but does not include any sample collection or analysis procedures.

EPA Method 19 is used to calculate mass emission rates in units of lb/MMBtu. EPA Method 19, Table 19-2 contains a list of assigned fuel factors for different types of fuels, which can be used for these calculations.

Pertinent information regarding the performance of the method is presented below:

- Method Options:
 - F factor is the oxygen-based F factor, dry basis (Fd)
 - F factor is provided by Bluewater's DAS
 - Heat input data is calculated based on the fuel flow rate and higher heating value
 - Heat input data is provided by Bluewater's DAS
 - Higher Heating Value is provided by Bluewater's DAS
- Method Exceptions:
 - None



3.1.3 EPA Method 320, Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive FTIR Spectroscopy

EPA Method 320 is an instrumental test method used to measure specific analyte concentrations for which EPA reference spectra have been developed or prepared. Extractive emission measurements are performed using FTIR spectroscopy. The FTIR analyzer is composed of a spectrometer and detector, a high optical throughput sampling cell, analysis software, and a quantitative spectral library. The analyzer collects high resolution spectra in the mid infrared spectral region (400 to 4,000 cm⁻¹), which are analyzed using the quantitative spectral library. This provides an accurate, highly sensitive measurement of gases and vapors.

Pertinent information regarding the performance of the method is presented below:

Method Options:

.

- The specific analyte concentrations include H₂O and formaldehyde
- Continuous static sampling is performed at a flow rate of approximately 5 liters per minute
- $_{\odot}~$ A dynamic matrix spike is performed using formal dehyde and SF_6 as a tracer gas
- Method Exceptions:
 - To calculate the MDL for the target analytes, the guidelines in Appendix B of 40 CFR 136 are followed using the Student t-test to calculate the MDL for each analyte at a 99% confidence level. This follows EPA guidelines for reporting of zeroes or non-detects and also meets the NELAC requirements for determination of MDL values.
 - Independent calculations of optical path length are not performed because the instrument has a fixed path of 5.11 meters
- Target and/or Minimum Required Sample Duration: 60 minutes

The typical sampling system is detailed in Figure 3-2.



Figure 3-2 EPA Method 320 Sampling Train



3.2 Process Test Methods

The test plan did not require that process samples be collected during this test program; therefore, no process sample data are presented in this test report.

Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station

MW023AS-024983-RT-1961



*

4.0 Test Discussion and Results

4.1 Field Test Deviations and Exceptions

No field deviations or exceptions from the test plan or test methods occurred during this test program.

4.2 Presentation of Results

The average results are compared to the permit limits in Table 1-2. The results of individual compliance test runs performed are presented in Table 4-1. Emissions are reported in units consistent with those in the applicable regulations or requirements. Additional information is included in the appendices as presented in the Table of Contents.



Table 4-1

CO and Formaldehyde Emissions Results -EU-COMP

Parameter/Units	Run 1	Run 2	Run 3	Average
Date	9/14/2023	9/14/2023	9/14/2023	
Time	10:37-11:37	11:50-12:50	13:03-14:03	
Process Data				
fuel factor, Fd	8612	8612	8612	8612
fuel flow, MSCFH	6.4	6.5	6.6	6.5
fuel heating value, BTU/scf	1062	1062	1062	1062.0
heat input, MMBtu/hr	6.8	6.9	7.0	6.9
Sampling & Flue Gas Paramet	ers			
sample duration, minutes	60	60	60	
O2, % volume dry	5.36	5.30	5.37	5.34
moisture content, % volume	15.4	15.4	15.2	15.3
Carbon Monoxide (CO)				
ppmvd	< 1.90	< 1.90	< 1.90	< 1.90
ppmvd @ 15% O ₂	< 0.72	< 0.72	< 0.72	< 0.72
lb/MMBtu	< 0.002	< 0.002	< 0.002	< 0.002
lb/hr	< 0.011	< 0.011	< 0.011	< 0.011
Formaldehyde				
ppmvw	0.78	0.71	0.62	0.70
ppmvd	0.93	0.84	0.73	0.83
ppmvd @ 15% O2	0.35	0.32	0.28	0.32
lb/MMBtu	0.001	0.001	0.001	0.001
lb/hr	0.006	0.005	0.005	0.005

Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station 1

*



5.0 Internal QA/QC Activities

5.1 QA/QC Audits

EPA Method 3A and 10 calibration audits were all within the measurement system performance specifications for the calibration drift checks, system calibration bias checks, and calibration error checks.

The EPA Method 320 performance parameters measured included signal to noise tests, noise equivalent absorbance (NEA), detector linearity, background spectra, potential interferents, and cell and system leakage. Quality assurance procedures included baseline measurement with ultra-high purity nitrogen, measurement of a calibration transfer standard (~100 ppm ethylene), direct analyte calibration measurements, and measurements to determine baseline shift. SF₆ was also used as a tracer gas in the calibration gases to verify the sample delivery system integrity. A dynamic matrix spike was performed using SF₆ as a tracer gas. The method QA/QC criteria were met.

5.2 QA/QC Discussion

All QA/QC criteria were met during this test program.

5.3 Quality Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is included in the report appendices. The content of this report is modeled after the EPA Emission Measurement Center Guideline Document (GD-043).



Appendix A Field Data and Calculations

Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station 4



*

*

Appendix A.1 Sampling Locations

Bluewater Gas Storage, LLC 2023 Compliance Source Test Report, Bluewater Booster Station

MW023AS-024983-RT-1961

MONTROSE AIR QUALITY SERVICES INC.

EPA Method 1

Sample and Velocity Traverses Datasheet

-	2
LOCATION	DOOSTER
Glient WP	2
Project No:	224483
Plant RAY	TOWN XHIP MI
Date 9.14	.33
Technician 5D	
Duct Diameter (in.)	11.
Port Diameter (In.)	2"
Port Length (In.)	115
Port Type	M. NIPPLE
Distance A (ft)	16'-120"
Distance B (ft)	2'-8"
Distance A (Duct Diame	ters) (0.9)
Distance B (Duct Diame	tere) 2.91



For rectangular ducts



* 1



Location Schematic and Notes	Traverse Point	Distance (in.)
	1	2.24
	2	6.50
	3	10.16
	4	
	5	
	8	
	7	
	8	
	8	
	10	
	11	
	12	
	13	
	14	
indicate sample ports, height from grade, types of disturbances, access, unistrut configuration, etc.	15	
Distance to point must include length of port	16	