

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Scheduled Inspection

P054126756

FACILITY: LAKEWOOD WASTEWATER AUTHORITY		SRN / ID: P0541
LOCATION: 13751 HARWOOD ROAD, LAKE ODESSA		DISTRICT: Grand Rapids
CITY: LAKE ODESSA		COUNTY: IONIA
CONTACT: Doug Suntken, Plant Superintendent		ACTIVITY DATE: 09/03/2014
STAFF: Eric Grinstern	COMPLIANCE STATUS: Non Compliance	SOURCE CLASS: MINOR
SUBJECT: Unannounced inspection		
RESOLVED COMPLAINTS:		

FACILITY DESCRIPTION

The facility processes wastewater from the Villages of Lake Odessa and Woodland as well as the Townships of Odessa and Woodland.

COMPLIANCE EVALUATION

At the facility staff met with Doug Suntken, Plant Superintendent.

Inspection of the facility was in response to information provided to AQD regarding the installation of an emergency backup engine being installed at the facility without obtaining a permit to install.

Onsite staff observed that an engine had been installed and was electrically connected and had fuel in the supply tank. From previously supplied information the engine is a 1,500 kw Caterpillar diesel-fueled unit. The unit is a certified engine with EPA in regards to NSPS.

The engine was required to obtain a permit prior to installation.

Conclusion

Staff informed Mr. Suntken that a VN would be issued for the violation.

NAME 

DATE 9/5/14

SUPERVISOR 