

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Marquette Board of Light and Power	SRN : P0668
Location : 2200 Wright Street	District : Upper Peninsula
	County : MARQUETTE
City : MARQUETTE State: MI Zip Code : 49855	Compliance Status : Compliance
Source Class : MAJOR	Staff : Sydney Bruestle
FCE Begin Date : 1/1/2018	FCE Completion Date : 3/3/2019
Comments : FCE	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
02/13/2019	Scheduled Inspection	Compliance	Onsite Inspection to verify compliance with PTI 204-15 and all other applicable state and federal air quality regulations
03/27/2018	MAERS	Compliance	2017 MAERS - refer to MAERS for any comments
03/27/2018	Stack Test	Compliance	Replacement Pages for PM Compliance stack test.
03/27/2018	Stack Test	Compliance	PM and NOx emissions testing. Below permit limits for both PM and NOx

Name: 

Date: 3-28-19

Supervisor: 