



Compliance Emissions Test Report

**Performed for: Marquette Board of Light and Power
At The: Marquette Energy Center
EU-ENGINE02 Outlet Duct
Marquette, Michigan
July 23 and 25, 2019**

**Report Submittal Date
September 17, 2019**

© Copyright 2019
All rights reserved in
Mostardi Platt

Project No. M193006B

TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	1
2.0 TEST METHODOLOGY	2
Method 1 Traverse Point Determination	3
Method 2 Volumetric Flowrate Determination	3
Method 3A Oxygen (O ₂)/Carbon Dioxide (CO ₂) Determination	3
Method 5 Filterable Particulate Matter Determination	3
Method 7E Nitrogen Oxide (NO _x) Determination	4
Method 10 Carbon Monoxide (CO) Determination	4
Method 25A Volatile Organic Compound (VOC) Determination	4
Method 320 Fourier Transform Infrared (FTIR) Detector for Methane, Ethane, Formaldehyde, and Moisture Determination	5
3.0 TEST RESULT SUMMARY	8
4.0 CERTIFICATION	10
APPENDIX	
Appendix A - Test Section Diagrams	12
Appendix B - Sample Train Diagrams	17
Appendix C - Calculation Nomenclature and Formulas	22
Appendix D - Reference Method Test Data (Computerized Sheets)	36
Appendix E - Field Data Sheets	57
Appendix F - Calibration Data	71
Appendix G - FTIR QA/QC	93
Appendix H – Gas Cylinder Certificates	97
Appendix I – Plant Operating Data	109
Appendix J – Method 18 Results and FTIR Compound List	114

1.0 EXECUTIVE SUMMARY

MOSTARDI PLATT conducted a compliance emissions test program for Marquette Board of Light and Power (MBLP) on July 23 and 25, 2019 at the Marquette Energy Center (MEC) on the Reciprocating Internal Combustion Engine 2 (EU-ENGINE02) Outlet Duct in Marquette, Michigan. The purpose of the test program was to meet the compliance demonstration requirements for emission rate in accordance with Permit to Install 204-15A, 40 CFR Part 60 Subpart JJJJ, and 40 CFR Part 60 Subpart IIII. This report summarizes the results of the test program and test methods used.

The test location, test dates, and test parameters are summarized below.

Test Location	Test Dates	Test Parameters
EU-ENGINE02 Outlet Duct	July 23 and 25, 2019	Nitrogen Oxides (NO _x), Carbon Monoxide (CO), Carbon Dioxide (CO ₂), Oxygen (O ₂), Volatile Organic Concentration (VOC), Formaldehyde (CH ₂ O), Filterable Particulate Matter (FPM), Volumetric Flow, and Moisture

MBLP has installed a dual-fuel Wärtsilä 18V50DFm four stroke, lean burn 17 MW (nominal) engine (173 mmBtu/hr when firing natural gas as primary fuel, 154 mmBtu/hr when firing emergency backup fuel oil), compression ignition reciprocating internal combustion engine used for electrical generation. The RICE electric generating unit utilizes pipeline quality natural gas and is equipped with selective catalytic reduction (SCR) for nitrogen oxides (NO_x) control and an oxidation catalyst system for carbon monoxide (CO), volatile organic compound (VOC), and organic hazardous air pollutant (HAP) control. The RICE electric generating unit exhausts into an individual stack.

Selected results of the test program are summarized below. A complete summary of emission test results follows the narrative portion of this report.

Source	Fuel	Parameter	Emission Limit	Test Results
EU-ENGINE02 Outlet Duct 7/23/19	Natural Gas	Nitrogen Oxides (NO _x)	3.3 lb/hr	1.0 lb/hr
			1.0 grams/HP-hr	0.020 grams/HP-hr
			82 ppmvd@15% O ₂	1.8 ppmvd@15% O ₂
		Carbon Monoxide (CO)	5.0 lb/hr	0.2 lb/hr
			2.0 grams/HP-hr	0.003 grams/HP-hr
			270 ppmvd@15% O ₂	0.4 ppmvd@15% O ₂
		Volatile Organic Compounds (VOC)	16.5 lb/hr	1.5 lb/hr
			0.7 grams/HP-hr	0.031 grams/HP-hr
			60 ppmvd@15% O ₂	2.9 ppmvd@15% O ₂
		Formaldehyde (CH ₂ O)	0.648 lb/hr	0.18 lb/hr

Source	Fuel	Parameter	Emission Limit	Test Results
EU-ENGINE02 Outlet Duct 7/23/19 and 7/25/19	Light Fuel Oil	NO _x	21.0 lb/hr	8.0 lb/hr
			2.58 g/HP-hr	0.161 g/HP-hr
		CO	N/A	0.1 lb/hr
		VOC	N/A	0.5 lb/hr
		CH ₂ O	N/A	0.03 lb/hr
		Filterable Particulate Matter (FPM)	0.15 g/kW-hr	0.032 g/kW-hr

The identifications of the individuals associated with the test program are summarized below.

TEST PERSONNEL INFORMATION		
Location	Address	Contact
Test Coordinator/ Test Facility	Marquette Board of Light and Power Marquette Energy Center 2200 Wright Street Marquette, Michigan 49855	Mr. Thomas J. Skewis Environmental Technician (906) 225-8670 (office) tskewis@mblp.org
Testing Company Representative	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Mr. John Nestor Project Manager (630) 993-2100 (phone) rsollars@mp-mail.com

The test crew consisted of Messrs. J. Carlson, N. Colangelo, and J. Nestor. Mr. Tom Gasloli with the Michigan Department of Environmental Quality observed the test program.

2.0 TEST METHODOLOGY

Emission testing was conducted following the methods specified in Code of Federal Regulations, Title 40, Part 60, Appendix A (40CFR60), 40CFR51, and 40CFR63. Schematics of the test section diagrams and sampling trains used are included in Appendix A and B, respectively. Calculation examples and nomenclature are included in Appendix C. Copies of analyzer print-outs and field data sheets for each test run are included in Appendices D and E, respectively.

The following methodologies were used during the test program:

Method 1 Traverse Point Determination

Test measurement points were selected in accordance with Method 1. The characteristics of the measurement location are summarized below.

TEST POINT INFORMATION						
Location	Diameter (Feet)	Area (Square Feet)	Upstream Distance (Inches)	Downstream Distance (Inches)	Test Parameter	Number of Sampling Points
EU-ENGINE02 Outlet Duct	5.25	21.65	>0.5	>2.0	Volumetric Flow	16
					NO _x /CO/VO C/O ₂ /CO ₂	12 (stratification test), 3 (Runs 1 through 3)

A null point pitot traverse check was performed utilizing a Type S pitot tube to verify the absence of cyclonic flow per USEPA Method 1, Section 11.4. The null point at the test location averaged 5 degrees which meets the requirements. The results of this traverse can be found in Appendix D.

Method 2 Volumetric Flowrate Determination

Gas velocity was measured following Method 2, for purposes of calculating stack gas volumetric flow rate. An S-type pitot tube, differential pressure gauge, Thermal couple and temperature readout were used to determine gas velocity at each sample point. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix F.

Method 3A Oxygen (O₂)/Carbon Dioxide (CO₂) Determination

Flue gas O₂ was determined in accordance with Method 3A. An ECOM analyzer was used to determine stack gas oxygen content connected to the outlet of the FTIR analyzer.

Flue gas carbon dioxide concentrations and emission rates were determined in accordance with Method 3A. An MKS MultiGas 2030 FTIR spectrometer was used to determine the CO₂ concentrations, in the manner specified in the Method. Nitrogen Content was determined from the difference of CO₂ and O₂.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 375°F. The entire system was calibrated in accordance with the Method, using certified calibration gases introduced at the probe, before and after each test run.

All of the equipment used was calibrated in accordance with the specifications of the Method and calibration data are included in Appendix F. Copies of the gas cylinder certifications are included in Appendix H.

Method 5 Filterable Particulate Matter Determination

Flue gas filterable particulate matter concentrations and emission rates are determined in accordance with Method 5. The probe and filter housing are maintained at a temperature of 248°F +/- 25°F. An Environmental Supply Company, Inc. sampling train is used to sample stack gas at an isokinetic rate. Four impingers were utilized. The impingers were weighed prior to and after each test run in order to determine moisture content of the stack gas. The total sample time was 60 minutes, with twelve sample points being utilized. A minimum of 30 dry standard cubic feet was sampled for the run.

Particulate matter in the sample probe was recovered utilizing acetone; a minimum of six passes of the probe brush through the entire probe was performed, followed by a visual inspection of the acetone exiting the probe. The acetone solution exiting the probe was clear, therefore the wash was considered complete. The nozzle was then removed from the probe and cleaned in a similar manner, utilizing an appropriately sized nozzle brush. The filter housing was washed a minimum of three times with acetone and inspected for cleanliness, and the filter placed in its corresponding petri dish. The acetone wash and the filter were labeled and marked, then analyzed off site by Mostardi Platt personnel in accordance with the method.

All of the equipment used is calibrated in accordance with the specifications of the Method. Calibration data is presented in the Appendix of the final report.

Method 7E Nitrogen Oxide (NO_x) Determination

Flue gas NO_x concentrations and emission rates were determined in accordance with Method 7E. An MKS MultiGas 2030 FTIR spectrometer was used to determine nitrogen oxide concentrations, in the manner specified in the Method.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 375°F. The entire system was calibrated in accordance with the Method, using certified calibration gases introduced at the probe, before and after each test run.

A list of calibration gases used and the results of all calibration and other required quality assurance checks can be found in Appendix F. Copies of calibration gas certifications can be found in Appendix H.

Method 10 Carbon Monoxide (CO) Determination

Flue gas CO concentrations and emission rates were determined in accordance with Method 10. An MKS MultiGas 2030 FTIR spectrometer was used to determine carbon monoxide concentrations, in the manner specified in the Method.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 375°F. The entire system was calibrated in accordance with the Method, using certified calibration gases introduced at the probe, before and after each test run.

A list of calibration gases used and the results of all calibration and other required quality assurance checks can be found in Appendix F. Copies of calibration gas certifications can be found in Appendix H.

Method 25A Volatile Organic Compound (VOC) Determination

Total hydrocarbon (THC) concentrations and emission rates were determined in accordance with Method 25A. Stack gas was delivered to the system via a Teflon® sampling line, heated to a minimum temperature of 375°F.

Methane and ethane concentrations were determined in accordance with Method 320 and then subtracted from the THC concentrations in order to determine VOC emissions. The methane concentration was also corrected for a response factor on the Thermo 51i Total Hydrocarbon analyzer.

The system was calibrated before and after each test run using certified calibration gases of propane for the THC determination. Calibration data are presented in Appendix F, field sheets are presented in Appendix D, and copies of gas certifications are presented in Appendix H.

Method 320 Fourier Transform Infrared (FTIR) Detector for Methane, Ethane, Formaldehyde, and Moisture Determination

Flue gas methane, ethane, formaldehyde, and moisture concentrations and emission rates were determined in accordance with Method 320. FTIR data was collected using an MKS MultiGas 2030 FTIR spectrometer. The FTIR was equipped with a temperature-controlled, 5.11 meter multi-pass gas cell maintained at 191°C. Gas flows and sampling system pressures were monitored using a rotameter and pressure transducer.

All data was collected at 0.5 cm⁻¹ resolution. Each spectrum was derived from the coaddition of 62 scans, with a new data point generated approximately every one minute. Analyzer data for each run is present in Appendix D.

SAMPLING SYSTEM PARAMETERS				
MKS Serial #	Sampling Line	Probe Assembly	Particulate Filter Media	Operating Temperatures
019088128	100' 3/8" dia., heated Teflon	Heated 3', 3/8" dia. SS	0.01µ heated borosilicate glass fiber	191°C

QA/QC procedures followed US EPA Method 320. See below for QA/QC procedure details and list of calibration gas standards. All calibration gases were introduced to the analyzer and the sampling system using an instrument grade stainless steel rotameter. All QA/QC procedures were within the acceptance criteria allowance of the applicable EPA methodology. See Appendix G for FTIR QA/QC Data.

FTIR QA/QC PROCEDURES						
QA/QC Specification	Purpose	Calibration Gas Analyte	Delivery	Frequency	Acceptance Criteria	Result
M320: Zero	Verify that the FTIR is free of contaminants & zero the FTIR	Nitrogen (zero)	Direct to FTIR	pre/post test	< MDL or Noise	Pass
M320: Calibration Transfer Standard (CTS) Direct	Verify FTIR stability, confirm optical path length	Ethylene	Direct to FTIR	pretest	+/- 5% cert. value	Pass
M320: Analyte Direct	Verify FTIR calibration	Formaldehyde, Nitrous Oxide	Direct to FTIR	pretest	+/- 5% cert. value	Pass
M320: CTS Response	Verify system stability, recovery, response time	Ethylene	Sampling System	Daily, pre/post test	+/- 5% of Direct Measurement	Pass
M320: Zero Response	Verify system is free of system bias	Nitrogen (zero)	Sampling System	pretest	Bias correct data	Pass
M320: Analyte Spike	Verify system ability to deliver and quantify analyte of interest in the presence of effluent gases	Formaldehyde, Nitrous Oxide	Dynamic Addition to Sampling System, 1:10 effluent	Throughout testing – daily	+/- 30% theoretical recovery	Pass

Note: The determined concentrations from direct analyses were used in all system/spike recovery calculations.

CALIBRATION GAS STANDARDS				
Components	Concentration (ppm)	Vendor	Cylinder #	Standard Type
Ethylene	100.0	Airgas	CC111625	Primary +/- 1%
Formaldehyde, Nitrous Oxide	0.9715 99.10	Airgas	CC717067	Certified Standard-Spec +/- 5%
Nitrogen	Zero Gas	Airgas	N/A	UHP Grade

Analyte Spiking

Formaldehyde spiking was performed prior to testing to verify the ability of the sampling system to quantitatively deliver a sample containing Formaldehyde from the base of the probe to the FTIR. Analyte spiking assures the ability of the FTIR sampling system to recover volatile organics in the presence of effluent gas.

As part of the spiking procedure, samples were measured to determine native formaldehyde concentrations to be used in the spike recovery calculations. The analyte spiking gases contained Nitrous Oxide (N₂O). The determined N₂O concentration in the spiked sample was used to calculate the dilution factor of the spike and thus used to calculate the concentration of the spiked formaldehyde. The spike target dilution ratio was 1:10 or less.

The following equation illustrates the percent recovery calculation.

$$DF = \frac{SF_6(spik)}{SF_6(direct)} \quad (\text{Sec. 9.2.3 (3) USEPA Method 320})$$

$$CS = DF * Spike(dir) + Unspike(1 - DF) \quad (\text{Sec. 9.2.3 (4) USEPA Method 320})$$

DF = Dilution factor of the spike gas

SF_{6(dir)} = SF₆ concentration measured directly in undiluted spike gas

SF_{6(spik)} = Diluted SF₆ concentration measured in a spiked sample

Spike_{dir} = Concentration of the analyte in the spike standard measure by the FTIR directly

CS = Expected concentration of the spiked samples

Unspike = Native concentration of analytes in unspiked samples

Post Collection Data Validation

As part of the data validation procedure, reference spectra are manually fit to that of the sample spectra and a concentration is determined. The reference spectra are scaled to match the peak amplitude of the sample, thus providing a scale factor. The scale factor multiplied by the reference spectra concentration is used to determine the concentration value for the sample spectra. Sample pressure and temperature corrections are then applied to compute the final sample concentration. The manually calculated results are then compared with the software-generated results. The data is then validated if the two concentrations are within ± 20% agreement. If there is a difference greater than ± 20% the spectra are reviewed for possible spectra interferences or any other possible causes leading to incorrectly quantified data.

Detection Limit

The detection limit of each analyte was calculated following Annex A2 of ASTM D6348-12 procedure using spectra that contained similar amounts of moisture and carbon dioxide.

Analyte	Detection Limit (ppmv wet)	Detection Limit (%v)
Methane	1.0	-
Ethane	0.5	-
Formaldehyde	0.2	
Moisture	-	0.1

QA/QC data are found in Appendix G. Copies of gas cylinder certifications are found in Appendix H. All concentration data were recorded on a wet, volume basis. The sample and data collection followed the procedures outlined in Method 320.

3.0 TEST RESULT SUMMARY

Marquette Board of Light and Power Marquette Energy Center EU-ENGINE02 Gaseous Summary Full Load - Natural Gas Firing																	
Test No.	Date	Start Time	End Time	NO _x ppmvd	CO ppmvd	CO ₂ % (dry)	O ₂ % (dry)	Formaldehyde, ppmvd	Moisture, %	Flowrate, DSCFM	Flowrate, SCFM	THC ppm as C ₂ H ₆ (wet)	CH ₄ ppm as CH ₄ (wet)	CH ₄ ppm as C ₂ H ₆ (wet)*	C ₂ H ₆ (wet)	C ₂ H ₆ ppm as C ₂ H ₆ (wet)	VOC ppm as C ₂ H ₆ (wet)
1	07/23/19	10:26	11:25	2.6	0.9	5.4	11.4	0.8	10.3	48,528	54,100	404.0	886.2	357.4	62.5	41.7	4.9
2	07/23/19	12:04	13:04	2.8	0.7	5.4	11.4	0.8	10.3	48,816	54,422	403.6	886.1	357.4	62.4	41.6	4.6
3	07/23/19	13:34	14:34	3.2	0.5	5.4	11.4	0.8	10.2	49,966	55,672	399.8	878.0	354.1	64.2	42.8	2.9
Average				2.9	0.7	5.4	11.4	0.8	10.3	49,103	54,731	402.5	883.4	356.3	63.0	42.0	4.1

Emission Rate Summary																
Test No.	Date	Start Time	End Time	Fd Factor, dscf/MMBtu	CO ppmvd @ 15% O ₂	NO _x ppmvd @ 15% O ₂	NMNE VOC ppmvd @ 15% O ₂	Formaldehyde, lb/hr	NO _x lb/hr	CO lb/hr	NMNE VOC lb/hr	Horsepower	NO _x g/hp-hr	CO g/hp-hr	NMNE VOC g/hp-hr	
1	07/23/19	10:26	11:25	8,710.0	0.6	1.6	3.4	0.18	0.9	0.2	1.8	22,442.5	0.018	0.004	0.037	
2	07/23/19	12:04	13:04	8,710.0	0.4	1.7	3.2	0.18	1.0	0.2	1.7	22,472.0	0.020	0.003	0.035	
3	07/23/19	13:34	14:34	8,710.0	0.3	2.0	2.0	0.18	1.2	0.1	1.1	22,419.9	0.023	0.002	0.022	
Average				8,710.0	0.4	1.8	2.9	0.18	1.0	0.2	1.5	22,444.8	0.020	0.003	0.031	

Marquette Board of Light and Power Marquette Energy Center EU-ENGINE02 Gaseous Summary Full Load - Fuel Oil																	
Test No.	Date	Start Time	End Time	NO _x ppmvd	CO ppmvd	CO ₂ % (dry)	O ₂ % (dry)	Formaldehyde, ppmvd	Moisture, %	Flowrate, DSCFM	Flowrate, SCFM	THC ppm as C ₂ H ₆ (wet)	CH ₄ ppm as CH ₄ (wet)	CH ₄ ppm as C ₂ H ₆ (wet)*	C ₂ H ₆ (wet)	C ₂ H ₆ ppm as C ₂ H ₆ (wet)	VOC ppm as C ₂ H ₆ (wet)
1	07/23/19	15:52	16:51	2.5	0.4	6.3	12.3	0.1	6.8	53,813	57,262	1.2	0.3	0.1	0.1	0.1	1.0
2	07/23/19	19:42	20:41	27.0	0.3	6.3	12.2	0.1	6.7	53,181	57,230	1.1	0.3	0.1	0.1	0.1	0.9
3	07/25/19	8:55	9:54	33.4	1.0	6.4	12.3	0.1	7.2	53,637	57,320	1.8	0.5	0.2	0.1	0.1	1.5
Average				21.0	0.6	6.3	12.3	0.1	6.9	53,544	57,271	1.4	0.4	0.1	0.1	0.1	1.2

Emission Rate Summary																
Test No.	Date	Start Time	End Time	Fd Factor, dscf/MMBtu	CO ppmvd @ 15% O ₂	NO _x ppmvd @ 15% O ₂	NMNE VOC ppmvd @ 15% O ₂	Formaldehyde, lb/hr	NO _x lb/hr	CO lb/hr	NMNE VOC lb/hr	Horsepower	NO _x g/hp-hr	CO g/hp-hr	NMNE VOC g/hp-hr	
1	07/23/19	15:52	16:51	9,190.0	0.3	1.7	0.7	0.03	1.0	0.1	0.4	22,521.6	0.019	0.002	0.008	
2	07/23/19	19:42	20:41	9,190.0	0.2	18.3	0.7	0.03	10.3	0.1	0.4	22,578.1	0.207	0.001	0.007	
3	07/25/19	8:55	9:54	9,190.0	0.7	22.9	1.1	0.03	12.8	0.2	0.6	22,542.0	0.258	0.005	0.012	
Average				9,190.0	0.4	14.3	0.8	0.03	8.0	0.1	0.5	22,547.2	0.161	0.003	0.009	

* Methane is corrected for a response factor of 1.21 for the Thermo 51i FID Analyzer

Client: Marquette Board of Light and Power
 Facility: Marquette Energy Center
 Test Location: EU-ENGINE02
 Test Method: 5

Source Condition	Light Fuel Oil	Light Fuel Oil	Light Fuel Oil	
Date	7/23/19	7/23/19	7/25/19	
Start Time	15:45	19:42	8:50	
End Time	18:07	20:54	9:58	
	Run 1	Run 2	Run 3	Average
Stack Conditions				
Average Gas Temperature, °F	714.5	710.1	724.1	716.2
Flue Gas Moisture, percent by volume	6.0%	7.1%	6.4%	6.5%
Average Flue Pressure, in. Hg	29.44	29.44	29.44	29.44
Gas Sample Volume, dscf	45.781	45.472	45.812	45.688
Average Gas Velocity, ft/sec	98.180	97.752	99.078	98.337
Gas Volumetric Flow Rate, acfm	129,472	128,907	130,656	129,678
Gas Volumetric Flow Rate, dscfm	53,813	53,181	53,637	53,544
Gas Volumetric Flow Rate, scfm	57,262	57,230	57,320	57,271
Average %CO ₂ by volume, dry basis	6.3	6.3	6.4	6.3
Average %O ₂ by volume, dry basis	12.3	12.2	12.3	12.3
Isokinetic Variance	100.9	101.4	101.3	101.2
Kilowatts	16807.0	16849.0	16822.0	16826.0
Standard Fuel Factor Fd, dscf/mmBtu	9,190.0	9,190.0	9,190.0	9,190.0
Filterable Particulate Matter (Method 5)				
grams collected	0.00968	0.00745	0.00541	0.00751
grains/acf	0.0014	0.0010	0.0007	0.0010
grains/dscf	0.0033	0.0025	0.0018	0.0025
lb/hr	1.505	1.152	0.838	1.165
g/kW-hr	0.041	0.031	0.023	0.032

4.0 CERTIFICATION

MOSTARDI PLATT is pleased to have been of service to Marquette Board of Light and Power. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

CERTIFICATION


As project manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results, and the test program was performed in accordance with the methods specified in this test report.

MOSTARDI PLATT



John S. Nestor

Program Manager




Jeffery M. Crivlare

Quality Assurance

APPENDICES

Appendix A - Test Section Diagrams

VOLUMETRIC FLOW TRAVERSE FOR ROUND DUCTS



Job: Marquette Board of Light and Power
Marquette Energy Center
Marquette, Michigan

Date: July 23, 2019

Test Location: EU-ENGINE02 Outlet Duct

Duct Diameter: 5.29 Feet


Duct Area: 21.979 Square Feet

No. Points Across Diameter: 6

No. of Ports: 2

Port Length: 8.0 Inches

REPRESENTATIVE POINT FOR GASEOUS RUNS ON ROUND DUCTS



Job: Marquette Board of Light and Power
Marquette Energy Center
Marquette, Michigan

Date: July 23 and 25, 2019

Test Location: EU-ENGINE02 Outlet Duct

Duct Diameter: 5.29 Feet


Duct Area: 21.979 Square Feet

No. Points Across Diameter: 1

No. of Ports: 1

Port Length: 8.0 Inches

GASEOUS STRATIFICATION TEST FOR ROUND DUCTS



Job: Marquette Board of Light and Power
Marquette Energy Center
Marquette, Michigan

Date: July 23, 2019

Test Location: EU-ENGINE02 Outlet Duct

Duct Diameter: 5.29 Feet


Duct Area: 21.979 Square Feet

No. Points Across Diameter: 6

No. of Ports: 2

Port Length: 8.0 Inches

ISOKINETIC TRAVERSE FOR ROUND DUCTS



Job: Marquette Board of Light and Power
Marquette Energy Center
Marquette, Michigan

Date: July 23 and 25, 2019

Test Location: EU-ENGINE02 Outlet Duct

Duct Diameter: 5.29 Feet

Duct Area: 21.979 Square Feet


No. Points Across Diameter: 12

No. of Ports: 2


Port Length: 8.0 Inches

Appendix B - Sample Train Diagrams


USEPA Method 2 – Type S Pitot Tube Manometer Assembly



USEPA Methods 3A and 320 – Sample Train Diagram



USEPA Method 25A – Total Gaseous Organic Compound Sample Train



USEPA Method 5 - Particulate Matter Sample Train Diagram

