

RECEIVED

FEB 28 2023

AIR QUALITY DIVISION

**Source Test Report for 2023 Compliance Testing  
Omo Road Station Gas Fired Turbine-EUTUR01  
Bluewater Gas Storage, LLC  
Ray Township, Michigan**

**Prepared For:**

**Bluewater Gas Storage  
333 S. Wales Center  
Columbus, MI 48063**

**Prepared By:**

**Montrose Air Quality Services, LLC  
1371 Brummel Avenue  
Elk Grove Village, IL 60007**

**For Submission To:**

**Michigan Department of Environment, Great Lakes and Energy  
525 West Allegan Street  
Lansing, Michigan 48933**

**Document Number: MW023AS-021939-RT-1670**

**Test Date: January 10, 2023**

**Submittal Date: February 10, 2023**





## Review and Certification

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

**Signature:** Brandon Check **Date:** 02 / 07 / 2023

**Name:** Brandon Check, QI **Title:** Client Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

**Signature:** Henry M. Taylor **Date:** 02 / 06 / 2023

**Name:** Henry M. Taylor, QSTO **Title:** Senior Reporting Specialist

## Table of Contents

<u>Section</u>	<u>Page</u>
1.0 Introduction .....	5
1.1 Summary of Test Program .....	5
1.2 Key Personnel .....	7
2.0 Plant and Sampling Location Descriptions.....	8
2.1 Process Description, Operation, and Control Equipment.....	8
2.2 Flue Gas Sampling Location .....	8
2.3 Operating Conditions and Process Data .....	8
3.0 Sampling and Analytical Procedures .....	10
3.1 Test Methods .....	10
3.1.1 EPA Methods 3A, 7E, and 10 .....	10
3.1.2 EPA Method 19.....	11
3.2 Process Test Methods.....	12
4.0 Test Discussion and Results.....	13
4.1 Field Test Deviations and Exceptions.....	13
4.2 Presentation of Results.....	13
5.0 Internal QA/QC Activities .....	15
5.1 QA/QC Audits.....	15
5.2 QA/QC Discussion.....	15
5.3 Quality Statement .....	15

## List of Appendices

A Field Data and Calculations .....	16
A.1 Sampling Location .....	17
A.2 Instrumental Test Method Data .....	19
A.3 Calculations/Results.....	23
A.4 Example Calculations .....	28
B Facility Process Data.....	31
B.1 Process Data.....	32
B.2 Tariff Sheets .....	41
C Quality Assurance/Quality Control .....	57
C.1 Units and Abbreviations .....	58
C.2 QA/QC Data.....	66
C.3 Accreditation Information/Certifications.....	82

**List of Tables**

1-1 Summary of Test Program .....5  
 1-2 Summary of Average Compliance Results –Turbine EUTUR01 .....6  
 1-3 Test Personnel and Observers.....7  
 2-1 Sampling Location.....8  
 2-2 Process Data .....9  
 4-1 NO<sub>x</sub> and CO Emissions Results - Turbine EUTUR01 ..... 14

**List of Figures**

3-1 EPA Method 3A, 7E, and 10 Sampling Train ..... 11

**RECEIVED**  
**FEB 28 2023**  
**AIR QUALITY DIVISION**

## 1.0 Introduction

### 1.1 Summary of Test Program

Bluewater Gas Storage, LLC (Bluewater) contracted Montrose Air Quality Services, LLC (Montrose) to perform a compliance emissions test on the Omo Road Station Natural Gas Fired Turbine (EUTUR01) at their facility located in Ray Township, Michigan.

The test was conducted to satisfy the requirements of the Michigan Department of Environment, Great Lakes and Energy (EGLE) PTI, the United States Environmental Protection Agency (EPA), 40 CFR 63.6640 (c), Subpart ZZZZ and KKKK as applicable.

The specific objectives were to:

- Determine the NO<sub>x</sub> and CO emissions from EUTUR01
- Conduct the test program with a focus on safety

Montrose performed the test to measure the emission parameters listed in Table 1-1.

**Table 1-1**  
**Summary of Test Program**

Test Date	Unit ID/ Source Name	Activity/ Parameters	Test Methods	No. of Runs	Duration (Minutes)
1/10/23	EUTUR01/Omo Road Station	O <sub>2</sub>	EPA 3A	3	30
	Natural Gas Fired Turbine	NO <sub>x</sub>	EPA 7E & 19	3	30
		CO	EPA 10 & 19	3	30
		SO <sub>2</sub> *	--	--	--

To simplify this report, a list of Units and Abbreviations is included in Appendix C.1. Throughout this report, chemical nomenclature, acronyms, and reporting units are not defined. Please refer to the list for specific details.

This report presents the test results and supporting data, descriptions of the testing procedures, descriptions of the facility and sampling location, and a summary of the quality assurance procedures used by Montrose. The average emission test results are summarized and compared to their respective permit limits in Table 1-2. Detailed results for individual test runs can be found in Section 4.0. All supporting data can be found in the appendices.

The test was conducted according to the Test Protocol No. MW023AS-021939-PP-540 dated November 4, 2022.

\*The permit has an exception allowing the site to use tariff sheets to calculate SO<sub>2</sub> instead of Montrose performing EPA Method 6C. Results for SO<sub>2</sub> were provided by Bluewater.

**Table 1-2**  
**Summary of Average Compliance Results –Turbine EUTUR01**  
**January 10, 2023**

Parameter/Units	Average Results	Emission Limits
<b>Nitrogen Oxides (NO<sub>x</sub>)</b>		
ppmvd	7.37	--
ppmvd @ 15% O <sub>2</sub>	7.81	25
lb/MMBtu	0.0285	--
lb/hr	1.86	5.18
<b>Carbon Monoxide (CO)</b>		
ppmvd	1.55	--
ppmvd @ 15% O <sub>2</sub>	1.65	--
lb/MMBtu	0.0036	--
lb/hr	0.24	5.25
<b>Sulfur Dioxide (SO<sub>2</sub>)</b>		
lb/MMBtu	See Appendix B.2	0.060

## 1.2 Key Personnel

A list of project participants is included below:

### Facility Information

Source Location: Bluewater Gas Storage  
 333 S Wales Center  
 Columbus, MI 48063

Project Contact: James Jensen  
 Company: Bluewater Gas Storage, LLC  
 Telephone: 414-221-2530  
 Email: James.Jensen@wecenergygroup.com

### Agency Information

Regulatory Agency: Michigan Department of Environment, Great Lakes and Energy  
 Agency Contact: Jeremy Howe  
 Telephone: 231-878-6687  
 Email: Howej@michigan.gov

### Testing Company Information

Testing Firm: Montrose Air Quality Services, LLC  
 Contact: Brandon Check  
 Title: Client Project Manager  
 Telephone: 630-860-4740  
 Email: bcheck@montrose-env.com

Test personnel and observers are summarized in Table 1-3.

**Table 1-3**  
**Test Personnel and Observers**

Name	Affiliation	Role/Responsibility
Matthew Libman	Montrose	Regional Vice President/Field Team Leader/Trailer Operator
Brian Romani	Montrose	Field Project Manager/QI/Trailer Operator
Jack Hutchison	Montrose	Report Preparation
James Jensen	Bluewater	Client Liaison/Test Coordinator



## 2.0 Plant and Sampling Location Descriptions

### 2.1 Process Description, Operation, and Control Equipment

Bluewater primarily provides seasonal storage needs throughout the Midwestern and Northeastern portions of the U.S. and the Southeastern portion of Canada. Bluewater’s customers consist primarily of pipelines, utilities and marketers seeking seasonal storage services. Bluewater’s 30-mile, 20-inch diameter pipeline header system connects with three interstate and three intrastate natural gas utility pipelines that provide access to the major market hubs of Chicago, Illinois and Dawn, Ontario, which supply natural gas to eastern Ontario and the northeastern United States. These interconnects also provide access to natural gas utilities that serve local markets in Michigan and Ontario.

The compliance test was conducted on the Gas Fired Turbine (EUTUR01) at the Omo Road Station facility located in Ray Township, Michigan.

### 2.2 Flue Gas Sampling Location

**Table 2-1  
Sampling Location**

Sampling Location	Stack Inside Diameter (in.)	Distance from Nearest Disturbance		Number of Traverse Points
		Downstream EPA "B" (in./dia.)	Upstream EPA "A" (in./dia.)	
EUTUR01	54	--	--	Gaseous: 3

Sample measurements were conducted at three points on the line passing through the centroidal area at 16.7, 50.0, and 83.3% of the measurement line. Each point was sampled for 10 minutes for each 30-minute test run.

### 2.3 Operating Conditions and Process Data

Plant personnel were responsible for establishing the test conditions and collecting all applicable unit-operating data. The process data that was provided is presented in Appendix B. Data collected includes the following parameters:

- Fuel factor,  $F_d$
- Fuel gas flow rate, MSCFH
- Heating value, BTU/scf
- Heat input (MMBTU/hr)

Process data information is summarized in Table 2-2.

**Table 2-2  
Process Data**

Run	Temperature (°F)	Humidity (%)	Pressure (in)	Engine Temperature (°F)	Fuel Flow (MSCFH)	Fuel Consumed (MSCF)
1	33	84	30.05	1371	61.5	30.8
2	35	77	30.03	1371	61.3	30.7
3	36	74	30.02	1373	62.4	31.2
Average	34.7	78.3	30.03	1371.7	61.7	30.9

## 3.0 Sampling and Analytical Procedures

### 3.1 Test Methods

The test methods for this test program have been presented in Table 1-1. Additional information regarding specific applications or modifications to standard procedures is presented below.

#### 3.1.1 EPA Methods 3A, 7E, and 10, Determination of Oxygen, Nitrogen Oxides, and Carbon Monoxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)


Concentrations of O<sub>2</sub>, NO<sub>x</sub>, and CO are measured simultaneously using EPA Methods 3A, 7E, and 10, which are instrumental test methods. Conditioned gas is sent to a series of analyzers to measure the gaseous emission concentrations. The performance requirements of the method must be met to validate the data.

Pertinent information regarding the performance of the method is presented below:

- Method Options:
  - A dry extractive sampling system is used to report emissions on a dry basis
  - A paramagnetic analyzer is used to measure O<sub>2</sub>
  - A chemiluminescent analyzer is used to measure NO<sub>x</sub>
  - A gas filter correlation nondispersive infrared analyzer is used to measure CO
- Method Exceptions:
  - None
- Target and/or Minimum Required Sample Duration: 30 minutes
- Target Analytes: O<sub>2</sub>, NO<sub>x</sub>, and CO

The typical sampling system is detailed in Figure 3-1.

**Figure 3-1  
EPA Method 3A, 7E, and 10 Sampling Train**



### 3.1.2 EPA Method 19, Measurement of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates

EPA Method 19 is a manual method used to determine (a) PM, SO<sub>2</sub>, and NO<sub>x</sub> emission rates; (b) sulfur removal efficiencies of fuel pretreatment and SO<sub>2</sub> control devices; and (c) overall reduction of potential SO<sub>2</sub> emissions. This method provides data reduction procedures, but does not include any sample collection or analysis procedures.

EPA Method 19 is used to calculate the stack gas volumetric flow rate from the measurement of the heat input rate, stack concentration of O<sub>2</sub> or CO<sub>2</sub>, and an F factor determined from fuel analysis. Volumetric flow rates are used to calculate mass emission rates in units of lb/hr. The metered fuel flow rate is recorded during each test period. Typically, fuel flow rates are reported in scf/hr. A fuel sample is collected and analyzed for higher heating value (HHV) and composition (C,H,O,N,S) to calculate the F factor. F factors are determined daily, if not more frequently, from each unique fuel supply.

Pertinent information regarding the performance of the method is presented below:

- Method Options:
  - F factor is the oxygen-based F factor, dry basis ( $F_d$ )
  - F factor is calculated from analysis of fuel samples collected on the test day
  - Higher Heating Value data is obtained from analysis of fuel samples
- Method Exceptions:
  - None

### 3.2 Process Test Methods

The test plan did not require that process samples be collected during this test program; therefore, no process sample data are presented in this test report.

RECEIVED  
FEB 28 2023  
AIR QUALITY DIVISION

## **4.0 Test Discussion and Results**

### **4.1 Field Test Deviations and Exceptions**

No field deviations or exceptions from the test plan or test methods occurred during this test program.

### **4.2 Presentation of Results**

The average results are compared to the permit limits in Table 1-2. The results of individual compliance test runs performed are presented in Table 4-1. Emissions are reported in units consistent with those in the applicable regulations or requirements. Additional information is included in the appendices as presented in the Table of Contents.

**Table 4-1**  
**NO<sub>x</sub> and CO Emissions Results -**  
**Turbine EUTUR01**

Parameter/Units	Run 1	Run 2	Run 3	Average
<b>Date</b>	1/10/2023	1/10/2023	1/10/2023	--
<b>Time</b>	10:58-11:28	11:40-12:10	12:21-12:51	--
<b>Process Data</b>				
fuel factor, F <sub>d</sub>	8,613	8,613	8,613	8,613
fuel flow, MSCFH	61.50	61.30	62.40	61.73
heating value, BTU/scf	1061.4	1057.4	1057.3	1058.7
heating input, MMBTU/hr	65.28	64.82	65.98	65.36
<b>Sampling &amp; Flue Gas Parameters</b>				
sample duration, minutes	30	30	30	--
O <sub>2</sub> , % volume dry	15.28	15.36	15.37	15.34
<b>Nitrogen Oxides (NO<sub>x</sub> as NO<sub>2</sub>)</b>				
ppmvd	7.32	7.29	7.48	7.37
ppmvd @ 15% O <sub>2</sub>	7.69	7.77	7.98	7.81
lb/MMBtu	0.0280	0.0283	0.0291	0.0285
lb/hr	1.83	1.83	1.92	1.86
<b>Carbon Monoxide (CO)</b>				
ppmvd	2.00	1.32	1.34	1.55
ppmvd @ 15% O <sub>2</sub>	2.10	1.41	1.43	1.65
lb/MMBtu	0.0047	0.0031	0.0032	0.0036
lb/hr	0.30	0.20	0.21	0.24

## 5.0 Internal QA/QC Activities

### 5.1 QA/QC Audits

EPA Method 3A, 7E, and 10 calibration audits were all within the measurement system performance specifications for the calibration drift checks, system calibration bias checks, and calibration error checks.

### 5.2 QA/QC Discussion

All QA/QC criteria were met during this test program.

### 5.3 Quality Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one QI as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is included in the report appendices. The content of this report is modeled after the EPA Emission Measurement Center Guideline Document (GD-043).





**MONTROSE**  
AIR QUALITY SERVICES

## **Appendix A**

### **Field Data and Calculations**


## **Appendix A.1**

### **Sampling Location**



ENVIRONMENTAL QUALITY DIRECTOR'S OFFICE  
EPA Method 1  
Sample and Velocity Traverses Worksheet

LOCATION 721

Site Name	<u>Dine wall</u>
Project No.	<u>21939</u>
Plant	<u>oro food</u>
Sample No.	<u>119123</u>
Analyst	<u>BL</u>
Duct Diameter (in)	<u>54"</u>
Box Diameter (in)	<u>      </u>
Box Length (in)	<u>      </u>
Box Type	<u>      </u>
Distance A (ft)	<u>      </u>
Distance B (ft)	<u>      </u>
Distance A (Duct Diameter)	<u>      </u>
Distance B (Duct Diameter)	<u>      </u>



For rectangular ducts 
$$ED = \frac{2LW}{(L+W)}$$



Stacks  $D > 24"$  min.  $\geq 1.00'$  away from wall  
Stacks  $D \leq 24"$  min.  $\geq 0.50'$  away from wall

Location Schematic and Notes	Traverse Point	Distance (in)
Indicate sample ports, height from grade, types of disturbances, access, unistrut configuration, etc. Distance to point must include length of port	1	<u>44.98</u>
	2	<u>27</u>
	3	<u>9.02</u>
	4	
	5	
	6	
	7	
	8	
	9	
	10	
	11	
	12	
	13	
	14	
	15	
	16	

40  
83.3  
50  
16.7

RECEIVED

FEB 28 2023

AIR QUALITY DIVISION

## **Appendix A.2**

### **Instrumental Test Method Data**

Date  
1/10/2023

Time	O <sub>2</sub> (%)	NO <sub>x</sub> (ppm)	CO (ppm)
Average	15.37	7.44	2.01

---

10:58:02	15.33	7.63	4.1
10:59:02	15.34	7.71	3.6
11:00:02	15.33	7.69	3.0
11:01:02	15.33	7.64	2.6
11:02:02	15.33	7.68	2.4
11:03:02	15.32	7.62	2.3
11:04:02	15.32	7.64	2.1
11:05:02	15.32	7.73	2.2
11:06:02	15.31	7.65	2.1
11:07:02	15.32	7.65	2.0
11:08:02	15.32	7.71	2.2
11:09:02	15.32	7.64	1.9
11:10:02	15.32	7.69	1.7
11:11:02	15.32	7.46	1.6
11:12:02	15.32	7.43	1.5
11:13:02	15.32	7.34	1.7
11:14:02	15.33	7.45	1.6
11:15:02	15.33	7.42	1.5
11:16:02	15.33	7.37	1.6
11:17:02	15.33	7.69	1.5
11:18:02	15.34	7.44	1.6
11:19:02	15.35	7.35	1.6
11:20:02	15.39	7.15	1.6
11:21:02	15.5	7.1	1.8
11:22:02	15.48	7.09	1.8
11:23:02	15.5	7.18	1.9
11:24:02	15.5	7.13	1.8
11:25:02	15.51	7.12	1.9
11:26:02	15.5	7.19	1.8
11:27:02	15.5	7.09	1.9
11:28:02	15.5	7.11	1.5

Date			
1/10/2023			
Time	O <sub>2</sub> (%)	NO <sub>x</sub> (ppm)	CO (ppm)
<b>Average</b>	15.35	7.39	1.35
<hr/>			
11:40:17	15.31	7.72	0.9
11:41:17	15.31	7.64	1.2
11:42:17	15.31	7.45	1.3
11:43:17	15.28	7.7	1.3
11:44:17	15.27	7.71	1.3
11:45:17	15.29	7.61	1.3
11:46:17	15.3	7.68	1.3
11:47:17	15.31	7.61	1.3
11:48:17	15.31	7.62	1.2
11:49:17	15.31	7.7	1.3
11:50:17	15.3	7.64	1.3
11:51:17	15.3	7.57	1.3
11:52:17	15.31	7.45	1.3
11:53:17	15.3	7.36	1.3
11:54:17	15.3	7.34	1.3
11:55:17	15.31	7.39	1.3
11:56:17	15.31	7.36	1.3
11:57:17	15.31	7.35	1.3
11:58:17	15.31	7.38	1.2
11:59:17	15.31	7.44	1.4
12:00:17	15.31	7.35	1.3
12:01:17	15.31	7.38	1.2
12:02:17	15.42	7.42	1.4
12:03:17	15.45	7.08	1.5
12:04:17	15.46	6.8	1.6
12:05:17	15.46	6.94	1.6
12:06:17	15.47	7.09	1.5
12:07:17	15.47	7.06	1.6
12:08:17	15.47	7.18	1.6
12:09:17	15.46	7.06	1.6
12:10:17	15.46	7.09	1.6

Date  
1/10/2023

Time	O <sub>2</sub> (%)	NO <sub>x</sub> (ppm)	CO (ppm)
Average	15.34	7.49	1.32

---

12:21:57	15.44	7	0.7
12:22:57	15.33	7.9	1.3
12:23:57	15.27	9	1.5
12:24:57	15.24	7.88	1.4
12:25:57	15.25	7.64	1.3
12:26:57	15.28	7.68	1.1
12:27:57	15.29	7.67	1.1
12:28:57	15.28	7.64	1.1
12:29:57	15.28	7.60	1.1
12:30:57	15.28	7.61	1.3
12:31:57	15.28	7.66	1.3
12:32:57	15.28	7.61	1.3
12:33:57	15.29	7.56	1.3
12:34:57	15.29	7.58	1.3
12:35:57	15.29	7.39	1.3
12:36:57	15.29	7.36	1.3
12:37:57	15.29	7.38	1.3
12:38:57	15.29	7.34	1.3
12:39:57	15.29	7.39	1.3
12:40:57	15.29	7.63	1.3
12:41:57	15.33	7.55	1.3
12:42:57	15.43	7.36	1.3
12:43:57	15.43	7.17	1.3
12:44:57	15.43	7.1	1.5
12:45:57	15.43	7.06	1.6
12:46:57	15.43	7.23	1.6
12:47:57	15.43	7.33	1.6
12:48:57	15.42	7.3	1.5
12:49:57	15.41	7.21	1.6
12:50:57	15.42	7.17	1.6
12:51:57	15.41	7.3	1.6



**MONTROSE**  
AIR QUALITY SERVICES

## **Appendix A.3**

### **Calculations/Results**



OXYGEN

Analyzer Values	Actual	Cal Error	Bias	Run 1	Run 2	Run 3
Date		1/10/23	1/10/23	1/10/23	1/10/23	1/10/23
Start Time		9:31	9:52	10:58	11:40	12:21
Stop Time		9:52	9:58	11:28	12:10	12:51
Concentration, C (%)				15.37	15.35	15.34
Zero Cal Gas, C <sub>0</sub> (%)	0.00	0.0	0.0	0.0	0.0	0.0
Mid Cal Gas (%)	9.938	10.1				
High Cal Gas (%)	21.10	21.1				
Span Value (%)	21.10					
Bias/Drift Check Gas, C <sub>s</sub> (%)	9.938		10.1	9.9	9.9	9.9
<b>RESULTS</b>						
Zero Error (%)	2 % of Span	0.0				
Mid Error (%)		0.6				
High Error (%)		0.0				
Upscale Error (%)						
Zero Bias (%)	5 % of Span		0.0	0.0	-0.1	0.0
Upscale Bias (%)			-0.1	-0.7	-0.7	-0.8
Zero Drift (%)	3 % of Span			0.0	0.0	0.0
Upscale Drift (%)				-0.6	0.0	-0.1
Concentration Corrected for Drift, C <sub>d</sub> (%)				15.28	15.36	15.37

NITROGEN OXIDES

Correction to Oxygen (%) **15.0**  
 Correction to Fd Factor (lb/MMBtu) **8,613**

Analyzer Values	Actual	Cal Error	Bias	Run 1	Run 2	Run 3
Date		1/10/23	1/10/23	1/10/23	1/10/23	1/10/23
Start Time		9:31	9:52	10:58	11:40	12:21
Stop Time		9:52	9:58	11:28	12:10	12:51
Concentration, C (ppm)				7.44	7.39	7.49
Zero Cal Gas, C <sub>0</sub> (ppm)	<b>0.00</b>	0.14	0.2	0.1	0.1	0.1
Mid Cal Gas (ppm)	<b>25.51</b>	25.7				
High Cal Gas (ppm)	<b>45.36</b>	45.4				
Span Value (ppm)	45.36					
Bias/Drift Check Gas, C <sub>s</sub> (ppm)	<b>25.51</b>		25.5	25.6	25.5	25.1

**RESULTS**

Zero Error (%)	2 % of Span	0.3				
Mid Error (%)		0.3				
High Error (%)		0.0				
Upscale Error (%)						
Zero Bias (%)	5 % of Span		0.1	0.0	-0.1	-0.1
Upscale Bias (%)			-0.3	-0.1	-0.3	-1.2
Zero Drift (%)	3 % of Span			-0.1	-0.1	0.0
Upscale Drift (%)				0.1	-0.2	-0.9
Concentration Corrected for Drift, C <sub>d</sub> (ppm)				<b>7.32</b>	<b>7.29</b>	<b>7.48</b>
Concentration Corrected to Oxygen, C <sub>O2</sub> (ppm)				<b>7.69</b>	<b>7.77</b>	<b>7.98</b>
Emission Rate, Fd Factor, E <sub>Fd</sub> (lb/MMBtu)				<b>0.0280</b>	<b>0.0283</b>	<b>0.0291</b>

CARBON MONOXIDE

Correction to Oxygen (%) **15.0**  
Correction to Fd Factor (lb/MMBtu) **8,613**

Analyzer Values	Actual	Cal Error	Bias	Run 1	Run 2	Run 3
Date		1/10/23	1/10/23	1/10/23	1/10/23	1/10/23
Start Time		9:31	9:52	10:58	11:40	12:21
Stop Time		9:52	9:58	11:28	12:10	12:51
Concentration, C (ppm)				2.01	1.35	1.32
Zero Cal Gas, C <sub>0</sub> (ppm)	<b>0.00</b>	0.16	0.0	0.0	0.1	0.0
Mid Cal Gas (ppm)	<b>24.98</b>	25.0				
High Cal Gas (ppm)	<b>45.25</b>	45.2				
Span Value (ppm)	45.25					
Bias/Drift Check Gas, C <sub>s</sub> (ppm)	<b>24.98</b>		25.1	24.6	24.7	24.4

**RESULTS**

Zero Error (%)	2 % of Span	0.4				
Mid Error (%)		0.1				
High Error (%)		-0.2				
Upscale Error (%)						
Zero Bias (%)	5 % of Span		-0.4	-0.3	-0.2	-0.4
Upscale Bias (%)			0.0	-0.9	-0.8	-1.4
Zero Drift (%)	3 % of Span			0.1	0.0	-0.2
Upscale Drift (%)				-0.9	0.1	-0.6
Concentration Corrected for Drift, C <sub>d</sub> (ppm)				<b>2.00</b>	<b>1.32</b>	<b>1.34</b>
Concentration Corrected to Oxygen, C <sub>O2</sub> (ppm)				<b>2.10</b>	<b>1.41</b>	<b>1.43</b>
Emission Rate, Fd Factor, E <sub>Fd</sub> (lb/MMBtu)				<b>0.0047</b>	<b>0.0031</b>	<b>0.0032</b>

**Test Parameters**

	Run 1	Run 2	Run 3	Average
Date	1/10/2023	1/10/2023	1/10/2023	
Start Time	10:58	11:40	12:21	
Stop Time	11:28	12:10	12:51	

**Gas Conditions**

Oxygen (% dry)	15.28	15.36	15.37	<b>15.34</b>
Fuel Factor, Fd	8,613	8,613	8,613	<b>8,613</b>
Fuel Flow (MSCFH)	61.50	61.30	62.40	<b>61.73</b>
Heating Value (BTU/scf)	1061.4	1057.4	1057.3	<b>1058.7</b>
Heat Input (MMBTU/hr)	65.28	64.82	65.98	<b>65.36</b>

**Nitrogen Oxides Results**

Nitrogen Oxides Concentration (ppmdv)	7.32	7.29	7.48	<b>7.37</b>	
Nitrogen Oxides Concentration, C (ppmdv@15% O2)	7.69	7.77	7.98	<b>7.81</b>	<25
Nitrogen Oxides Emission rate, E (lb/mmBTU)	0.0280	0.0283	0.0291	<b>0.0285</b>	
Nitrogen Oxides Emission rate (lb/hr)	1.83	1.83	1.92	<b>1.86</b>	<5.18

**Carbon Monoxide Results**

Carbon Monoxide Concentration (ppmdv)	2.00	1.32	1.34	<b>1.55</b>	
Carbon Monoxide Concentration, C (ppmdv@15% O2)	2.10	1.41	1.43	<b>1.65</b>	
Carbon Monoxide Emission rate, E (lb/mmBTU)	0.0047	0.0031	0.0032	<b>0.0036</b>	
Carbon Monoxide Emission Rate (lb/hr)	0.30	0.20	0.21	<b>0.24</b>	<5.25