



# Testing Solutions for a Better World

EMISSION COMPLIANCE TEST  
FOR THE  
SIEMENS, SGE-56SL, UNIT #1-6  
PREPARED FOR  
LIVWELL  
AT THE  
LIVWELL CULTIVATION BUSINESS CENTER  
WARREN, MACOMB COUNTY, MICHIGAN  
FEBRUARY 15-21, 2023

Permit No: 10-20A (P1109)

Report Date: April 9, 2023



**Corporate Headquarters**

1600 W. Tacoma Street  
Broken Arrow, OK 74012



**AIR HYGIENE, INC.**

(918) 307-8865 or (888) 461-8778  
[www.airhygiene.com](http://www.airhygiene.com)


**Remote Testing Offices**

Chicago, IL  
Shreveport, LA  
Las Vegas, NV  
Pittsburgh, PA  
Fort Worth, TX  
Salt Lake City, UT



**EMISSION COMPLIANCE TEST  
FOR THE  
SIEMENS, SGE-56SL, UNIT #1-6  
PREPARED FOR  
LIVWELL  
AT THE  
LIVWELL CULTIVATION BUSINESS CENTER  
WARREN, MACOMB COUNTY, MICHIGAN  
FEBRUARY 15-21, 2023**

Prepared and Reviewed by:




Matt McBride, QSTI  
Instrumentation Field Services  
Manager



Darin Grimes  
Sr. Testing Solutions Specialist



Thomas K. Graham, PE, QSTI  
Director of AHU




I, Greg Vaughn, QSTI  
Test Manager

certify that this testing was conducted and  
this report was created in conformance  
with the requirements of ASTM D7036

*(this page intentionally left blank)*

## CERTIFICATION OF INFORMATION

I certify under penalty of law that I believe the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.



\_\_\_\_\_  
Greg Vaughn, QSTI  
Test Manager  
Air Hygiene International, Inc.

\_\_\_\_\_  
March 20, 2023  
Date

## FACILITY CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attached documents and, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.

I am the responsible official with direct knowledge and overall responsibility for the information contained in this report.

\_\_\_\_\_  
Name

\_\_\_\_\_  
Title

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

*(this page intentionally left blank)*

# Table of Contents

<b>1.0</b>	<b>INTRODUCTION</b>	<b>1</b>
<b>1.1</b>	<b>TEST PURPOSE AND OBJECTIVES</b>	<b>1</b>
<b>1.2</b>	<b>SUMMARY OF TEST PROGRAM</b>	<b>1</b>
1.2.1	Participating Organizations	1
1.2.2	Industry	1
1.2.3	Air Permit and Federal Requirements	1
1.2.4	Plant Location	1
1.2.5	Equipment Tested	1
1.2.6	Emission Points	2
1.2.7	Emission Parameters Measured	2
1.2.8	Dates of Emission Test	2
1.2.9	Federal and State Certifications	2
<b>1.3</b>	<b>KEY PERSONNEL</b>	<b>2</b>
<b>2.0</b>	<b>SUMMARY OF TEST RESULTS</b>	<b>2</b>
<b>3.0</b>	<b>SOURCE OPERATION</b>	<b>3</b>
<b>3.1</b>	<b>PROCESS DESCRIPTION</b>	<b>3</b>
<b>3.2</b>	<b>SAMPLING LOCATION</b>	<b>3</b>
<b>4.0</b>	<b>SAMPLING AND ANALYTICAL PROCEDURES</b>	<b>3</b>
<b>4.1</b>	<b>TEST METHODS</b>	<b>3</b>
<b>4.2</b>	<b>INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS</b>	<b>4</b>

## APPENDICES

Appendix A	Test Results and Calculations
Appendix B	Emission Data Records
Appendix C	Calibration Gas Certifications
Appendix D	Quality Assurance and Quality Control Data
Appendix E	Stratification Test Data
Appendix F	Equipment Calibration Records

**Emissions Compliance Test  
Siemens, SGE-56SL, Unit #1-6  
LivWell  
Livwell Cultivation Business Center  
Warren, Macomb County, Michigan  
February 15-21, 2023**

## **1.0 INTRODUCTION**

Air Hygiene International, Inc. (Air Hygiene) has completed the Emissions Compliance Test for nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), total hydrocarbons/non-methane hydrocarbons/volatile organic compounds (THC/NMHC/VOC), and ammonia (NH<sub>3</sub>) from the exhaust of the Siemens, SGE-56SL, Unit #1-6 for LivWell at the Livwell Cultivation Business Center in Warren, Macomb County, Michigan. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on February 15-21, 2023.

## **1.1 TEST PURPOSE AND OBJECTIVES**

The purpose of the test was to conduct a periodic emission test to document levels of selected pollutants at maximum operation levels of the unit. The information will be used to confirm compliance with the operating permit issued by the Michigan Department of Environment, Great Lakes & Energy (Michigan EGLE) in addition to the requirements of 40 Code of Federal Regulations, Part 60, Subpart JJJJ. The specific objective was to determine the emission concentration of NO<sub>x</sub>, CO, THC/NMHC/VOC, and NH<sub>3</sub> from the exhaust of LivWell's Siemens, SGE-56SL, Unit #1-6.

## **1.2 SUMMARY OF TEST PROGRAM**

The following list details pertinent information related to this specific project:

- 1.2.1 Participating Organizations
  - Michigan Department of Environment, Great Lakes & Energy (Michigan EGLE)
  - LivWell
  - Air Hygiene
- 1.2.2 Industry
  - Cannabis Cultivation and Production
- 1.2.3 Air Permit and Federal Requirements
  - Permit Number: 10-20A (P1109)
  - 40 CFR 60, Subpart JJJJ
- 1.2.4 Plant Location
  - Livwell Cultivation Business Center in Warren, Macomb County, Michigan
    - GPS Coordinates [Latitude 42.455310, Longitude -83.003680]
    - Physical Address: 21550 Hoover Road, CUP Building, Warren, Michigan 48089
- 1.2.5 Equipment Tested
  - Siemens, SGE-56SL, Unit #1-6



- 1.2.6 Emission Points
  - Exhaust from the Siemens, SGE-56SL, Unit #1-6
  - For all gases, one to three sample points in the exhaust stacks from the Siemens, SGE-56SL, Unit #1-6, at the point nearest the mean (non-stratified) or 16.7, 50.0, and 83.3 percent of the diameter (minimally stratified)
  - For all flow testing, 12 sampling points in the exhaust stacks from the Siemens, SGE-56SL, Unit #1-6
- 1.2.7 Emission Parameters Measured
  - NO<sub>x</sub>
  - CO
  - THC/NMHC/VOC
  - NH<sub>3</sub>
  - Flow
  - H<sub>2</sub>O
  - CO<sub>2</sub>
  - O<sub>2</sub>
- 1.2.8 Dates of Emission Test
  - February 15-21, 2023
- 1.2.9 Federal and State Certifications
  - Stack Testing Accreditation Council AETB Certificate No. 3796.02
  - International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

**1.3 KEY PERSONNEL**

LivWell:	Shannelle Montoya (shannelle.montoya@livwell.com)	720-276-7669
Cultivated Power:	Jim Kelly (jim.kelly@cultivatedpower.net)	303-601-5681
Michigan EGLE:	Lindsey Wells (wells18@michigan.gov)	517-282-2345
Air Hygiene:	Greg Vaughn (gvaughn@airhygiene.com)	918-307-8865
Air Hygiene:	Matt McBride	918-307-8865
Air Hygiene:	Garrett Rogers	918-307-8865

**2.0 SUMMARY OF TEST RESULTS**

Results from the sampling conducted on LivWell’s Siemens, SGE-56SL, Unit #1-6 located at the Livwell Cultivation Business Center on February 15-21, 2023 are summarized in the following table and relate only to the items tested.

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

**RECEIVED**  
**JUN 20 2023**  
**AIR QUALITY DIVISION**

**TABLE 2.1  
SUMMARY OF SIEMENS, SGE-56SL, UNIT #EUGEN1, SERIAL #A9B0018 RESULTS**

Parameter	Unit #1 S#A9B0018 (EUGEN1)	Unit #2 S#A9C0007 (EUGEN2)	Unit #3 S#A9A0027 (EUGEN3)	Unit #4 S#A9B0001 (EUGEN4)	Unit #5 S#A9B0011 (EUGEN5)	Unit #6 S#BOD0008 (EUGEN6)	FGCOGEN Emission Limits	40 CFR 60, Subpart JJJJ Limits <sup>5</sup>
Date (mm/dd/yy)	02/21/23	02/16/23	02/20/23	02/18/23	02/19/23	02/15/23	--	--
Power Output (kilowatts)	900.0	906.7	900.0	909.7	906.7	900.0	--	--
Stack Flow (M2) (DSCFH)	142,648	136,509	100,307	141,240	127,263	142,817	--	--
NOx (ppmvd)	4.25	7.60	25.16	17.37	20.67	7.68	--	--
NOx (ppm@15%O <sub>2</sub> )	2.04	3.65	11.90	8.53	9.87	3.66	--	82
NOx (g/hp*hr)	0.027	0.046	0.113	0.109	0.118	0.049	0.05 <sup>1</sup> / 0.14 <sup>2</sup>	1.0
CO (ppmvd)	8.23	0.11	4.72	0.01	3.70	6.46	--	--
CO (ppm@15%O <sub>2</sub> )	3.95	0.05	2.23	0.00	1.77	3.08	--	270
CO (g/hp*hr)	0.032	0.000	0.013	0.000	0.013	0.025	0.036 <sup>3</sup> / 0.45 <sup>4</sup>	2.0
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	2.18	1.64	28.42	31.84	28.07	18.89	--	--
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	1.05	0.78	13.44	15.63	13.41	9.00	--	60
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	0.01	0.01	0.12	0.19	0.15	0.12	0.07 <sup>3</sup> / 0.28 <sup>4</sup>	0.7
NH <sub>3</sub> (ppmvd)	3.92	4.59	6.78	0.24	6.87	2.42	--	--
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	1.88	2.20	3.21	0.12	3.28	1.15	5 <sup>3</sup> / 3.5 <sup>4</sup>	--
NH <sub>3</sub> (g/hp*hr)	0.009	0.010	0.011	0.001	0.015	0.006	--	--

Notes: <sup>1</sup>Applicable to Units 1, 2, and 6; <sup>2</sup>Applicable to Units 3, 4, and 5; <sup>3</sup>Applicable to Units 1 and 2; <sup>4</sup>Applicable to Units 3, 4, 5, and 6; <sup>5</sup>Based on 2019 Manufacturing Date

### 3.0 SOURCE OPERATION

#### 3.1 PROCESS DESCRIPTION

The units tested were Siemens, SGE-56SL, Unit #1-6. The engines are rated at 1,431 horsepower. The engine emissions are vented to the atmosphere through exhaust systems extending from each engine. The lean burn engines use an oxidation catalyst and ammonia injection between the engine and the exhaust stack.

#### 3.2 SAMPLING LOCATION

The stacks are vertical, circular, and measure 1.1 feet (ft) (13.25 inches) in diameter at the test ports which are approximately 37 ft above grade level with an exit elevation of approximately 42 ft above grade level. The test ports are located approximately 7.5 ft (90 inches) [6.8 dia] downstream and approximately 5.2 ft (62.5 inches) [4.7 dia] upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by LivWell. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from one (non-stratified) or three (minimally stratified) sample points determined after conducting stratification tests. During the stratification test six points were traversed from each of the two test ports. The probe was allowed to remain at a point for at least two times the system response time. For flow testing, an initial velocity traverse was performed across the stack from 12 total points. All flow sampling occurred from the same 12 points.

### 4.0 SAMPLING AND ANALYTICAL PROCEDURES

#### 4.1 TEST METHODS

The emission test on the Siemens, SGE-56SL, Unit #1-6 at the Livwell Cultivation Business Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on February 15-21, 2023.

**TABLE 4.1  
SUMMARY OF SAMPLING METHODS**

<b>Pollutant or Parameter</b>	<b>Sampling Method</b>	<b>Analysis Method</b>
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	S-Type Pitot Tube
Oxygen	EPA Method 3A	Paramagnetic Cell
Carbon Dioxide	EPA Method 3A	Nondispersive Infrared Analyzer
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Ammonia, THC, Methane, Ethane, Carbon Dioxide, and Water	EPA Method 320	Fourier Transform Infrared

#### **4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS**

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3A, 7E, 10; and 40 CFR 63, Appendix A, Method 320.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless-steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample. Exhaust samples were routed to the wet based analyzer prior to gas conditioning.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e., NO<sub>x</sub> calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 60 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer, interferograms consisting of 60 co-added scans were recorded continuously during the test periods and provided approximately 60-second average concentrations. Spectral data was analyzed by the MAX Analytical software.

The stack gas analysis for O<sub>2</sub> and CO<sub>2</sub> concentrations was performed in accordance with procedures set forth in EPA Method 3A and 20. The O<sub>2</sub> analyzer uses a paramagnetic cell detector, and the CO<sub>2</sub> analyzer uses a continuous nondispersive infrared analyzer.

EPA Method 7E was used to determine concentrations of NO<sub>x</sub>. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO<sub>2</sub> in air manufacturer-certified gas cylinder was used to verify at least a 90 percent NO<sub>2</sub> conversion on the day of the test.


CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

A MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer was used for ammonia, total hydrocarbon, methane, ethane, carbon dioxide, and moisture analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm<sup>-1</sup>. The system employed a silicon carbide infrared source at 1200°C, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191°C. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 4.0 liters per minute, the sample gas in the cell is refreshed approximately four times each minute. Interferograms consisting of 60 co-added scans were recorded continuously during the test periods and provided approximately 60-second average concentrations.

**TABLE 4.2  
ANALYTICAL INSTRUMENTATION**

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NO <sub>x</sub>	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO <sub>2</sub> to NO. Chemiluminescence of reaction of NO with O <sub>3</sub> . Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor-based linearization.
CO <sub>2</sub>	SERVOMEX 1440	0-20%	0.1%	Nondispersive infrared
NH <sub>3</sub> , CH <sub>4</sub> , CO <sub>2</sub> , H <sub>2</sub> O	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
O <sub>2</sub>	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

Figure 4.2 represents the sample system used for the flow tests. Flow rates were monitored with manometers.



Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.



Figure 4.1  
**EMISSIONS TESTING LAB**  
 1600 W Tacoma Street  
 Broken Arrow, Oklahoma 74012  
 www.airhygiene.com  
 (888) 461-8778




Figure 4.2  
FLOW ASSEMBLY  
1600 W Tacoma Street  
Broken Arrow, Oklahoma 74012  
www.airhygiene.com  
(888) 461-8778

**APPENDIX A**  
**TEST RESULTS AND CALCULATIONS**

TABLE A.1: EMISSIONS TESTING SCHEDULE

Unit	Load	Component	Run	Date	Start	Stop	Time Sync	Duration
1	> 90%	Stratification Test	1	02/21/23	11:18	11:48	DAHS	00:31
1	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-1	02/21/23	12:18	13:17	DAHS	01:00
1	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-2	02/21/23	13:28	14:27	DAHS	01:00
1	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-3	02/21/23	14:39	15:38	DAHS	01:00
1	> 90%	Flow	Flow-U1-V1	02/21/23	12:20	12:35	DAHS	00:15
1	> 90%	Flow	Flow-U1-V2	02/21/23	13:30	13:40	DAHS	00:10
1	> 90%	Flow	Flow-U1-V3	02/21/23	14:40	14:51	DAHS	00:11
2	> 90%	Stratification Test	1	02/16/23	13:53	14:29	DAHS	00:36
2	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-1	02/16/23	14:36	15:35	DAHS	01:00
2	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-2	02/16/23	15:44	16:43	DAHS	01:00
2	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-3	02/16/23	16:55	17:54	DAHS	01:00
2	> 90%	Flow	Flow-U2-V1	02/16/23	14:42	14:59	DAHS	00:17
2	> 90%	Flow	Flow-U2-V2	02/16/23	15:37	15:49	DAHS	00:12
2	> 90%	Flow	Flow-U2-V3	02/16/23	16:49	17:02	DAHS	00:13
3	> 90%	Stratification Test	1	02/20/23	13:14	13:45	DAHS	00:32
3	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-1	02/20/23	18:17	19:16	DAHS	01:00
3	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-2	02/20/23	19:29	20:28	DAHS	01:00
3	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-3	02/20/23	20:43	21:42	DAHS	01:00
3	> 90%	Flow	Flow-U3-V1	02/20/23	18:17	18:30	DAHS	00:13
3	> 90%	Flow	Flow-U3-V2	02/20/23	19:29	19:39	DAHS	00:10
3	> 90%	Flow	Flow-U3-V3	02/20/23	20:43	20:53	DAHS	00:10
4	> 90%	Stratification Test	1	02/18/23	17:17	17:48	DAHS	00:32
4	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-1	02/18/23	18:40	19:39	DAHS	01:00
4	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-2	02/18/23	19:57	20:56	DAHS	01:00
4	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-3	02/18/23	21:10	22:09	DAHS	01:00
4	> 90%	Flow	Flow-U4-V1	02/18/23	18:26	18:42	DAHS	00:16
4	> 90%	Flow	Flow-U4-V2	02/18/23	20:12	20:27	DAHS	00:15
4	> 90%	Flow	Flow-U4-V3	02/18/23	21:20	21:35	DAHS	00:15
5	> 90%	Stratification Test	1	02/19/23	09:53	10:39	DAHS	00:46
5	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-1	02/19/23	12:34	13:33	DAHS	01:00
5	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-2	02/19/23	15:46	16:45	DAHS	01:00
5	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-3	02/19/23	17:43	18:42	DAHS	01:00
5	> 90%	Flow	Flow-U5-V1	02/19/23	12:15	12:30	DAHS	00:15
5	> 90%	Flow	Flow-U5-V2	02/19/23	16:10	16:20	DAHS	00:10
5	> 90%	Flow	Flow-U5-V3	02/19/23	17:00	17:15	DAHS	00:15
6	> 90%	Stratification Test	1	02/15/23	13:44	14:22	DAHS	00:38
6	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-1	02/15/23	16:51	17:50	DAHS	01:00
6	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-2	02/15/23	18:02	19:01	DAHS	01:00
6	> 90%	NOx, CO, VOC, NH <sub>3</sub>	1-3	02/15/23	19:07	20:06	DAHS	01:00
6	> 90%	Flow	Flow-U5-V1	02/15/23	16:33	16:47	DAHS	00:14
6	> 90%	Flow	Flow-U5-V2	02/15/23	18:27	18:40	DAHS	00:13
6	> 90%	Flow	Flow-U5-V3	02/15/23	19:15	19:27	DAHS	00:12



# TEST RESULTS AND CALCULATIONS

## Unit #1 Emissions Data

SIEMENS, SGE-56SL, UNIT #EUGEN1, SERIAL #A9B0018 ≥90% LOAD DATA SUMMARY

Parameter	≥90% Load, Run - 1-1	≥90% Load, Run - 1-2	≥90% Load, Run - 1-3	Average
Date (mm/dd/yy)	02/21/23	02/21/23	02/21/23	02/21/23
Start Time (hh:mm:ss)	12:18:22	13:28:23	14:39:24	12:18:22
End Time (hh:mm:ss)	13:17:52	14:27:53	15:38:54	15:38:54
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.05	28.98	29.00	29.01
Amb. Temp. (°F)	56	38	40	44
Rel. Humidity (%)	50	50	48	49
Spec. Humidity (lb water / lb air)	0.004859	0.002416	0.002548	0.003274
Power Output (kilowatts)	900.0	900.0	900.0	900.0
Stack Flow (M2) (DSCFH)	144,278	142,661	141,004	142,648
Stack Moisture (% Method 320)	11.1	11.2	11.2	11.2
NOx (ppmvd)	4.14	4.25	4.36	4.25
NOx (ppm@15%O <sub>2</sub> )	1.99	2.04	2.09	2.04
NOx (g/hp*hr)	0.027	0.027	0.028	0.027
CO (ppmvd)	8.09	8.27	8.35	8.23
CO (ppm@15%O <sub>2</sub> )	3.88	3.96	4.00	3.95
CO (g/hp*hr)	0.032	0.032	0.032	0.032
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	406.51	410.20	405.26	407.32
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	195.07	196.50	194.26	195.28
THC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	2.518	2.512	2.453	2.494
CH <sub>4</sub> (ppmvd)	404.31	408.05	403.05	405.14
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	2.20	2.15	2.21	2.18
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	1.06	1.03	1.06	1.05
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	0.014	0.013	0.013	0.013
NH <sub>3</sub> (ppmvd)	3.65	3.91	4.21	3.92
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	1.75	1.88	2.02	1.88
NH <sub>3</sub> (g/hp*hr)	0.0087	0.0093	0.0099	0.0093
CO <sub>2</sub> (%)	6.88	6.87	6.88	6.88
O <sub>2</sub> (%)	8.60	8.58	8.59	8.59

**RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:**

ACE = Analyzer calibration error, percent of calibration span.  
B<sub>WS</sub> = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.  
C<sub>Ag</sub> = Average unadjusted gas concentration indicated by data recorder for the test run.  
C<sub>D</sub> = Pollutant concentration adjusted to dry conditions.  
C<sub>Dir</sub> = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.  
C<sub>Gas</sub> = Average effluent gas concentration adjusted for bias.  
C<sub>M</sub> = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.  
C<sub>MA</sub> = Actual concentration of the upscale calibration gas, ppmv.  
C<sub>O</sub> = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.  
C<sub>S</sub> = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.  
C<sub>SS</sub> = Concentration of NO<sub>x</sub> measured in the spiked sample.  
C<sub>Spike</sub> = Concentration of NO<sub>x</sub> in the undiluted spike gas.  
C<sub>Calc</sub> = Calculated concentration of NO<sub>x</sub> in the spike gas diluted in the sample.  
C<sub>V</sub> = Manufacturer certified concentration of a calibration gas (low, mid, or high).  
C<sub>W</sub> = Pollutant concentration measured under moist sample conditions, wet basis.  
CS = Calibration span.  
D = Drift assessment, percent of calibration span.  
E<sub>p</sub> = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.  
Eff<sub>NO2</sub> = NO<sub>2</sub> to NO converter efficiency, percent.  
H = High calibration gas, designator.  
L = Low calibration gas, designator.  
M = Mid calibration gas, designator.  
NO<sub>Final</sub> = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.  
NO<sub>x</sub>Corr = The NO<sub>x</sub> concentration corrected for the converter efficiency.  
NO<sub>x</sub>Final = The final NO<sub>x</sub> concentration observed during the converter efficiency test in Section 16.2.2.  
NO<sub>x</sub>Peak = The highest NO<sub>x</sub> concentration observed during the converter efficiency test in Section 16.2.2.  
Q<sub>Spike</sub> = Flow rate of spike gas introduced in system calibration mode, L/min.  
Q<sub>Total</sub> = Total sample flow rate during the spike test, L/min.  
R = Spike recovery, percent.  
SB = System bias, percent of calibration span.  
SB<sub>i</sub> = Pre-run system bias, percent of calibration span.  
SB<sub>f</sub> = Post-run system bias, percent of calibration span.  
SB / D<sub>AK</sub> = Alternative absolute difference criteria to pass bias and/or drift checks.  
SCE = System calibration error, percent of calibration span.  
SCE<sub>i</sub> = Pre-run system calibration error, percent of calibration span.  
SCE<sub>final</sub> = Post-run system calibration error, percent of calibration span.  
Z = Zero calibration gas, designator.

**40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:**

P<sub>r</sub> = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg  
P<sub>o</sub> = observed combustor inlet absolute pressure at test, mm Hg  
H<sub>o</sub> = observed humidity of ambient air, g H<sub>2</sub>O/g air  
e = transcendental constant, 2.718  
T<sub>a</sub> = ambient temperature, K

**Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:**

bhp = brake horsepower  
hp = horsepower  
Q<sub>sys</sub> = system flow (lpm)  
Q<sub>m</sub> = matrix spike flow (lpm)

RECEIVED

JUN 20 2023

AIR QUALITY DIVISION

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant  
 $B_{va}$  = Moisture fraction of ambient air, percent.  
 Btu = British thermal unit  
 $\%C$  = Concentration of carbon from an ultimate analysis of fuel, weight percent.  
 $\%CO_{2d}, \%CO_{2w}$  = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.  
 CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.  
 E = Pollutant emission rate, ng/J (lb/million Btu).  
 $E_a$  = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).  
 $E_{ao}, E_{ai}$  = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).  
 $E_{bi}$  = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).  
 $E_{bo}$  = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).  
 $E_{ci}$  = Pollutant rate in combined effluent, ng/J (lb/million Btu).  
 $E_{co}$  = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).  
 $E_d$  = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).  
 $E_{di}$  = Average inlet SO<sub>2</sub> rate for each sampling period d, ng/J (lb/million Btu).  
 $E_g$  = Pollutant rate from gas turbine, ng/J (lb/million Btu).  
 $E_{ga}$  = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 $E_p, E_{\bar{p}}$  = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 $E_h$  = Hourly average pollutant, ng/J (lb/million Btu).  
 $E_{hj}$  = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.  
 Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19  
 $F_d, F_w, F_c$  = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).  
 ft<sup>3</sup> = cubic feet  
 G = ideal gas conversion factor  
 (385.23 SCF/lb-mol at 68 deg F & 14.696 psia)  
 GCM = gross Btu per SCF (constant, compound based)  
 GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).  
 $GCV_p, GCV_r$  = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).  
 $\%H$  = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.  
 $H_b$  = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).  
 $H_g$  = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).  
 $\%H_2O$  = Concentration of water from an ultimate analysis of fuel, weight percent.  
 H = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).  
 K = volume of combustion component per pound of component (constant)  
 K = Conversion factor, 10<sup>-5</sup> (kJ/J)/(%) [10<sup>5</sup> Btu/million Btu].  
 $K_c = (9.57 \text{ scm/kg})/\% [(1.53 \text{ scf/lb})/\%]$ .  
 $K_{cc} = (2.0 \text{ scm/kg})/\% [(0.321 \text{ scf/lb})/\%]$ .  
 $K_{hd} = (22.7 \text{ scm/kg})/\% [(3.64 \text{ scf/lb})/\%]$ .  
 $K_{hw} = (34.74 \text{ scm/kg})/\% [(5.57 \text{ scf/lb})/\%]$ .  
 $K_n = (0.86 \text{ scm/kg})/\% [(0.14 \text{ scf/lb})/\%]$ .  
 $K_o = (2.85 \text{ scm/kg})/\% [(0.46 \text{ scf/lb})/\%]$ .  
 $K_s = (3.54 \text{ scm/kg})/\% [(0.57 \text{ scf/lb})/\%]$ .  
 $K_{std,ur} = 2 \times 10^4 \text{ Btu/wt}\% \text{-MMBtu}$   
 $K_w = (1.30 \text{ scm/kg})/\% [(0.21 \text{ scf/lb})/\%]$ .  
 lb = pound  
 ln = Natural log of indicated value.  
 $L_p, L_r$  = Weight of the product and raw fuel lots, respectively, metric ton (ton).  
 $\%N$  = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.  
 $M\%$  = mole percent  
 mol = mole  
 MW = molecular weight (lb/lb-mol)  
 $MW_{AIR}$  = molecular weight of air ( 28.9625 lb/lb-mole)<sup>1</sup>  
 NCM = net Btu per SCF (constant based on compound)  
 $\%O$  = Concentration of oxygen from an ultimate analysis of fuel, weight percent.  
 $\%O_{2d}, \%O_{2w}$  = Concentration of oxygen on a dry and wet basis, respectively, percent.  
 $P_B$  = barometric pressure, in Hg  
 $P_s$  = Potential SO<sub>2</sub> emissions, percent.  
 $\%S$  = Sulfur content of as-fired fuel lot, dry basis, weight percent.  
 $S_e$  = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).  
 $\%S_f$  = Concentration of sulfur from an ultimate analysis of fuel, weight percent.  
 $S(w\%)$  = weight percent of sulfur, per lab analysis by appropriate ASTM standard  
 $S_d$  = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).  
 $S_o$  = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).  
 $\%S_p, \%S_r$  = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.  
 SCF = standard cubic feet  
 SH = specific humidity, pounds of water per pound of air  
 $t_{0.95}$  = Values shown in Table 19-3 for the indicated number of data points n.  
 $T_{amb}$  = ambient temperature, °F  
 W/D Factor = 1.0236 = conv. at 14.696 psia and  
 68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)  
 $X_{CO_2}$  = CO<sub>2</sub> Correction factor, percent.  
 $X_k$  = Fraction of total heat input from each type of fuel k.

# Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

## Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

### ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO <sub>2</sub> (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH <sub>3</sub> (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO <sub>2</sub> (lb/lb-mole) =	44.01

## Formulas:

1. Corrected Raw Average (C<sub>Gas</sub>), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_o) \times \left( \frac{C_M}{C_M - C_o} \right)$$

2. Correction to % O<sub>2</sub>, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(T_{avg})} \times \left( \frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

3. Correction to % O<sub>2</sub> and ISO Conditions

$$C_{ISO} = C_{adj} \times \sqrt{\frac{P_f}{P_o}} \times e^{(19 \times (H_o - 0.00633))} \times \left( \frac{288}{T_o} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_s = \left( \frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left( \frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

### 40CFR60, App. A, RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO <sub>2</sub> =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH <sub>3</sub> =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO <sub>2</sub> =	0.0000001142434

NOTE: units are lb/ppm\*ft<sup>3</sup>

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_s \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O<sub>2</sub> based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_c \times 20.9\%}{20.9\% - C_{Gas(O_2)}}$$

8. Emission Concentration in g/hp\*hr

$$E_{g/hp\text{-}hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp}$$

## Nomenclature

- %CO = carbon monoxide concentration (%)
- %CO<sub>2</sub> = carbon dioxide concentration (%)
- %N<sub>2</sub> = nitrogen concentration (%)
- %O<sub>2</sub> = oxygen concentration (%)
- %O<sub>2,wet</sub> = Oxygen content of gas stream, % by volume of wet gas. (Note: The oxygen percentage used in Method 201A, Equation 3 is on a wet gas basis. That means that since oxygen is typically measured on a dry gas basis, the measured percent O<sub>2</sub> must be multiplied by the quantity (1 - B<sub>ws</sub>) to convert to the actual volume fraction. Therefore, %O<sub>2,wet</sub> = (1 - B<sub>ws</sub>) \* %O<sub>2,dry</sub>)
- (%EA)<sub>avg</sub> = average excess air (%)
- (F<sub>o</sub>)<sub>avg</sub> = average calculated fuel factor
- [(Δp)<sup>0.5</sup>]<sub>avg</sub> = Average of square roots of the velocity pressures measured during the preliminary traverse, inches W.C.
- μ = Gas viscosity, micropoise
- 12.0 = Constant calculated as 60 percent of 20.5 square inch cross-sectional area of combined cyclone head, square inches
- 17.03 = mg/milliequivalents for ammonium ion
- 22.4 = liters of ideal gas per lb-mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 24.04 = liters of ideal gas per lb-mol of substance at 20°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 5.02 × 10<sup>4</sup> = constant derived from the molecular weight and correcting standard temperature and pressure (ref. Bay Area Air Quality Management District, Source Test Procedure ST-1B, Ammonia Integrated Sampling, Adopted January 20, 1982, Regulation 7-303)
- A = distance upstream (in.)
- A<sub>D</sub> = stack diameters upstream (dia.)
- A<sub>n</sub> = Area of nozzle, square feet
- A<sub>s</sub> = area of stack (ft<sup>2</sup>)
- B = distance downstream (in.)
- B<sub>D</sub> = stack diameters downstream (dia.)
- b<sub>f</sub> = Average blockage factor calculated in Equation 26, dimensionless
- B<sub>wm</sub> = meter moisture content (%)
- B<sub>ws</sub> = stack moisture content (%)
- C = Cunningham correction factor for particle diameter, D<sub>p</sub>, and calculated using the actual stack gas temperature, dimensionless
- C<sub>1</sub> = -150.3162 (micropoise)
- C<sub>2</sub> = 18.0614 (micropoise/K<sup>0.5</sup>) = 13.4622 (micropoise/R<sup>0.5</sup>)
- C<sub>3</sub> = 1.19183 × 10<sup>6</sup> (micropoise/K<sup>2</sup>) = 3.86153 × 10<sup>6</sup> (micropoise/R<sup>2</sup>)
- C<sub>4</sub> = 0.591123 (micropoise)
- C<sub>5</sub> = 91.9723 (micropoise)
- C<sub>6</sub> = 4.91705 × 10<sup>-5</sup> (micropoise/K<sup>2</sup>) = 1.51761 × 10<sup>-5</sup> (micropoise/R<sup>2</sup>)
- C<sub>a</sub> = Acetone blank concentration, mg/mg
- C<sub>b</sub> = Concentration of NH<sub>3</sub> ion in the back half of train (breakthrough)
- C<sub>f</sub> = Concentration of NH<sub>3</sub> ion in the front half of train (main catch)
- C<sub>fPM10</sub> = Conc. of filterable PM<sub>10</sub>, gr/dscf
- C<sub>fPM2.5</sub> = Conc. of filterable PM<sub>2.5</sub>, gr/dscf
- C<sub>k</sub> = K Factor Constant, 849.8

## Nomenclature

- $C_n$  = nozzle diameter constant, 0.03575
- $C_p'$  = Coefficient for the pitot used in the preliminary traverse, dimensionless
- $C_p$  = Pitot coefficient for the combined cyclone pitot, dimensionless
- $C_{cpm}$  = Concentration of the condensable PM in the stack gas, dry basis, corrected to standard conditions, milligrams/dry standard cubic foot.
- $C_r$  = Re-estimated Cunningham correction factor for particle diameter equivalent to the actual cut size diameter and calculated using the actual stack gas temperature, dimensionless
- $D_{50}$  = Particle cut diameter, micrometers
- $D_{50(N+1)}$  =  $D_{50}$  value for cyclone IV calculated during the N+1 iterative step, micrometers
- $D_{50-1}$  = Re-calculated particle cut diameters based on re-estimated  $C_r$ , micrometers
- $D_{50LL}$  = Cut diameter for cyclone I corresponding to the 2.25 micrometer cut diameter for cyclone IV, micrometer
- $D_{50N}$  =  $D_{50}$  value for cyclone IV calculated during the Nth iterative step, micrometers
- $D_{50T}$  = Cyclone I cut diameter corresponding to the middle of the overlap zone shown in Method 201A, Figure 10 of Section 17, micrometers
- $D_e$  = equivalent stack diameter (in.)
- $\Delta H@$  =  $\Delta H @ 0.75$  scfm (in. H<sub>2</sub>O)
- $\Delta H_{avg}$  = average orifice pressure (in. H<sub>2</sub>O)
- $D_n$  = Inner diameter of sampling nozzle mounted on Cyclone I, inches
- $D_{na}$  = actual nozzle diameter (in.)
- $D_p$  = Physical particle size, micrometers
- $\Delta p$  = velocity head (in. H<sub>2</sub>O)
- $\Delta p_1$  = velocity head at first current traverse point (in. H<sub>2</sub>O)
- $\Delta p'_1$  = velocity head at first preliminary traverse point (in. H<sub>2</sub>O)
- $\Delta p_{avg}$  = average pitot tube differential pressure (in. H<sub>2</sub>O)
- $\Delta p_n$  = velocity head at subsequent current traverse point (in. H<sub>2</sub>O)
- $\Delta p_{RM2}$  = method 2 velocity head (in. H<sub>2</sub>O)
- $D_s$  = diameter of stack (in.)
- $F_d$  = fuel f-factor (dscf/MMBtu)
- $f_{O_2}$  = stack gas fraction of O<sub>2</sub>, by volume, dry basis
- $I$  = Percent isokinetic sampling, dimensionless
- $K_1$  = standard volume correction, 17.65°R/in. Hg
- $K_4$  = isokinetic conversion constant, 0.0945min•in.Hg/sec•°R
- $K_5$  = water mass to std water vapor, 0.04715 ft<sup>3</sup>/g
- $K_p$  = 85.49, ((ft/sec)/(pounds/mole •°R))
- $L$  = length of stack (in.)
- $L_{fw}$  = distance to far wall of stack (in.)
- $L_{nw}$  = distance to near wall of stack (in.) [reference]
- $m_{\#x}$  = weight measurements (g)
- $M_1$  = Milligrams of PM collected on the filter, less than or equal to 2.5 micrometers
- $M_2$  = Milligrams of PM recovered from Container #2 (acetone blank corrected), greater than 10 micrometers
- $M_3$  = Milligrams of PM recovered from Container #3 (acetone blank corrected), less than or equal to 10 and greater than 2.5 micrometers
- $M_4$  = Milligrams of PM recovered from Container #4 (acetone blank corrected), less than or equal to 2.5 micrometers

## Nomenclature

- $m_a$  = Mass of residue of acetone after evaporation, mg
- $m_c$  = Mass of the  $\text{NH}_4^+$  added to sample to form ammonium sulfate, mg
- $m_{\text{cpm}}$  = Mass of the total condensable PM, mg
- $M_d$  = Molecular weight of dry gas, pounds/pound mole
- $m_{\text{fb}}$  = Mass of total CPM in field train recovery blank, mg
- $m_{\text{fx}}$  = final weight, avg of last two measurements (g)
- mg = Milligram
- mg/L = Milligram per liter
- $m_i$  = Mass of inorganic CPM, mg
- $m_{\text{ib}}$  = Mass of inorganic CPM in field train recovery blank, mg
- $M_n$  = total particulates (mg)
- $m_o$  = Mass of organic CPM, mg
- $m_{\text{ob}}$  = Mass of organic CPM in field train blank, mg
- $m_r$  = Mass of dried sample from inorganic fraction, mg
- $m_{\text{tx}}$  = tare weight (g)
- MW = molecular weight (lb/lb-mole)
- $M_w$  = Molecular weight of wet gas, pounds/pound mole
- N = Normality of ammonium hydroxide titrant
- $N_a$  = null angle (deg.)
- $N_{\text{re}}$  = Reynolds number, dimensionless
- $N_{\text{tp}}$  = Number of iterative steps or total traverse points
- $P_b = P_{\text{bar}}$  = barometric pressure (in. Hg)
- $P_{\text{bar}}$  = barometric pressure (in. Hg)
- ppmCO = carbon monoxide concentration (ppm)
- ppmv = Parts per million by volume
- ppmw = Parts per million by weight
- $P_s$  = absolute stack pressure (in. Hg)
- $P_{\text{static}}$  = static pressure (in.  $\text{H}_2\text{O}$ )
- $P_{\text{std}}$  = standard pressure, 29.92 in. Hg
- $\Theta$  = total sampling time (min)
- $Q_{\text{aw}}$  = average stack wet flow rate (ascf/min)
- $Q_l$  = Sampling rate for cyclone I to achieve specified  $D_{50}$
- $Q_m$  = estimated orifice flow rate, 0.750 acfm, else  $V_m/Q$  from previous run
- $Q_s$  = Sampling rate for cyclone I to achieve specified  $D_{50}$
- $Q_{\text{s(std)}}$  = total cyclone flow rate at standard conditions (dscf/min)
- $Q_{\text{sd}}$  = dry standard stack flow rate (dscfm)
- $Q_{\text{sST}}$  = Dry gas sampling rate through the sampling assembly, dscfm
- $Q_{\text{sw}}$  = wet standard stack flow rate (ascfm)
- $R_{\text{max}}$  = Nozzle/stack velocity ratio parameter, dimensionless
- $R_{\text{min}}$  = Nozzle/stack velocity ratio parameter, dimensionless
- $t_1$  = Sampling time at point 1, min
- $t_m$  = average gas meter temperature ( $^{\circ}\text{F}$ )
- $t_m$  = average meter temperature ( $^{\circ}\text{F}$ )
- $T_m$  = Meter box and orifice gas temperature,  $^{\circ}\text{R}$
- $t_n$  = Sampling time at point n, min



## Nomenclature

- $t_r$  = Total projected run time, min
- $T_s$  = Absolute stack gas temperature, °R
- $T_{std}$  = standard temperature, 68°F, 528°R
- $T_u$  = absolute temperature offset, 460°R
- $V_a$  = Volume of acetone blank, ml
- $V_{aw}$  = Volume of acetone used in sample recovery wash, ml
- $V_b$  = Volume of aliquot taken for IC analysis, ml
- $V_c$  = Quantity of water captured in impingers and silica gel, ml
- $V_f$  = final impinger volume (ml)
- $V_i$  = initial impinger volume (ml)
- $V_{ic}$  = Volume of impinger contents sample, ml
- $V_m$  = Dry gas meter volume sampled, acf
- $V_{m(std)}$  = standard meter volume (dscf)
- $v_{max}$  = Maximum gas velocity calculated from Equations 18 or 19, ft/sec
- $v_{max}$  = maximum nozzle velocity (ft/sec)
- $V_{mf}$  = final dry gas meter reading (dcf)
- $V_{mi}$  = initial dry gas meter reading (dcf)
- $v_{min}$  = Minimum gas velocity calculated from Method 201A, Equations 16 or 17, ft/sec
- $V_{ms}$  = Dry gas meter volume sampled, corrected to standard conditions, dscf
- $v_n$  = Sample gas velocity in the nozzle, ft/sec
- $v_{org}$  = organics wash volume (ml)
- $V_p$  = Volume of water added during train purge
- $v_s$  = average stack gas velocity (ft/sec)
- $v_{sl}$  = local velocity (ft/sec)
- $V_t$  = total impinger volume (ml) =  $;(V_f - V_i)$
- $V_t$  = Volume of NH<sub>4</sub>OH titrant, ml
- $V_{w(std)}$  = volume of water vapor in gas sample at standard conditions (scf)
- $v_x$  = blank volume (ml)
- $W$  = width of stack (in.)
- $W_{2,3,4}$  = Weight of PM recovered from Containers #2, #3, and #4, mg
- $W_a$  = Weight of blank residue in acetone used to recover samples, mg
- $W_f$  = final impinger weight (g)
- $W_i$  = initial impinger weight (g)
- $W_t$  = total impinger weight (g) =  $;(W_f - W_i)$
- $w_x$  = blank weight of solids (g)
- $Y$  = meter calibration factor (a.k.a gamma)
- $Z$  = Ratio between estimated cyclone IV  $D_{50}$  values, dimensionless
- $\gamma$  = Dry gas meter gamma value, dimensionless
- $\Delta H$  = Meter box orifice pressure drop, inches W.C.
- $\Delta H@$  = Pressure drop across orifice at flow rate of 0.75 scfm at standard conditions, inches W.C. (Note: Specific to each orifice and meter box.)
- $\Delta p_1$  = Velocity pressure measured at point 1, inches W.C.
- $\Delta p_{avg}$  = Average velocity pressure, inches W.C.
- $\Delta p_m$  = Observed velocity pressure using S-type pitot tube in preliminary traverse, inches W.C.
- $\Delta p_{max}$  = Maximum velocity pressure, inches W.C.

## Nomenclature

- $\Delta p_{\min}$  = Minimum velocity pressure, inches W.C.
- $\Delta p_n$  = Velocity pressure measured at point n during the test run, inches W.C.
- $\Delta p_s$  = Velocity pressure calculated in Method 201a, Equation 25, inches W.C.
- $\Delta p_{s1}$  = Velocity pressure adjusted for combined cyclone pitot tube, inches W.C.
- $\Delta p_{s2}$  = Velocity pressure corrected for blockage, inches W.C.
- $\theta$  = Total run time, min
- $\rho_a$  = Density of acetone, mg/ml (see label on bottle)
- $\Sigma_n$  = total number of sampling points

**EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)**

**Diameter of Stack (in.)**

$$D(\text{in.}) = L_{fv} - L_{mv}$$

$$D(\text{in.}) = 19.00 \text{ in.} - 5.75 \text{ in.} = 13.25 \text{ in.}$$

**Stack Diameters Downstream**

$$B_D(\text{dia.}) = \frac{B}{D}$$

$$B_D(\text{dia.}) = \frac{90.00 \text{ in.}}{13.25 \text{ in.}} = 6.79 \text{ diameters}$$

**Area of Stack (ft<sup>2</sup>)**

$$A_s(\text{ft}^2) = \pi \times \left( \frac{D}{2 \times 12} \right)^2$$

$$A_s(\text{ft}^2) = 3.14 \times \left( \frac{13.25 \text{ in.}}{2 \times 12 \text{ in./ft}} \right)^2 = 0.96 \text{ ft}^2$$

**Stack Diameters Upstream**

$$A_D(\text{dia.}) = \frac{A}{D}$$

$$A_D(\text{dia.}) = \frac{62.50 \text{ in.}}{13.25 \text{ in.}} = 4.72 \text{ diameters}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Preliminary test]**

**Carbon Monoxide Concentration (%)**

$$\%CO = \frac{ppmCO}{10,000}$$

$$\%CO (\%) = \frac{8.09 \text{ ppm}}{10,000 \text{ ppm/\%}} = 0.0008 \%$$

**Nitrogen Concentration (%)**

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$$\%N_2 (\%) = 100 - 6.88 \% - 8.60 \% - 8.09 / 10,000 \% = 84.52 \%$$

**Stack Dry Molecular Weight (lb/lb-mole)**

$$M_d (\text{lb} / \text{lb} - \text{mol}) = \sum \left( \frac{MW_{comp}}{100} \times \%component \right)$$

$$M_d (\text{lb/lb-mol}) = \left( \frac{44 \text{ lb/lb-mol}}{100} \times 6.88 \% \right) +$$

$$\left( \frac{32 \text{ lb/lb-mol}}{100} \times 8.60 \% \right) + \left( \frac{28 \text{ lb/lb-mol}}{100} \times \left[ \frac{8.09}{10,000} + 84.52 \right] \right) = \frac{29.44 \text{ lb}}{\text{lb-mol}}$$

**Stack Wet Molecular Weight (lb/lb-mole)**

$$M_s (\text{lb} / \text{lb} - \text{mol}) = \left[ M_d \times \left( 1 - \frac{B_{ws}}{100} \right) \right] + \left[ MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s (\text{lb/lb-mol}) = \left\{ \frac{29.44 \text{ lb}}{\text{lb-mol}} \times \left( 1 - \frac{11.14 \%}{100} \right) \right\} + \left\{ \frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{11.14 \%}{100} \right\} = \frac{28.17 \text{ lb}}{\text{lb-mol}}$$

**Average Calculated Fuel Factor (F<sub>o</sub>)**

$$F_{o(avg)} = \frac{[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - 8.60 \% - (0.5 \times 0.001 \%)}{6.88 \% + 0.001 \%} = 1.788$$

**Average Excess Air (%)**

$$\%EA_{avg} (\%) = \frac{100 \times [(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}{(0.264 \times (N_2)_{avg}) - [(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{ 8.60 \% - (0.5 \times 0.001 \%) \}}{(0.264 \times 84.52 \%) - \{ 8.60 \% - (0.5 \times 0.001 \%) \}} = 62.77 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (Reference Method 2) [Values from Preliminary test]**

**Absolute Stack Pressure (in. Hg)**

$$P_s (\text{in. Hg}) = P_b + \frac{P_{\text{static}}}{13.6}$$

$$P_s (\text{in. Hg}) = 29.05 \text{ in. Hg} + \frac{-0.47 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.02 \text{ in. Hg}$$

**Average Stack Gas Velocity (ft/sec)**

$$v_s (\text{ft/sec}) = K_p \times C_p \times (\sqrt{\Delta p})_{\text{avg}} \times \sqrt{\frac{(t_s)_{\text{avg}} + T_u}{P_s \times M_s}}$$

$v_{sl} (\text{ft/sec}) =$

$$\left( \frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\text{sec (}^\circ\text{R)(in. H}_2\text{O)}} \right)^{1/2} \times 0.81 \times 0.96 \text{ in. H}_2\text{O}^{1/2} \times \sqrt{\frac{184.00 + 460^\circ\text{R}}{29.02 \text{ in. Hg} \times 28.17 \text{ lb/lb-mol}}} = \frac{59.2 \text{ ft}}{\text{sec}}$$

**Average Stack Dry Standard Flow Rate (dscfh)**

$$Q_{sd} (\text{dscfh}) = \frac{60 \times 60 \times \left(1 - \frac{B_{\text{ws}}}{100}\right) \times v_s \times A_s \times T_{\text{std}} \times P_s}{(t_s + T_u) \times P_{\text{std}}}$$

$$Q_{sd} (\text{dscf/hr}) = \frac{3600 \text{ sec}}{\text{hr}} \times \left(1 - \frac{11.14 \%}{100}\right) \times \frac{59.24 \text{ ft}}{\text{sec}} \times 0.96 \text{ ft}^2 \times \frac{68.00 + 460^\circ\text{R}}{184.00 + 460^\circ\text{R}} \times \frac{29.02 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{144,277.57 \text{ dscf}}{\text{hr}}$$

**Average Stack Wet Flow Rate (acfm)**

$$Q_{aw} (\text{acfm}) = 60 \times v_s \times A_s$$

$$Q_{aw} (\text{acf/min}) = \frac{60 \text{ sec}}{\text{min}} \times \frac{59.24 \text{ ft}}{\text{sec}} \times 0.96 \text{ ft}^2 = \frac{3,403.33 \text{ acf}}{\text{min}}$$

**Average Stack Wet Standard Flow Rate (ascfh)**

$$Q_{sw} (\text{ascfh}) = \frac{60 \times Q_{aw} \times T_{\text{std}} \times P_s}{(t_s + T_u) \times P_{\text{std}}}$$

$$Q_{sw} (\text{ascf/hr}) = \frac{60 \text{ min}}{\text{hr}} \times \frac{3,403.33 \text{ acf}}{\text{min}} \times \frac{68.00 + 460^\circ\text{R}}{184.00 + 460^\circ\text{R}} \times \frac{29.02 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{162,356.99 \text{ ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (INFORMATION)**

**Specific Humidity (RH<sub>sp</sub>)**

Note: RH<sub>sp</sub> (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} (lb/lb) = \left[ \left( \frac{gr}{lb} \right) \times \frac{lb}{7000 gr} \right] \qquad RH_{sp} = \frac{34.02 \text{ gr}}{lb} \times \frac{1 \text{ lb}}{7000 \text{ gr}} = 0.004859 \frac{\text{lb H}_2\text{O}}{\text{lb Air}}$$

**EXAMPLE CALCULATIONS (CALIBRATION)**

**Analyzer Calibration Error**

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left( \frac{C_{Dir} - C_r}{CS} \right) \times 100 \qquad \text{Eq. 7E-1} \qquad ACE = \frac{9.28 \text{ ppm} - 8.87 \text{ ppm}}{18.10 \text{ ppm}} \times 100 = 2.27 \%$$

**EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)**

**System Bias**

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left( \frac{C_s - C_{Dir}}{CS} \right) \times 100 \qquad \text{Eq. 7E-2} \qquad SB = \frac{8.83 \text{ ppm} - 9.28 \text{ ppm}}{18.10 \text{ ppm}} \times 100 = -2.49 \%$$

**Drift Assessment**

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{final} - SB_i| \qquad \text{Eq. 7E-4} \qquad D = | -2.38 \% - -2.49 \% | = 0.11 \%$$

**Alternative Drift and Bias**

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs - Cdir| is ≤ 0.5 ppmv or if |Cs - Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Air} = |C_s - C_{Dir}| \qquad \text{Eq. Section 13.2 and 13.3} \qquad SB / D_{Air} = | 8.83 \text{ ppm} - 9.28 \text{ ppm} | = 0.45 \text{ ppm}$$

**Bias Adjusted Average**

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_o) \times \left( \frac{C_M}{C_M - C_o} \right) \qquad \text{Eq. 7E-5b} \qquad C_{Gas} = \left[ 4.25 \text{ ppm} - 0.22 \text{ ppm} \right] \left( \frac{8.87 \text{ ppm}}{8.84 \text{ ppm} - 0.22 \text{ ppm}} \right) = 4.14 \text{ ppm}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (RUNS)**

**Moisture Correction**

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_W}{1 - B_{H_2O}} \quad \text{Eq. 7E-10} \quad C_D = \frac{3.68 \text{ ppmvw}}{1 - 0.11} = 4.14 \text{ ppmvd} \quad \text{or inversely,} \quad C_W = 4.14 \text{ ppmvd} \times (1 - 0.11) = 3.68 \text{ ppmvw}$$

**Diluent-Corrected Pollutant Concentration, O<sub>2</sub> Based**

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O<sub>2</sub> Concentration. Calculate the O<sub>2</sub> corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(T arg ct)} \times \left( \frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right) \quad \text{Eq. 20-4} \quad C_{adj} = 4.14 \text{ ppm} \times \left( \frac{20.9\% - 15.00\%}{20.9\% - 8.60\%} \right) = 1.99 \text{ ppm@15\%O}_2$$

**Emissions Rate (lb/hr)**

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G} \quad E_{lb/hr} = \frac{4.14 \text{ ppmvd}}{10^6 \text{ ppm/part}} \times \frac{144,278 \text{ DSCFH} \times 46.01 \text{ lb/lb-mol}}{385.23 \text{ SCF/lb-mol}} = \frac{0.07 \text{ lb}}{\text{hr}}$$

**Emissions Rate (g/hp-hr)**

Calculation for grams per horsepower-hour. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{g/hp-hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp} \quad E_{g/hp-hr} = \frac{0.07 \text{ lb}}{\text{hr}} \times \frac{453.6 \text{ g}}{\text{lb}} \times \frac{1}{0.90 \text{ mw}} \times \frac{\text{mw}}{1341.022 \text{ hp}} = \frac{0.03 \text{ g}}{\text{hp*hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**Method 320 Equation 3, Dilution Factor (DF)**

(example calculation for Pre-Trial, where applicable)

$$DF = \frac{SF_6(spik)}{SF_6(dir)} = \frac{(SF_6(spik+native) - SF_6(native))}{SF_6(dir)} \text{ OR } \frac{(CO_2(native) - CO_2(spik+native))}{CO_2(native)}$$

$$DF (SF_6) = \frac{0.8416 \text{ ppmvw} - 0.0120 \text{ ppmvw}}{9.99 \text{ ppmvw}} = 0.0830$$

**Test Method 320, Section 9.0 Quality Control**

Where,

SF<sub>6(dir)</sub> = SF<sub>6</sub> (or tracer gas) concentration measured directly in undiluted spike gas

SF<sub>6(spik)</sub> = Diluted SF<sub>6</sub> (or tracer gas) concentration measured in a spiked sample

$$SF_6(spik) = SF_6(spik+native) - SF_6(native)$$

SF<sub>6(spik+native)</sub> = Diluted SF<sub>6</sub> (or tracer gas) concentration measured in a spiked sample in stack gas

SF<sub>6(native)</sub> = SF<sub>6</sub> (or tracer gas) concentration measured in a native stack gas sample

**Dilution Factor Ratio**

(example calculation for Pre-Trial, where applicable)

$$DF \text{ Ratio} = \frac{SF_6(dir)}{SF_6(spik)} = \frac{SF_6(dir)}{(SF_6(spik+native) - SF_6(native))} \text{ OR } \frac{CO_2(native)}{CO_2(native) - CO_2(spik+native)} \geq 10$$

$$DF \text{ Ratio} = \frac{9.99 \text{ ppmvw}}{0.8416 \text{ ppmvw} - 0.0120 \text{ ppmvw}} =$$

$$\text{Spike Ratio} = 12.0 : 1 \geq 10$$

Unspike = Native concentration of analytes in unspiked samples

Spike<sub>dir</sub> = Concentration of the analyte in the spike standard measured by filling the FTIR cell directly

**Method 320 Equation 4 [Method 321 Equation 2], Excepted Concentration of the Spiked Samples**

**Ideal Spike Yield**

(example calculation for Pre-Trial (SF<sub>6</sub>), where applicable)

$$CS = DF \times \text{Spike}_{dir} + \text{Unspike} (1 - DF)$$

$$CS = 0.0830 \times 9.9925 \text{ ppmvw} + 0.0120 \text{ ppmvw} \times (1 - 0.0830) = 0.8406 \text{ ppmvw}$$

**Method 320 Spiked vs Expected**

$$\text{Spiked vs Expected} = \frac{\text{Actual Spike Yield}}{\text{Ideal Spike Yield}} \times 100$$

(example calculation for Pre-Trial (SF<sub>6</sub>), where applicable)

$$\% \text{ Recovery} = \frac{0.8416 \text{ ppmvw}}{0.8406 \text{ ppmvw}} \times 100 = 100.118 \%$$

**Method 320 Equation 4 [Method 321 Equation 2], Excepted Concentration of the Spiked Samples**

**Ideal Spike Yield**

(example calculation for Pre-Trial (NH<sub>3</sub>), where applicable)

$$CS = DF \times \text{Spike}_{dir} + \text{Unspike} (1 - DF)$$

$$CS = 0.0830 \times 47.6968 \text{ ppmvw} + 2.5519 \text{ ppmvw} \times (1 - 0.0830) = 6.3001 \text{ ppmvw}$$

**Method 320 Spiked vs Expected**

$$\text{Spiked vs Expected} = \frac{\text{Actual Spike Yield}}{\text{Ideal Spike Yield}} \times 100$$

(example calculation for Pre-Trial (NH<sub>3</sub>), where applicable)

$$\% \text{ Recovery} = \frac{7.1369 \text{ ppmvw}}{6.3001 \text{ ppmvw}} \times 100 = 113.283 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.



**Method 320 Equation 3, Dilution Factor (DF)**

(example calculation for Post-Trial, where applicable)

$$DF = \frac{SF_6(spik)}{SF_6(dir)} = \frac{(SF_6(spik+native) - SF_6(native))}{SF_6(dir)} \text{ OR } \frac{(CO_2(native) - CO_2(spik+native))}{CO_2(native)}$$

$$DF (SF_6) = \frac{0.8318 \text{ ppmw} - 0.0133 \text{ ppmw}}{9.99 \text{ ppmw}} = 0.0819$$

**Test Method 320, Section 9.0 Quality Control**

Where,

SF<sub>6(dir)</sub> = SF<sub>6</sub> (or tracer gas) concentration measured directly in undiluted spike gas

SF<sub>6(spik)</sub> = Diluted SF<sub>6</sub> (or tracer gas) concentration measured in a spiked sample

$$SF_{6(spik)} = SF_{6(spik+native)} - SF_{6(native)}$$

SF<sub>6(spik+native)</sub> = Diluted SF<sub>6</sub> (or tracer gas) concentration measured in a spiked sample in stack gas

SF<sub>6(native)</sub> = SF<sub>6</sub> (or tracer gas) concentration measured in a native stack gas sample

**Dilution Factor Ratio**

(example calculation for Post-Trial, where applicable)

$$DF \text{ Ratio} = \frac{SF_6(dir)}{SF_6(spik)} = \frac{SF_6(dir)}{(SF_6(spik+native) - SF_6(native))} \text{ OR } \frac{CO_2(native)}{CO_2(native) - CO_2(spik+native)} \geq 10$$

$$DF \text{ Ratio} = \frac{9.99 \text{ ppmw}}{0.8318 \text{ ppmw} - 0.0133 \text{ ppmw}} =$$

$$\text{Spike Ratio} = 12.2 : 1 \geq 10$$

Unspike = Native concentration of analytes in unspiked samples

Spike<sub>dir</sub> = Concentration of the analyte in the spike standard measured by filling the FTIR cell directly

**Method 320 Equation 4 [Method 321 Equation 2], Expected Concentration of the Spiked Samples**

**Ideal Spike Yield**

(example calculation for Post-Trial (SF<sub>6</sub>), where applicable)

$$CS = DF \times Spike_{dir} + Unspike (1 - DF)$$

$$CS = 0.0819 \times 9.9925 \text{ ppmw} + 0.0133 \text{ ppmw} \times [1 - 0.0819] = 0.8307 \text{ ppmw}$$

**Method 320 Spiked vs Expected**

$$Spiked \text{ vs Expected} = \frac{\text{Actual Spike Yield}}{\text{Ideal Spike Yield}} \times 100$$

(example calculation for Post-Trial (SF<sub>6</sub>), where applicable)

$$\% \text{ Recovery} = \frac{0.8318 \text{ ppmw}}{0.8307 \text{ ppmw}} \times 100 = 100.131 \%$$

**Method 320 Equation 4 [Method 321 Equation 2], Expected Concentration of the Spiked Samples**

**Ideal Spike Yield**

(example calculation for Post-Trial (NH<sub>3</sub>), where applicable)

$$CS = DF \times Spike_{dir} + Unspike (1 - DF)$$

$$CS = 0.0819 \times 47.6968 \text{ ppmw} + 3.9577 \text{ ppmw} \times [1 - 0.0819] = 7.5405 \text{ ppmw}$$

**Method 320 Spiked vs Expected**

$$Spiked \text{ vs Expected} = \frac{\text{Actual Spike Yield}}{\text{Ideal Spike Yield}} \times 100$$

(example calculation for Post-Trial (NH<sub>3</sub>), where applicable)

$$\% \text{ Recovery} = \frac{8.2625 \text{ ppmw}}{7.5405 \text{ ppmw}} \times 100 = 109.575 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

## **TEST RESULTS AND CALCULATIONS**

### **Unit #2 Emissions Data**

**SIEMENS, SGE-56SL, UNIT #EUGEN2, SERIAL #A9C0007 ≥90% LOAD DATA SUMMARY**

Parameter	≥90% Load, Run - 1-1	≥90% Load, Run - 1-2	≥90% Load, Run - 1-3	Average
Date (mm/dd/yy)	02/16/23	02/16/23	02/16/23	02/16/23
Start Time (hh:mm:ss)	14:36:23	15:44:23	16:55:28	14:36:23
End Time (hh:mm:ss)	15:35:53	16:43:53	17:54:58	17:54:58
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.17	29.13	29.08	29.13
Amb. Temp. (°F)	37	33	31	34
Rel. Humidity (%)	71	77	90	79
Spec. Humidity (lb water / lb air)	0.003354	0.003105	0.003332	0.003264
Power Output (kilowatts)	920.0	900.0	900.0	906.7
Stack Flow (M2) (DSCFH)	136,843	136,618	136,067	136,509
Stack Moisture (% Method 320)	11.2	11.4	11.4	11.3
NOx (ppmvd)	7.35	7.62	7.84	7.60
NOx (ppm@15%O <sub>2</sub> )	3.53	3.65	3.76	3.65
NOx (g/hp*hr)	0.044	0.047	0.048	0.046
CO (ppmvd)	0.09	0.11	0.13	0.11
CO (ppm@15%O <sub>2</sub> )	0.05	0.05	0.06	0.05
CO (g/hp*hr)	0.000	0.000	0.000	0.000
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	362.74	356.82	346.26	355.27
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	173.90	170.94	166.07	170.30
THC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	2.084	2.093	2.022	2.067
CH <sub>4</sub> (ppmvd)	361.15	355.16	344.61	353.64
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	1.59	1.66	1.66	1.64
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	0.76	0.80	0.80	0.78
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	0.009	0.010	0.010	0.010
NH <sub>3</sub> (ppmvd)	4.56	4.69	4.50	4.59
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	2.19	2.25	2.16	2.20
NH <sub>3</sub> (g/hp*hr)	0.0102	0.0106	0.0102	0.0103
CO <sub>2</sub> (%)	6.63	6.82	6.79	6.74
O <sub>2</sub> (%)	8.59	8.58	8.60	8.59

## **TEST RESULTS AND CALCULATIONS**

### **Unit #3 Emissions Data**

**SIEMENS, SGE-56SL, UNIT #EUGEN3, SERIAL #A9A0027 ≥90% LOAD DATA SUMMARY**

Parameter	≥90% Load, Run - 1-1	≥90% Load, Run - 1-2	≥90% Load, Run - 1-3	Average
Date (mm/dd/yy)	02/20/23	02/20/23	02/20/23	02/20/23
Start Time (hh:mm:ss)	18:17:24	19:29:24	20:43:24	18:17:24
End Time (hh:mm:ss)	19:16:54	20:28:54	21:42:54	21:42:54
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.00	28.99	28.96	28.98
Amb. Temp. (°F)	41	38	35	38
Rel. Humidity (%)	47	51	70	56
Spec. Humidity (lb water / lb air)	0.002572	0.002533	0.003072	0.002726
Power Output (kilowatts)	900.0	900.0	900.0	900.0
Stack Flow (M2) (DSCFH)	98,233	100,535	102,152	100,307
Stack Moisture (% Method 320)	11.5	11.4	11.4	11.4
NOx (ppmvd)	25.62	24.89	24.97	25.16
NOx (ppm@15%O <sub>2</sub> )	12.13	11.78	11.80	11.90
NOx (g/hp*hr)	0.113	0.112	0.114	0.113
CO (ppmvd)	4.73	4.72	4.72	4.72
CO (ppm@15%O <sub>2</sub> )	2.24	2.23	2.23	2.23
CO (g/hp*hr)	0.013	0.013	0.013	0.013
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	384.13	382.87	384.30	383.77
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	181.89	181.16	181.56	181.54
THC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	1.620	1.652	1.685	1.652
CH <sub>4</sub> (ppmvd)	355.72	354.41	355.92	355.35
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	28.41	28.46	28.39	28.42
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	13.45	13.47	13.41	13.44
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	0.120	0.123	0.124	0.122
NH <sub>3</sub> (ppmvd)	6.48	6.86	6.99	6.78
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	3.07	3.25	3.30	3.21
NH <sub>3</sub> (g/hp*hr)	0.0106	0.0115	0.0119	0.0113
CO <sub>2</sub> (%)	6.88	6.88	6.89	6.88
O <sub>2</sub> (%)	8.44	8.43	8.41	8.43

## TEST RESULTS AND CALCULATIONS

### Unit #4 Emissions Data

10/10/2010  
10/10/2010

**SIEMENS, SGE-56SL, UNIT #EUGEN4, SERIAL #A9B0001 ≥90% LOAD DATA SUMMARY**

Parameter	≥90% Load, Run - 1-1	≥90% Load, Run - 1-2	≥90% Load, Run - 1-3	Average
Date (mm/dd/yy)	02/18/23	02/18/23	02/18/23	02/18/23
Start Time (hh:mm:ss)	18:40:12	19:57:12	21:10:12	18:40:12
End Time (hh:mm:ss)	19:39:42	20:56:42	22:09:42	22:09:42
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.48	29.49	29.48	29.48
Amb. Temp. (°F)	40	39	39	39
Rel. Humidity (%)	53	57	58	56
Spec. Humidity (lb water / lb air)	0.002784	0.002879	0.002930	0.002864
Power Output (kilowatts)	920.0	909.0	900.0	909.7
Stack Flow (M2) (DSCFH)	144,002	135,641	144,076	141,240
Stack Moisture (% Method 320)	11.0	11.0	11.0	11.0
NOx (ppmvd)	17.75	17.23	17.14	17.37
NOx (ppm@15%O <sub>2</sub> )	8.71	8.46	8.41	8.53
NOx (g/hp*hr)	0.112	0.104	0.111	0.109
CO (ppmvd)	0.02	0.00	0.00	0.01
CO (ppm@15%O <sub>2</sub> )	0.01	0.00	0.00	0.00
CO (g/hp*hr)	0.000	0.000	0.000	0.000
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	446.45	447.58	448.48	447.50
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	219.16	219.79	220.20	219.72
THC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	2.700	2.580	2.774	2.685
CH <sub>4</sub> (ppmvd)	414.69	415.86	416.44	415.66
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	31.76	31.72	32.04	31.84
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	15.59	15.58	15.73	15.63
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	0.192	0.183	0.198	0.191
NH <sub>3</sub> (ppmvd)	0.43	0.17	0.13	0.24
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	0.21	0.08	0.06	0.12
NH <sub>3</sub> (g/hp*hr)	0.0010	0.0004	0.0003	0.0006
CO <sub>2</sub> (%)	6.60	6.65	6.67	6.64
O <sub>2</sub> (%)	8.88	8.88	8.88	8.88

**RECEIVED**

**JUN 20 2023**

**AIR QUALITY DIVISION**

## **TEST RESULTS AND CALCULATIONS**

### **Unit #5 Emissions Data**



**SIEMENS, SGE-56SL, UNIT #EUGEN5, SERIAL #A9B0011 ≥90% LOAD DATA SUMMARY**

Parameter	≥90% Load, Run - 1-1	≥90% Load, Run - 1-2	≥90% Load, Run - 1-3	Average
Date (mm/dd/yy)	02/19/23	02/19/23	02/19/23	02/19/23
Start Time (hh:mm:ss)	12:34:02	15:46:02	17:43:02	12:34:02
End Time (hh:mm:ss)	13:33:32	16:45:32	18:42:32	18:42:32
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.13	29.04	29.04	29.07
Amb. Temp. (°F)	52	56	55	54
Rel. Humidity (%)	43	40	41	41
Spec. Humidity (lb water / lb air)	0.003545	0.003886	0.003823	0.003751
Power Output (kilowatts)	920.0	900.0	900.0	906.7
Stack Flow (M2) (DSCFH)	126,593	128,531	126,666	127,263
Stack Moisture (% Method 320)	11.3	11.3	11.3	11.3
NOx (ppmvd)	19.70	20.57	21.73	20.67
NOx (ppm@15%O <sub>2</sub> )	9.41	9.84	10.38	9.87
NOx (g/hp*hr)	0.112	0.119	0.124	0.118
CO (ppmvd)	3.66	3.68	3.77	3.70
CO (ppm@15%O <sub>2</sub> )	1.75	1.76	1.80	1.77
CO (g/hp*hr)	0.013	0.013	0.013	0.013
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	397.63	398.28	403.02	399.64
THC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	189.98	190.43	192.43	190.95
THC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	2.161	2.197	2.191	2.183
CH <sub>4</sub> (ppmvd)	369.42	370.14	375.16	371.57
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppmvd)	28.21	28.14	27.86	28.07
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (ppm@15%O <sub>2</sub> )	13.48	13.46	13.30	13.41
NMHC (as C <sub>3</sub> H <sub>8</sub> ) (g/hp*hr)	0.153	0.155	0.151	0.153
NH <sub>3</sub> (ppmvd)	7.69	7.52	5.41	6.87
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	3.68	3.59	2.59	3.28
NH <sub>3</sub> (g/hp*hr)	0.0162	0.0160	0.0114	0.0145
CO <sub>2</sub> (%)	6.87	6.88	6.92	6.89
O <sub>2</sub> (%)	8.55	8.56	8.54	8.55

## **TEST RESULTS AND CALCULATIONS**

### **Unit #6 Emissions Data**

**SIEMENS, SGE-56SL, UNIT #EUGEN6, SERIAL #BOD0008 ≥90% LOAD DATA SUMMARY**

<b>Parameter</b>	<b>≥90% Load, Run - 1-1</b>	<b>≥90% Load, Run - 1-2</b>	<b>≥90% Load, Run - 1-3</b>	<b>Average</b>
<b>Date (mm/dd/yy)</b>	02/15/23	02/15/23	02/15/23	02/15/23
<b>Start Time (hh:mm:ss)</b>	16:51:17	18:02:17	19:07:17	16:51:17
<b>End Time (hh:mm:ss)</b>	17:50:47	19:01:47	20:06:47	20:06:47
<b>Run Duration (min / run)</b>	60	60	60	60
<b>Bar. Pressure (in. Hg)</b>	29.05	29.14	29.18	29.12
<b>Amb. Temp. (°F)</b>	56	54	50	53
<b>Rel. Humidity (%)</b>	50	56	60	55
<b>Spec. Humidity (lb water / lb air)</b>	0.004859	0.005065	0.004638	0.004854
<b>Power Output (kilowatts)</b>	900.0	900.0	900.0	900.0
<b>Stack Flow (M2) (DSCFH)</b>	142,848	141,941	143,664	142,817
<b>Stack Moisture (% Method 320)</b>	11.7	11.7	11.6	11.7
<b>NOx (ppmvd)</b>	7.61	7.71	7.71	7.68
<b>NOx (ppm@15%O<sub>2</sub>)</b>	3.63	3.67	3.67	3.66
<b>NOx (g/hp*hr)</b>	0.049	0.049	0.050	0.049
<b>CO (ppmvd)</b>	6.40	6.44	6.53	6.46
<b>CO (ppm@15%O<sub>2</sub>)</b>	3.05	3.07	3.11	3.08
<b>CO (g/hp*hr)</b>	0.025	0.025	0.026	0.025
<b>THC (as C<sub>3</sub>H<sub>8</sub>) (ppmvd)</b>	362.82	363.74	362.09	362.88
<b>THC (as C<sub>3</sub>H<sub>8</sub>) (ppm@15%O<sub>2</sub>)</b>	172.88	173.22	172.49	172.86
<b>THC (as C<sub>3</sub>H<sub>8</sub>) (g/hp*hr)</b>	2.225	2.216	2.233	2.225
<b>CH<sub>4</sub> (ppmvd)</b>	344.27	344.99	342.73	343.99
<b>NMHC (as C<sub>3</sub>H<sub>8</sub>) (ppmvd)</b>	18.55	18.76	19.37	18.89
<b>NMHC (as C<sub>3</sub>H<sub>8</sub>) (ppm@15%O<sub>2</sub>)</b>	8.84	8.93	9.23	9.00
<b>NMHC (as C<sub>3</sub>H<sub>8</sub>) (g/hp*hr)</b>	0.114	0.114	0.119	0.116
<b>NH<sub>3</sub> (ppmvd)</b>	2.98	2.28	2.01	2.42
<b>NH<sub>3</sub> (ppm@15%O<sub>2</sub>)</b>	1.42	1.09	0.96	1.15
<b>NH<sub>3</sub> (g/hp*hr)</b>	0.0071	0.0054	0.0048	0.0057
<b>CO<sub>2</sub> (%)</b>	6.06	6.85	6.84	6.58
<b>O<sub>2</sub> (%)</b>	8.52	8.51	8.51	8.51

**APPENDIX B**  
**EMISSION DATA RECORDS**