



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
LANSING



C. HEIDI GREYER  
DIRECTOR

June 11, 2018

Mr. Brian Donovan  
BD Donovan Builders, Inc.  
7235 Campbell Mills Court  
Brighton, Michigan 48116

Mr. Rick Haslock  
Haslock & Sons Excavating  
5275 West Coon Lake Road  
Howell, Michigan 48843

SRN / ID: U471803725; Livingston County

Dear Mr. Donovan and Mr. Haslock:

### **VIOLATION NOTICE**

On June 7, 2018, the Department of Environmental Quality (DEQ), Air Quality Division, performed an asbestos NESHAP (National Emission Standard for Hazardous Air Pollutants) inspection at 293-295 and 301-303 Second Street, Brighton, Livingston County. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451).

According to my investigation, BD Donovan Builders, Inc., owns the subject facility and Haslock & Sons Excavating, is the contractor who performed the demolition activities. The National Emission Standard for Asbestos holds both the owner and operator equally liable for any violations.

During the inspection, staff observed the following:

The multi-unit apartment buildings were demolished, and the demolition debris was in the process of being loaded-out for offsite disposal. A 10-working day notification for the demolition was not submitted to the administrator prior to the demolition activities.

Mr. Brian Donovan  
Mr. Rick Haslock  
Page 2  
June 11, 2018


Process Description	Section Violated	Comments
Upon arrival to perform a post-planned renovation inspection of the multi-unit apartments located at 301-303 and 293-295 Second St., Brighton, Livingston County, staff observed demolition activities without a 10-working day notification	40 CFR 61.145 (b)(1)(3)(i)	Failed to provide the administrator with written notice of intention to demolish

Please initiate actions necessary to correct the cited violation and submit a written response to this violation notice by July 2, 2018, (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation, and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence. The signed written response to this violation notice may be submitted by mail and directed to my attention at; DEQ AQD, P.O. Box 30260, Lansing, Michigan 48909 or scanned and emailed as an attachment to me at; dechyc@michigan.gov.

If you believe the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my site visit. If you have any questions regarding the violation notification or the actions necessary to bring this facility into compliance, please feel free to contact me at 517-749-2891; dechyc@michigan.gov; or DEQ AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

Sincerely,



Craig Dechy  
Environmental Quality Analyst  
Air Quality Division

cc: Ms. Mary Ann Dolehanty, DEQ  
Mr. Craig Fitzner, DEQ  
Mr. Christopher Ethridge, DEQ  
Mr. Brad Myott, DEQ  
Ms. Jenine Camilleri, DEQ  
Ms. Karen Kajiya-Mills, DEQ