## SUPPLEMENT TO PERMIT NO. 45-98

P.O.H. Medical Center Pontiac, Michigan

April 23, 1998

## GENERAL CONDITIONS

- 1. Rule 201(1) The process or process equipment covered by this permit shall not be reconstructed, relocated, altered, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule.
- 2. Rule 201(4) If the installation, reconstruction, relocation, or alteration of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the person to whom this permit was issued, or the designated authorized agent, shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909, if it is decided not to pursue the installation, reconstruction, relocation, or alteration of the equipment allowed by this Permit to Install.
- 3. Rule 201(6)(a) If this Permit to Install is issued for a process or process equipment located at a stationary source which is subject to a Renewable Operating Permit pursuant to Rule 210, trial operation is allowed if the equipment performs in accordance with the terms and conditions of this Permit to Install and until the appropriate terms and conditions of this Permit to Install have been incorporated into the Renewable Operating Permit as a modification pursuant to Rule 216 or upon renewal pursuant to Rule 217. Upon incorporation of the appropriate terms and conditions into the Renewable Operating Permit, this Permit to Install shall become void.
- 4. Rules 201(7)(a) or 216(1)(a)(v)(A) Except as provided in General Condition No. 3, operation of the process or process equipment is allowed if, not more than 30 days after completion of the installation, construction, reconstruction, relocation, alteration, or modification authorized by this Permit to Install, the person to whom this Permit to Install was issued, or the authorized agent pursuant to Rule 204, notifies the District Supervisor, Air Quality Division, in writing, of the completion of the activity. Completion of the installation, construction, reconstruction, relocation, alteration, or modification is considered to occur not later than commencement of trial operation of the process or process equipment.
- 5. Rule 201(7)(b) Except as provided in General Condition No. 3, not more than 18 months after completion of the installation, construction, reconstruction, relocation, alteration, or modification authorized by this Permit to Install, the person to whom this permit was issued, or the authorized agent pursuant to Rule 204, shall notify the District Supervisor, Air Quality Division, in writing, of the status of compliance of the process or process equipment with the terms and conditions of the Permit to Install. The notification shall include all of the following:
  - A. The results of all testing, monitoring, and recordkeeping performed to determine the actual emissions from the process or process equipment and to demonstrate compliance with the terms and conditions of the Permit to Install.
  - B. A schedule of compliance for the process or process equipment as described in Rule 119(a).

P.O.H. Medical Center Permit No. 45-98 Page 2 April 23, 1998

- C. A statement, signed by the person owning or operating the process or process equipment, that, based on information and belief formed after reasonable inquiry, the statements and information in the notification are true, accurate, and complete.
- 6. Rule 201(8) and Section 5510 of Act 451, P.A. 1994 The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Departments' rules or the Clean Air Act.
- 7. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to Rule 219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required in Rule 219(1)(a), (b) and (c). The written request shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environmental Quality.
- 8. Rule 901 Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property.
- 9. Rule 912 The owner or operator of a source, process, or process equipment shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant in excess of standards for more than one hour, or of any air contaminant in excess of standards for more than two hours, as required in this rule, to the District Supervisor, Air Quality Division. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the District Supervisor within 10 days, with the information required in this rule.
- 10. Approval of this permit does not exempt the person to whom this permit was issued from complying with any future regulations which may be promulgated under Part 55 of Act 451, P.A. 1994.
- 11. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
- 12. Operation of this equipment may be subject to other requirements of Part 55 of Act 451, P.A. 1994, and the rules promulgated thereunder.

## SPECIAL CONDITIONS

13. The sulfur dioxide emission rate from the three natural gas and No. 2 fuel oil fired boilers, hereafter referred to as "boilers", shall not exceed 0.5 pound per million BTUs heat input, nor 31.5 pounds per hour, based upon a 30-day time period, nor 87.7 tons per year. This is equivalent to using distillate fuel oil with a 0.5% sulfur content and a heat value of 140,000 BTUs per gallon.

P.O.H. Medical Center Permit No. 45-98 Page 3 April 23, 1998

- 14. Applicant shall not burn more than 2,506,000 gallons of No. 2 fuel oil in the boilers based on a 12-calendar month rolling time period.
- 15. Applicant shall keep a daily record of the amount of No. 2 fuel oil burned in the boilers. By the 15th day of each calendar month, the applicant shall calculate the previous 12-calendar month No. 2 fuel oil usage in gallons. The calendar month usage and 12-calendar month usage rates shall be kept on file for a period of at least two years and made available to the Air Quality Division upon request.
- 16. Visible emissions from the boilers shall not exceed a 6-minute average of 20% opacity, except as specified in Rule 301(1)(a).
- 17. The exhaust gases from the boilers shall be discharged unobstructed vertically upwards to the ambient air from a stack with a maximum diameter of 36 inches at an exit point not less than 192.7 feet above ground level.
- 18. Within 60 days after achieving the maximum production rate, but not later than 180 days after the commencement of trial operation, Federal Standards of Performance for New Stationary Sources require certification from the fuel supplier of sulfur in the No. 2 fuel oil burned in the boilers by testing, at owner's expense, in accordance with 40 CFR, Part 60, Subparts A and Dc. Certification includes the submittal of a complete report of the test results. Applicant shall notify the District Supervisor in writing within 15 days of the date of commencement of trial operation in accordance with 40 CFR, Part 60.7(a)(3). The certification procedure shall be in accordance with 40 CFR, Part 60.48c(f)(1). No less than 60 days prior to testing, a complete certification procedure must be submitted to the Air Quality Division. The procedure must be approved by the Air Quality Division prior to testing.
- 19. Monitoring and recording of emissions and operating information is required to comply with the Federal Standards of Performance for New Stationary Sources as specified in 40 CFR, Part 60, Subparts A and Dc. All source emissions data and operating data shall be submitted to the District Supervisor in an acceptable format within 30 days following the end of the quarter in which the data were collected.