MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY DIVISION

July 14, 2011

PERMIT TO INSTALL 199-10A

ISSUED TO
Hewlett-Packard Enterprise Services, LLC

LOCATED AT 1035 West Entrance Drive Auburn Hills, Michigan

IN THE COUNTY OF Oakland

RIS PENINSULA

STATE REGISTRATION NUMBER N5505

The Air Quality Division has approved this Permit to Install, pursuant to the delegation of authority from the Michigan Department of Environmental Quality. This permit is hereby issued in accordance with and subject to Section 5505(1) of Article II, Chapter I, Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. Pursuant to Air Pollution Control Rule 336.1201(1), this permit constitutes the permittee's authority to install the identified emission unit(s) in accordance with all administrative rules of the Department and the attached conditions. Operation of the emission unit(s) identified in this Permit to Install is allowed pursuant to Rule 336.1201(6).

DATE OF RECEIPT OF ALL INFORMATION REQUIRED BY RULE 203: June 24, 2011			
DATE PERMIT TO INSTALL APPROVED: July 14, 2011	SIGNATURE:		
DATE PERMIT VOIDED:	SIGNATURE:		
DATE PERMIT REVOKED:	SIGNATURE:		

PERMIT TO INSTALL

Table of Contents

Section	Page
Alphabetical Listing of Common Abbreviations / Acronyms	2
General Conditions	3
Special Conditions	5
Emission Unit Summary Table	5
Special Conditions for EU-ENGINE-05	6
Flexible Group Summary Table	8
Special Conditions for FG-ENGINES	9

Common Abbreviations / Acronyms

Common Acronyms			Pollutant/Measurement Abbreviations		
AQD	Air Quality Division	BTU	British Thermal Unit		
ANSI	American National Standards Institute	°C	Degrees Celsius		
BACT	Best Available Control Technology	co	Carbon Monoxide		
CAA	Clean Air Act	dscf	Dry standard cubic foot		
CEM	Continuous Emission Monitoring	dscm	Dry standard cubic meter		
CFR	Code of Federal Regulations	°F	Degrees Fahrenheit		
СОМ	Continuous Opacity Monitoring	gr	Grains		
EPA	Environmental Protection Agency	Hg	Mercury		
EU	Emission Unit	hr	Hour		
FG	Flexible Group	H ₂ S	Hydrogen Sulfide		
GACS	Gallon of Applied Coating Solids	hp	Horsepower		
GC	General Condition	lb	Pound		
HAP	Hazardous Air Pollutant	m	Meter		
HVLP	High Volume Low Pressure *	mg	Milligram		
ID	Identification	mm	Millimeter		
LAER	Lowest Achievable Emission Rate	MM	Million		
MACT	Maximum Achievable Control Technology	MW	Megawatts		
MAERS	Michigan Air Emissions Reporting System	ng	Nanogram		
MAP	Malfunction Abatement Plan	NO_x	Oxides of Nitrogen		
MDEQ	Michigan Department of Environmental Quality (Department)	PM	Particulate Matter		
MIOSHA	Michigan Occupational Safety & Health Administration	PM10	PM less than or equal to 10 microns diameter		
MSDS	Material Safety Data Sheet	PM2.5	PM less than or equal 2.5 microns diameter		
NESHAP	National Emission Standard for Hazardous Air Pollutants	pph	Pound per hour		
NSPS	New Source Performance Standards	ppm	Parts per million		
NSR	New Source Review	ppmv	Parts per million by volume		
PS	Performance Specification	ppmw	Parts per million by weight		
PSD	Prevention of Significant Deterioration	psia	Pounds per square inch absolute		
PTE	Permanent Total Enclosure	psig	Pounds per square inch gauge		
PTI	Permit to Install	scf	Standard cubic feet		
RACT	Reasonably Available Control Technology	sec	Seconds		
ROP	Renewable Operating Permit	SO ₂	Sulfur Dioxide		
SC	Special Condition	THC	Total Hydrocarbons		
SCR	Selective Catalytic Reduction	tpy	Tons per year		
SRN	State Registration Number	μg	Microgram		
TAC	Toxic Air Contaminant	VOC	Volatile Organic Compounds		
TEQ	Toxicity Equivalence Quotient	yr	Year		
VE	Visible Emissions				

^{*} For High Volume Low Pressure (HVLP) applicators, the pressure measured at the HVLP gun air cap shall not exceed ten (10) pounds per square inch gauge (psig).

GENERAL CONDITIONS

- 1. The process or process equipment covered by this permit shall not be reconstructed, relocated, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule. (R 336.1201(1))
- 2. If the installation, construction, reconstruction, relocation, or modification of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the permittee or the designated authorized agent shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909-7760, if it is decided not to pursue the installation, construction, reconstruction, relocation, or modification of the equipment allowed by this Permit to Install. (R 336.1201(4))
- 3. If this Permit to Install is issued for a process or process equipment located at a stationary source that is not subject to the Renewable Operating Permit program requirements pursuant to R 336.1210, operation of the process or process equipment is allowed by this permit if the equipment performs in accordance with the terms and conditions of this Permit to Install. (R 336.1201(6)(b))
- 4. The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Department's rules or the Clean Air Act. (R 336.1201(8), Section 5510 of Act 451, PA 1994)
- 5. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to R 336.1219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required by subrules (1)(a), (b), and (c) of R 336.1219 and shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environmental Quality. (R 336.1219)
- 6. Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property. (R 336.1901)
- 7. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the Department. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the Department within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal condition or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5). (R 336.1912)
- 8. Approval of this permit does not exempt the permittee from complying with any future applicable requirements which may be promulgated under Part 55 of 1994 PA 451, as amended or the Federal Clean Air Act.
- 9. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
- 10. Operation of this equipment may be subject to other requirements of Part 55 of 1994 PA 451, as amended and the rules promulgated thereunder.

- 11. Except as provided in subrules (2) and (3) or unless the special conditions of the Permit to Install include an alternate opacity limit established pursuant to subrule (4) of R 336.1301, the permittee shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of density greater than the most stringent of the following. The grading of visible emissions shall be determined in accordance with R 336.1303. (R 336.1301)
 - a) A six-minute average of 20 percent opacity, except for one six-minute average per hour of not more than 27 percent opacity.
 - b) A visible emission limit specified by an applicable federal new source performance standard.
 - c) A visible emission limit specified as a condition of this Permit to Install.
- 12. Collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in R 336.1370(2). (R 336.1370)
- 13. The Department may require the permittee to conduct acceptable performance tests, at the permittee's expense, in accordance with R 336.2001 and R 336.2003, under any of the conditions listed in R 336.2001. (R 336.2001)

SPECIAL CONDITIONS

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Process Equipment & Control Devices)	Installation Date / Modification Date	Flexible Group ID
EU-ENGINE-01	Diesel-fired Emergency Backup Generator No. 1: Location: Building No. 1035 Engine Make: Detroit Diesel Engine Model: 16V-149TIB Manufacturing Year: 1994 Rated Output (electrical): 1,745 kWe Rated Engine Power at 100% Load: 2,340 BHP Permitted Capacity: 75% of Maximum Load	4/10/1995	FG-ENGINES
EU-ENGINE-02	Diesel-fired Emergency Backup Generator No. 2: Location: Building No. 1035 Engine Make: Detroit Diesel Engine Model: 16V-149TIB Manufacturing Year: 1994 Rated Output (electrical): 1,745 kWe Rated Engine Power at 100% Load: 2,340 BHP Permitted Capacity: 75% of Maximum Load	4/10/1995	FG-ENGINES
EU-ENGINE-03	Diesel-fired Emergency Backup Generator No. 3: Location: Building No. 1035 Engine Make: Detroit Diesel Engine Model: 16V-149TIB Manufacturing Year: 1994 Rated Output (electrical): 1,745 kWe Rated Engine Power at 100% Load: 2,340 BHP Permitted Capacity: 75% of Maximum Load	4/10/1995	FG-ENGINES
EU-ENGINE-04	Diesel-fired Emergency Backup Generator No. 4: Location: Building No. 1035 Engine Make: Detroit Diesel Engine Model: 16V-149TIB Manufacturing Year: 1994 Rated Output (electrical): 1,745 kWe Rated Engine Power at 100% Load: 2,340 BHP Permitted Capacity: 75% of Maximum Load	4/10/1995	FG-ENGINES
EU-ENGINE-05	Diesel-fired Emergency Backup Generator No. 5: Location: Building No. 1035 Engine Make: Detroit Diesel Engine Model: 12V4000G43 Manufacturing Year: 2010 Rated Output (electrical): 1500 kWe Permitted Capacity: 100% of Maximum Load	3/26/2011	N/A

Changes to the equipment described in this table are subject to the requirements of R 336.1201, except as allowed by R 336.1278 to R 336.1290.

The following conditions apply to: EU-ENGINE-05

<u>DESCRIPTION</u>: A 1,500-kw diesel-fueled emergency backup generator located at Building No. 1035.

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT: None

I. EMISSION LIMITS

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1. NO _x	5.2 tpy	12-month rolling time period as determined at the end of each calendar month	EU-ENGINE-05	SC VI.3	R 336.1205, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)

The NO_x limit is based on emission factors of 2.42E-01 lbs NO_x per gallon of diesel fuel used in EU-ENGINE-05.

II. MATERIAL LIMITS

- 1. The diesel fuel used in EU-ENGINE-05 shall meet the requirements of 40 CFR 80.510 (b) with the maximum sulfur content of the fuel oil not to exceed 15 ppm (0.0015 per cent) by weight. (R 336.1205, 40 CFR 60.4207 (b), 40 CFR 80.510(b))
- 2. The diesel fuel use for EU-ENGINE-05 shall not exceed 42,976 gallons per 12-month rolling time period as determined at the end of each calendar month. (R 336.1205, R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))

III. PROCESS/OPERATIONAL RESTRICTIONS

- 1. The permittee shall install and operate EU-ENGINE-05 in accordance with the manufacture's specifications. (40 CFR Part 60 Subpart IIII)
- 2. The permittee shall comply with all provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60 Subparts A and IIII, as they apply to EU-ENGINE-05. (40 CFR Part 60 Subparts A & IIII)
- 3. The permittee shall not exceed 100 hours per 12-month rolling time period for maintenance checks and readiness testing. (Subpart IIII, § 60.4211(e))

IV. DESIGN/EQUIPMENT PARAMETERS

1. The permittee shall equip and maintain EU-ENGINE-05 with non-resettable hours meter to track its operating hours. (R 336.1205, R 336.1224, R 336.1225, 40 CFR 60.4209(a))

V. TESTING/SAMPLING

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years, unless otherwise indicated. (R 336.1201(3))

- 1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition. (R 336.1205, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))
- 2. The permittee shall monitor and record in a satisfactory manner the diesel fuel usage rate for EU-ENGINE-05 on a monthly and 12-month rolling time period basis. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))
- 3. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period NO_x emission calculation records for EU-ENGINE-05. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))
- 4. The permittee shall keep separate records of the sulfur content calculations for EU-ENGINE-05, in percent by weight, on an annual average, based on fuel analysis data. Alternately, the permittee shall keep, for EACH fuel shipment delivery, a statement from the fuel supplier indicating that the diesel fuel sulfur content is 15 ppm or less, by weight. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, 40 CFR Part 72.7, 40 CFR 80.510(a), 40 CFR 80.510(b))
- 5. The permittee shall keep, for the life of the engine, the manufacture certification documentation indicating that EU-ENGINE-05 meets the applicable emission limitations contained in the federal Standards of Performance for New Stationary Sources 40 CFR Part 60 Subpart IIII. The permittee shall keep all records on file and make them available to the Department upon request. (40 CFR 60.4211(b) (3))
- 6. The permittee shall monitor the hours of operation of EU-ENGINE-05 and the reason it was in operation during that time, on a monthly and 12-month rolling basis, in a manner that is acceptable to the District Supervisor, Air Quality Division. (R 336.1205(1)(a) and (3), 40 CFR Part 60, Subpart IIII, § 60.4214)

VII. REPORTING

N/A

VIII. STACK/VENT RESTRICTIONS

The exhaust gases from the stack listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter/ Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV-ENGINE-05	18	24	R 336.1225, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)

FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FG-ENGINES	Four diesel-fired emergency back-up generators located at Building 1035, each with the following specifications:	EU-ENGINE-01, EU-ENGINE-02, EU-ENGINE-03, EU-ENGINE-04
	Engine Make: Detroit Diesel Engine Model: 16V-149TIB Manufacturing Year: 1994 Rated Output (electrical): 1,745 kWe Rated Engine Power at 100% Load: 2,340 BHP Permitted Capacity: 75% of Maximum Load	

The following conditions apply to: FG-ENGINES

DESCRIPTION: Four diesel-fired emergency back-up generators located at Building 1035.

Emission Units: EU-ENGINE1, EU-ENGINE2, EU-ENGINE3, EU-ENGINE4

POLLUTION CONTROL EQUIPMENT: N/A

I. <u>EMISSION LIMITS</u>

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1. Opacity	10 percent	Test protocol will specify averaging time	Each Engine (EU-ENGINE-01, EU-ENGINE-02, EU-ENGINE-03, EU-ENGINE-04)	GC 13	R 336.1301(1)(c)
2. NO _x	42.8 pph	Test protocol will specify averaging time	Each Engine (EU-ENGINE-01, EU-ENGINE-02, EU-ENGINE-03, EU-ENGINE-04)	GC 13	R 336.1205, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)
3. NO _x	171.2 pph	Test protocol will specify averaging time	FG-ENGINES	GC 13	R 336.1205, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)
4. SO ₂	0.06 lbs/MM Btu heat input	Test protocol will specify averaging time	Each Engine (EU-ENGINE-01, EU-ENGINE-02, EU-ENGINE-03, EU-ENGINE-04)	GC 13	R 336.1401

II. MATERIAL LIMITS

1. The diesel fuel use for each engine of the FG-ENGINES shall not exceed 83.5 gallons per hour. (R 336.1205(1)(a), R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))

III. PROCESS/OPERATIONAL RESTRICTIONS

1. The permittee shall not operate each engine of FG-ENGINES for more than 387 hours per 12-month rolling time period as determined at the end of each calendar month. (R 336.1205, R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))

IV. <u>DESIGN/EQUIPMENT PARAMETERS</u>

N/A

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

 Upon request from the District Supervisor, the permittee shall verify NO_X emission rates from each engine of the FG-ENGINES, by testing at owner's expense, in accordance with Department requirements. No less than 60 days prior to testing, the permittee must submit a complete stack-testing plan to the AQD. The AQD must approve the final plan prior to testing. Verification of emission rates includes the submittal of a complete report of the test results to the AQD within 60 days following the last date of the test. (R 336.2001, R 336.2003, R 336.2004)

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition.(R 336.1205, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))
- 2. The permittee shall keep records of the sulfur content, in percent by weight on a supplier shipment basis (for each delivery). The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1401)
- 3. The permittee shall monitor and record in a satisfactory manner the diesel usage rate for each engine of the FG-ENGINES on a gallons per hour basis. (R 336.1205(1)(a), R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))
- 4. The permittee shall monitor and record in a satisfactory manner the hours of operation for each engine of the FG-ENGINES on a monthly and 12-month rolling time period basis. (R 336.1205, R 336.1205, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))

VII. REPORTING

NA

VIII. STACK/VENT RESTRICTIONS

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV-ENGINE-01	18	24	R 336.1225, R 336.1901, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)
2. SV-ENGINE-02	18	24	R 336.1225, R 336.1901, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)
3. SV-ENGINE-03	18	24	R 336.1225, R 336.1901, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)
4. SV-ENGINE-04	18	24	R 336.1225, R 336.1901, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)

IX. OTHER REQUIREMENTS

N/A

Footnotes: ¹This condition is state only enforceable and was established pursuant to Rule 201(1)(b).