MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY DIVISION

March 4, 2014

PERMIT TO INSTALL 5-14

ISSUED TO
Ferris State University

LOCATED AT 625 South Warren Avenue Big Rapids, Michigan

IN THE COUNTY OF Mecosta

FRIS PENINSTIT

STATE REGISTRATION NUMBER K2155

The Air Quality Division has approved this Permit to Install, pursuant to the delegation of authority from the Michigan Department of Environmental Quality. This permit is hereby issued in accordance with and subject to Section 5505(1) of Article II, Chapter I, Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. Pursuant to Air Pollution Control Rule 336.1201(1), this permit constitutes the permittee's authority to install the identified emission unit(s) in accordance with all administrative rules of the Department and the attached conditions. Operation of the emission unit(s) identified in this Permit to Install is allowed pursuant to Rule 336.1201(6).

DATE OF RECEIPT OF ALL INFORMATION REQUIRED BY RULE 203: January 30, 2014				
DATE PERMIT TO INSTALL APPROVED: March 4, 2014	SIGNATURE:			
DATE PERMIT VOIDED:	SIGNATURE:			
DATE PERMIT REVOKED:	SIGNATURE:			

PERMIT TO INSTALL

Table of Contents

Section	Page
Alphabetical Listing of Common Abbreviations / Acronyms	2
General Conditions	3
Special Conditions	5
Emission Unit Summary Table	5
Special Conditions for EU-INCINERATOR	6
Special Conditions for EU-COGEN	8
Special Conditions for EU-BOILER	11
Flexible Group Summary Table	13
Special Conditions for FGFACILITY	13
Appendix A: Incinerator Operation and Maintenance Guidelines	16
Appendix B: Example Calculations for GHGs	16

Common Abbreviations / Acronyms

	Common Acronyms		collutant / Measurement Abbreviations
AQD	Air Quality Division	BTU	British Thermal Unit
BACT	Best Available Control Technology	°C	Degrees Celsius
CAA	Clean Air Act	co	Carbon Monoxide
CEM	Continuous Emission Monitoring	dscf	Dry standard cubic foot
CFR	Code of Federal Regulations	dscm	Dry standard cubic meter
CO ₂ e	Carbon Dioxide Equivalent	°F	Degrees Fahrenheit
COM	Continuous Opacity Monitoring	gr	Grains
EPA	Environmental Protection Agency	Hg	Mercury
EU	Emission Unit	hr	Hour
FG	Flexible Group	H ₂ S	Hydrogen Sulfide
GACS	Gallon of Applied Coating Solids	hp	Horsepower
GC	General Condition	lb	Pound
GHGs	Greenhouse Gases	kW	Kilowatt
HAP	Hazardous Air Pollutant	m	Meter
HVLP	High Volume Low Pressure *	mg	Milligram
ID	Identification	mm	Millimeter
LAER	Lowest Achievable Emission Rate	MM	Million
MACT	Maximum Achievable Control Technology	MW	Megawatts
MAERS	Michigan Air Emissions Reporting System	ng	Nanogram
MAP	Malfunction Abatement Plan	NO _x	Oxides of Nitrogen
MDEQ	Michigan Department of Environmental Quality (Department)	PM	Particulate Matter
MSDS	Material Safety Data Sheet	PM10	PM with aerodynamic diameter ≤10 microns
NESHAP	National Emission Standard for Hazardous Air Pollutants	PM2.5	PM with aerodynamic diameter ≤ 2.5 microns
NSPS	New Source Performance Standards	pph	Pounds per hour
NSR	New Source Review	ppm	Parts per million
PS	Performance Specification	ppmv	Parts per million by volume
PSD	Prevention of Significant Deterioration	ppmw	Parts per million by weight
PTE	Permanent Total Enclosure	psia	Pounds per square inch absolute
PTI	Permit to Install	psig	Pounds per square inch gauge
RACT	Reasonably Available Control Technology	scf	Standard cubic feet
ROP	Renewable Operating Permit	sec	Seconds
SC	Special Condition	SO ₂	Sulfur Dioxide
SCR	Selective Catalytic Reduction	THC	Total Hydrocarbons
SRN	State Registration Number	tpy	Tons per year
TAC	Toxic Air Contaminant	μg	Microgram
TEQ	Toxicity Equivalence Quotient	VOC	Volatile Organic Compound
VE	Visible Emissions	yr	Year

^{*} For High Volume Low Pressure (HVLP) applicators, the pressure measured at the HVLP gun air cap shall not exceed ten (10) pounds per square inch gauge (psig).

GENERAL CONDITIONS

- 1. The process or process equipment covered by this permit shall not be reconstructed, relocated, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule. (R 336.1201(1))
- 2. If the installation, construction, reconstruction, relocation, or modification of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the permittee or the designated authorized agent shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909-7760, if it is decided not to pursue the installation, construction, reconstruction, relocation, or modification of the equipment allowed by this Permit to Install. (R 336.1201(4))
- 3. If this Permit to Install is issued for a process or process equipment located at a stationary source that is not subject to the Renewable Operating Permit program requirements pursuant to R 336.1210, operation of the process or process equipment is allowed by this permit if the equipment performs in accordance with the terms and conditions of this Permit to Install. (R 336.1201(6)(b))
- 4. The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Department's rules or the Clean Air Act. (R 336.1201(8), Section 5510 of Act 451, PA 1994)
- 5. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to R 336.1219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required by subrules (1)(a), (b), and (c) of R 336.1219 and shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environmental Quality. (R 336.1219)
- 6. Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property. (R 336.1901)
- 7. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the Department. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the Department within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal condition or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5). (R 336.1912)
- 8. Approval of this permit does not exempt the permittee from complying with any future applicable requirements which may be promulgated under Part 55 of 1994 PA 451, as amended or the Federal Clean Air Act.
- 9. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
- 10. Operation of this equipment may be subject to other requirements of Part 55 of 1994 PA 451, as amended and the rules promulgated thereunder.

- 11. Except as provided in subrules (2) and (3) or unless the special conditions of the Permit to Install include an alternate opacity limit established pursuant to subrule (4) of R 336.1301, the permittee shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of density greater than the most stringent of the following. The grading of visible emissions shall be determined in accordance with R 336.1303. (R 336.1301)
 - a) A six-minute average of 20 percent opacity, except for one six-minute average per hour of not more than 27 percent opacity.
 - b) A visible emission limit specified by an applicable federal new source performance standard.
 - c) A visible emission limit specified as a condition of this Permit to Install.
- 12. Collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in R 336.1370(2). (R 336.1370)
- 13. The Department may require the permittee to conduct acceptable performance tests, at the permittee's expense, in accordance with R 336.2001 and R 336.2003, under any of the conditions listed in R 336.2001. (R 336.2001)

SPECIAL CONDITIONS

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Process Equipment & Control Devices)	Installation Date / Modification Date	Flexible Group ID
EU-INCINERATOR	J.A.R. Model MCP60 incinerator to burn pathological waste. Stack ID: SV-INCINERATOR	1985	FGFACILITY
EU-COGEN	A co-generation system consisting of a 1130 KW gas turbine, and a boiler (duct burner) rated at 50,000 pound of steam per hour and a heat input of 45 million Btus per hour. Stack ID: SV-COGEN		FGFACILITY
EU-BOILER	75,000 pound per hour gas/oil-fired boiler. Stack ID: SV-BOILER	1996	FGFACILITY
Changes to the equipm	ent described in this table are subject to the requi	rements of R 336 120	1 except as allowed

Changes to the equipment described in this table are subject to the requirements of R 336.1201, except as allowed by R 336.1278 to R 336.1290.

The following conditions apply to: EU-INCINERATOR

DESCRIPTION: J.A.R. Model MCP60 incinerator to burn pathological waste.

Flexible Group ID: FGFACILITY

POLLUTION CONTROL EQUIPMENT: NA

I. EMISSION LIMITS

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1. PM	0.20 pounds per 1,000 pounds of exhaust gases, corrected to 50% excess air.	Test Protocol	EU-INCINERATOR	GC 13	R 336.1331

II. MATERIAL LIMITS

1. The permittee shall not burn any waste in EU-INCINERATOR other than the following wastes: (40 CFR 60.51c, R 336.1205)

Pathological wastes - As defined in the federal Standards of Performance for New Stationary Sources, 40 CFR 60.51c, pathological waste means waste materials consisting of only human or animal remains, anatomical parts, and/or tissue; the bags/containers used to collect and transport the waste material; and animal bedding.

III. PROCESS/OPERATIONAL RESTRICTIONS

1. The incinerator shall be installed, maintained, and operated in a satisfactory manner to control emissions from EU-INCINERATOR. A list of recommended operating and maintenance procedures is specified in Appendix A. (R 336.1301, R 336.1331, R 336.1910)

IV. DESIGN/EQUIPMENT PARAMETERS

1. The permittee shall not operate EU-INCINERATOR unless the incinerator is equipped with a manual timer switch, with operating instructions, to insure use of the afterburner whenever the incinerator is operated. If it is determined, by the AQD District Supervisor, that such manual timer switch is not being utilized correctly, an automatic afterburner switch shall be required to be installed. (R 336.1301, R 336.1331)

V. <u>TESTING/SAMPLING</u>

Records shall be maintained on file for a period of five years. (R 336.1201(3))

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. All required calculations shall be completed in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any recordkeeping, reporting or notification special condition. **(R 336.1205)**
- 2. The permittee shall keep, in a satisfactory manner, daily records of the time, description and weight of waste combusted in EU-INCINERATOR, as required by SC II.1. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205)

VII. REPORTING

NA

VIII. STACK/VENT RESTRICTIONS

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter/Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV-INCINERATOR	18	58	R 336.1225, 40 CFR 52.21(c) & (d)

IX. OTHER REQUIREMENTS

The following conditions apply to: EU-COGEN

<u>DESCRIPTION</u>: A co-generation system consisting of a 1130 KW gas turbine, and a boiler (duct burner) rated at 50,000 pound of steam per hour and a heat input of 45 million BTUs per hour.

Flexible Group ID: FGFACILITY

POLLUTION CONTROL EQUIPMENT: NA

I. <u>EMISSION LIMITS</u>

	Time Period /					
	Pollutant	Limit	Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1.	NO _x when firing natural gas	85 ppmv ¹	Test Protocol	Turbine portion of EU-COGEN	GC 13, SC V.1, 40 CFR Part 60 Subpart GG, 60.335	R 336.1205(1)(a) & (3), 40 CFR Part 60 Subpart GG, 60.332
2.	NO _x when firing natural gas		Test Protocol	Turbine portion of EU-COGEN	GC 13	R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d)
3	NO _x when firing natural gas	10.64 pph	Test Protocol	Combined turbine and duct burner portions of EU-COGEN	GC 13	R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d)
4.	NO _x when firing No. 2 fuel oil	97 ppmv ¹	Test Protocol	Turbine portion of EU-COGEN	GC 13, SC V.1, 40 CFR Part 60 Subpart GG, 60.335	R 336.1205(1)(a) & (3), 40 CFR Part 60 Subpart GG, 60.332
5.	NO _x when firing No. 2 fuel oil	13.52 pph	Test Protocol	Combined turbine and duct burner portions of EU-COGEN	GC 13	R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d)
6.	SO ₂ when firing No. 2 fuel oil	64 ppmv ¹	Test Protocol	Turbine portion of EU-COGEN	GC 13, SC V.1, 40 CFR Part 60 Subpart GG, 60.335	R 336.1205(1)(a) & (3), 40 CFR Part 60 Subpart GG, 60.332
	SO ₂ when firing No. 2 fuel oil		Test Protocol	Combined turbine and duct burner portions of EU-COGEN	GC 13	R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d)
	SO ₂ when firing No. 2 fuel oil	,		Combined turbine and duct burner portions of EU-COGEN	SC 2.4, SC VI.4	R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d)
9.	CO when firing natural gas or No. 2 fuel oil	3.74 pph	Test Protocol	Combined turbine and duct burner portions of EU-COGEN	GC 13	R 336.1205(1)(a) & (3)

ppmv = parts per million by volume at 15 percent oxygen and on a dry gas basis.

Based on an emission rate of 0.10 pounds per million Blus heat input.

Based on an emission rate of 0.42 pounds per million Btus heat input.

Based on an emission rate of 0.06 pounds per million Btus heat input.

II. MATERIAL LIMITS

- 1. The permittee shall only burn pipeline quality natural gas or No. 2 fuel oil in EU-COGEN. (R 336.1205, R 336.1224, 40 CFR 52.21(c) & (d))
- 2. The sulfur content of all No. 2 fuel oil fired in EU-COGEN shall not exceed 0.4 percent by weight. (R 336.1224, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subparts GG, 60.333(b))
- 3. The permittee shall not fire more than 74,000 pounds per calendar day of No. 2 fuel oil in EU-COGEN. (R 336.1205, R 336.1224, 40 CFR 52.21(c) & (d))

III. PROCESS/OPERATIONAL RESTRICTIONS

1. The permittee shall comply with all provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60 Subparts A and GG, as they apply to the turbine portion of EU-COGEN. (40 CFR Part 60 Subparts A and GG)

IV. DESIGN/EQUIPMENT PARAMETERS

1. The permittee shall not fire any fuel in the duct burner unless the turbine portion of EU-COGEN is operating. (R 336.1205(a) and (3), R 336.2803, R 336.2804, 40 CFR 52.21(c) and (d))

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. The permittee shall monitor the sulfur content in the No. 2 fuel oil in accordance with 40 CFR 60.334(h). Sulfur content monitoring will be used to determine compliance with SC II.2. (R 336.1224, 40 CFR 52.21(c) & (d), 40 CFR 60.334 and 60.335)
- 2. The permittee shall monitor the nitrogen and sulfur content in the fuels in accordance with 40 CFR 60.335(d) and (e) or as described in an approved Custom Fuel Monitoring Plan (CFMP). If the permittee develops a CFMP, it shall be submitted within 90 days of permit issuance, and shall be implemented and maintained. The permittee shall submit the CFMP and any amendments to the CFMP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the CFMP or amended CFMP shall be considered approved. (40 CFR 60.334 and 60.335)
- 3. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any recordkeeping, reporting or notification special condition. (R 336.1205, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart GG)
- 4. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period natural gas use and No. 2 fuel oil use records for EU-COGEN. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart GG)

- 5. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period NO_x emission calculation records for each fuel fired in the turbine and duct burner portions of EU-COGEN. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, R 336.2803, R 336.2804, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart GG, 60.332)
- 6. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period SO_2 emission calculation records for No. 2 fuel oil fired in the turbine and duct burner portions of EU-COGEN. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart GG, 60.332)
- 7. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period CO emission calculation records for each fuel fired in the turbine and duct burner portions of EU-COGEN. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205)
- 8. The permittee shall keep, in a satisfactory manner, a complete copy of each No. 2 fuel oil analysis, as supplied by the oil vendor. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, 40 CFR 52.21(c) & (d))

VII. REPORTING

NA

VIII. STACK/VENT RESTRICTIONS

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter/Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV-COGEN	36	53	R 336.1225, 40 CFR 52.21(c) & (d)

IX. OTHER REQUIREMENTS

The following conditions apply to: EU-BOILER

DESCRIPTION: 75,000 pound per hour gas/oil-fired boiler.

Flexible Group ID: FGFACILITY

POLLUTION CONTROL EQUIPMENT: NA

I. EMISSION LIMITS

P	ollutant	Limit	Time Period / Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1.	NO _x	8.96 pph	Test Protocol	EU-BOILER		R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d)
2.	SO ₂	33.91 pph	Test Protocol	EU-BOILER		R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d)
3.	SO ₂	34.3 tpy	12-month rolling time period as determined at the end of each calendar month	EU-BOILER	SC II.3, SC VI.4	R 336.1205(1)(a) & (3)
4.	СО	13.44 pph	Test Protocol	EU-BOILER	GC 13	R 336.1205(1)(a) & (3)

5. Visible emissions from EU-BOILER shall not exceed 20 percent opacity except as specified in the federal Standards of Performance for New Stationary Sources, 40 CFR Part 60 Subparts A and Dc. (40 CFR Part 60 Subparts A & Dc)

II. MATERIAL LIMITS

- 1. The permittee shall only burn pipeline quality natural gas or No. 2 fuel oil in EU-BOILER. (R 336.1205, R 336.1224, R 336.1225, 40 CFR 52.21(c) & (d))
- 2. The sulfur content of all No. 2 fuel oil fired in EU-BOILER shall not exceed 0.4 percent by weight. (R 336.1224, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart Dc, 60.42c(d))
- 3. The permittee shall not fire more than 1,200,000 gallons per 12-month rolling time period as determined at the end of each calendar month of No. 2 fuel oil in EU-BOILER. (R 336.1205, R 336.1224)

III. PROCESS/OPERATIONAL RESTRICTIONS

1. The permittee shall comply with all provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60 Subparts A and Dc, as they apply to EU-BOILER. (40 CFR Part 60 Subparts A and Dc)

IV. DESIGN/EQUIPMENT PARAMETERS

NA

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any recordkeeping, reporting or notification special condition. (R 336.1205, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart Dc)
- 2. The permittee shall keep, in a satisfactory manner, daily, monthly and 12-month rolling time period natural gas use and No. 2 fuel oil use records for EU-BOILER. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart Dc)
- 3. The permittee shall keep, in a satisfactory manner, daily, monthly and 12-month rolling time period NO_x emission calculation records for each fuel fired in EU-BOILER. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart Dc)
- 4. The permittee shall keep, in a satisfactory manner, daily, monthly and 12-month rolling time period SO₂ emission calculation records for each fuel fired in EU-BOILER. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205, 40 CFR 52.21(c) & (d))
- 5. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period CO emission calculation records for each fuel fired in EU-BOILER. The permittee shall keep all records on file and make them available to the Department upon request. (R 336.1205)
- 6. The permittee shall verify the sulfur content of the No. 2 fuel oil for each new shipment of oil in accordance with 40 CFR Part 60 Subpart Dc, 60.42c(h). The verification shall be submitted to the AQD District Supervisor in an acceptable format within 30 days following the end of the quarter in which the data were collected. (R 336.1205, 40 CFR 52.21(c) & (d), 40 CFR Part 60 Subpart Dc, 60.42c(h))

VII. REPORTING

NA

VIII. STACK/VENT RESTRICTIONS

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter/Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV-BOILER	42	53	R 336.1225, 40 CFR 52.21(c) & (d)

IX. OTHER REQUIREMENTS

FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGFACILITY	All process equipment source-wide including	NA
	equipment covered by other permits, grandfathered	
	equipment and exempt equipment.	

The following conditions apply Source-Wide to: FGFACILITY

I. <u>EMISSION LIMITS</u>

	Pollutant	Limit	Time Period / Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1.	NO _x	Less than 90.0 tpy	12-month rolling time period as determined at the end of each calendar month	FGFACILITY	SC II.1, SC VI.2, SC VI.3	R 336.1205(3)
2.	SO ₂	Less than 90.0 tpy	12-month rolling time period as determined at the end of each calendar month	FGFACILITY	SC II.1, SC VI.2, SC VI.3	R 336.1205(3)
3.	Each Individual HAP	Less than 9.0 tpy	12-month rolling time period as determined at the end of each calendar month	FGFACILITY	SC VI.4	R 336.1205(3)
4.	Aggregate HAPs	Less than 22.5 tpy	12-month rolling time period as determined at the end of each calendar month	FGFACILITY	SC VI.4	R 336.1205(3)
5.	CO ₂ e	89,000 tpy	12-month rolling time period as determined at the end of each calendar month.	FGFACILITY	SC II.1, SC VI.2 - SC VI.5 and Appendix A	R 336.1205(3)

II. MATERIAL LIMITS

1. The permittee shall not use more than 3.165 million gallons of fuel oil per 12-month rolling time period in FGFACILITY, nor more than 1,479.6 million cubic feet of natural gas per 12-month rolling time period, or the amount as determined from the following equation:

Foil = $3.165 \times (1 - Fgas/1,479.6)$

Where:

Foil = The amount of fuel oil used, in million gallons, based upon a 12-month rolling time period, as determined at the end of each calendar month.

Fgas = The amount of natural gas used, in million cubic feet, based upon a 12-month rolling time period, as determined at the end of each calendar month.

(R 336.1205(3))

III. PROCESS/OPERATIONAL RESTRICTIONS

NA

IV. <u>DESIGN/EQUIPMENT PARAMETERS</u>

NA

V. TESTING/SAMPLING

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor and make them available by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any recordkeeping, reporting or notification special condition. (R 336.1205(3))
- 2. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period fuel use records for FGFACILITY. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(3))
- 3. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period NO_x and SO_2 emission calculation records for FGFACILITY, as required by SC I.1 and I.2. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(3))
- 4. The permittee shall keep, in a satisfactory manner, individual and aggregate HAP emission calculations determining the cumulative emission rate of each during the first 12 months and the annual emission rate of each thereafter, in tons per 12-month rolling time period as determined at the end of each calendar month, as required by SC I.3 and I.4. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(3))

5. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period CO₂e emission calculation records for FGFACILITY, as required by SC I.5 and Appendix A. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(3))

VII. REPORTING

NA

VIII. STACK/VENT RESTRICTIONS

NA

IX. OTHER REQUIREMENTS

 $\mathsf{N}\mathsf{A}$

APPENDIX A: Incinerator Operation and Maintenance Guidelines

- 1. Designate a trained operator for your unit and make that person responsible for compliance with the air pollution control requirements.
- 2. Grates should be cleaned before each day's operation (more often if necessary) and the ashes disposed of properly.
- 3. Preheat the unit with the burners (not with waste) for at least 15 minutes.
- 4. Do not overload. Stay within the given loading rates and follow manufacturer's instructions.
- 5. Schedule charges to minimize opening the charging door as infrequently as possible. Opening the charging door lets cold air in and quenches the fire causing smoke.
- 6. Burn only the type of wastes that your incinerator has been approved to burn. Follow the manufacturer's instructions to maximize the efficiency of the unit, and to properly burn the waste(s).
- 7. Keep the combustion air adjusted according to the manufacturer's instructions.
- 8. Observe the stack frequently and adjust your operation as necessary to eliminate smoke and fly ash.
- 9. A copy of the manufacturer's manual and this Guideline should be posted near your incinerator.
- 10. Make quarterly inspections to check and service all of the equipment. If you do not have a qualified person available for proper inspections, a service contract with a reputable manufacturer is advisable.

APPENDIX B: Example Calculations for GHGs

For limits on Fuel usage:

Total natural gas consumed for one year = assumed value of 596.4 MMcf

Emission factors from 40 CFR Part 98, Table C-1.

CO_2 , CH_4 , and N_2O (tons/yr) = fuel usage x heat value x emission factor x 1 ton/2000 lbs

 $CO_2 = (596.4 \text{ MMcf}) \times (1028 \text{ Btu/cf}) \times (116.89 \text{ lbs } CO_2/\text{MMbtu}) \times (1 \text{ ton/2000 lbs}) = 35.832.58 \text{ tons/yr}$

 $CH_4 = (596.4 \text{ MMcf}) \times (1028 \text{ Btu/cf}) \times (0.0022 \text{ lbs } CH_4/\text{MMbtu}) \times (1 \text{ ton/2000 lbs}) = 0.67 \text{ tons/yr}$

 $N_2O = (596.4 \text{ MMcf}) \times (1028 \text{ Btu/cf}) \times (0.00022 \text{ lbs } N_2O/\text{MMBtu}) \times (1/2000) = 0.07 \text{ tons/yr}$

Global Warming Potential from 40 CFR Part 98, Table A-1

Actual CO₂e = GHG emission rate x Global Warming Potential

PTE $CO_2e = CO_2(35.832.58 \times 1) + CH_4(0.67 \times 21) + N_2O(0.07 \times 310) = 35.868.35 \text{ tons/yr}$