MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY DIVISION

August 21, 2017

PERMIT TO INSTALL 112-17

ISSUED TO Beaumont Information Technology Center

> LOCATED AT 1350 Stephenson Highway Troy, Michigan

IN THE COUNTY OF Oakland

STATE REGISTRATION NUMBER P0243

The Air Quality Division has approved this Permit to Install, pursuant to the delegation of authority from the Michigan Department of Environmental Quality. This permit is hereby issued in accordance with and subject to Section 5505(1) of Article II, Chapter I, Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. Pursuant to Air Pollution Control Rule 336.1201(1), this permit constitutes the permittee's authority to install the identified emission unit(s) in accordance with all administrative rules of the Department and the attached conditions. Operation of the emission unit(s) identified in this Permit to Install is allowed pursuant to Rule 336.1201(6).

DATE OF RECEIPT OF ALL INFORMATION REQUIRED BY RULE 203: July 25, 2017

DATE PERMIT TO INSTALL APPROVED: SIGNATURE: August 21, 2017 SIGNATURE: DATE PERMIT VOIDED: SIGNATURE: DATE PERMIT REVOKED: SIGNATURE:

PERMIT TO INSTALL

Table of Contents

Section	Page
Alphabetical Listing of Common Abbreviations / Acronyms	2
General Conditions	3
Special Conditions	5
Emission Unit Summary Table	5
Special Conditions for EU-GENP	5

Common A	bbreviations /	Acronyms
----------	----------------	----------

Common Acronyms		Pollutant / Measurement Abbreviations		
AQD	Air Quality Division	acfm	Actual cubic feet per minute	
BACT	Best Available Control Technology	BTU	British Thermal Unit	
CAA	Clean Air Act	°C	Degrees Celsius	
CAM	Compliance Assurance Monitoring	со	Carbon Monoxide	
CEM	Continuous Emission Monitoring	CO ₂ e	Carbon Dioxide Equivalent	
CFR	Code of Federal Regulations	dscf	Dry standard cubic foot	
СОМ	Continuous Opacity Monitoring	dscm	Dry standard cubic meter	
Department/	Michigan Department of Environmental	°F	Degrees Fahrenheit	
department	Quality	gr	Grains	
EU	Emission Unit	HAP	Hazardous Air Pollutant	
FG	Flexible Group	Hg	Mercury	
GACS	Gallons of Applied Coating Solids	hr	Hour	
GC	General Condition	HP	Horsepower	
GHGs	Greenhouse Gases	H ₂ S	Hydrogen Sulfide	
HVLP	High Volume Low Pressure*	kW	Kilowatt	
ID	Identification	lb	Pound	
IRSL	Initial Risk Screening Level	m	Meter	
ITSL	Initial Threshold Screening Level	mg	Milligram	
LAER	Lowest Achievable Emission Rate	mm	Millimeter	
MACT	Maximum Achievable Control Technology	MM	Million	
MAERS	Michigan Air Emissions Reporting System	MW	Megawatts	
MAP	Malfunction Abatement Plan	NMOC	Non-methane Organic Compounds	
MDEQ	Michigan Department of Environmental	NOx	Oxides of Nitrogen	
MSDS	Quality	ng PM	Nanogram Particulate Matter	
NA	Material Safety Data Sheet Not Applicable		Particulate Matter equal to or less than 10	
NAAQS	National Ambient Air Quality Standards	PM10	microns in diameter	
NESHAP	National Emission Standard for		Particulate Matter equal to or less than 2.5	
	Hazardous Air Pollutants	PM2.5	microns in diameter	
NSPS	New Source Performance Standards	pph	Pounds per hour	
NSR PS	New Source Review	ppm	Parts per million	
PSD	Performance Specification	ppmv	Parts per million by volume	
PTE	Prevention of Significant Deterioration Permanent Total Enclosure	ppmw	Parts per million by weight	
PTI	Permit to Install	psia	Pounds per square inch absolute	
RACT	Reasonable Available Control	psig	Pounds per square inch gauge	
INAC I	Technology	scf	Standard cubic feet	
ROP	Renewable Operating Permit	sec	Seconds	
SC	Special Condition	SO ₂	Sulfur Dioxide	
SCR	Selective Catalytic Reduction	TAC	Toxic Air Contaminant	
SNCR	Selective Non-Catalytic Reduction	Temp	Temperature	
SRN	State Registration Number	тнс	Total Hydrocarbons	
TEQ	Toxicity Equivalence Quotient	tpy	Tons per year	
USEPA/EPA	United States Environmental Protection	μg	Microgram	
	Agency	μm	Micrometer or Micron	
VE	Visible Emissions	VOC	Volatile Organic Compounds	
		yr	Year	

 yr
 Year

 *For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig.

GENERAL CONDITIONS

- 1. The process or process equipment covered by this permit shall not be reconstructed, relocated, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule. (R 336.1201(1))
- 2. If the installation, construction, reconstruction, relocation, or modification of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the permittee or the designated authorized agent shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909-7760, if it is decided not to pursue the installation, construction, reconstruction, relocation, or modification of the equipment allowed by this Permit to Install. (R 336.1201(4))
- 3. If this Permit to Install is issued for a process or process equipment located at a stationary source that is not subject to the Renewable Operating Permit program requirements pursuant to R 336.1210, operation of the process or process equipment is allowed by this permit if the equipment performs in accordance with the terms and conditions of this Permit to Install. (R 336.1201(6)(b))
- 4. The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Department's rules or the Clean Air Act. (R 336.1201(8), Section 5510 of Act 451, PA 1994)
- 5. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to R 336.1219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required by subrules (1)(a), (b), and (c) of R 336.1219 and shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environmental Quality. (R 336.1219)
- 6. Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property. (R 336.1901)
- 7. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the Department. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the Department within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal condition or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5). **(R 336.1912)**
- 8. Approval of this permit does not exempt the permittee from complying with any future applicable requirements which may be promulgated under Part 55 of 1994 PA 451, as amended or the Federal Clean Air Act.
- 9. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
- 10. Operation of this equipment may be subject to other requirements of Part 55 of 1994 PA 451, as amended and the rules promulgated thereunder.

- 11. Except as provided in subrules (2) and (3) or unless the special conditions of the Permit to Install include an alternate opacity limit established pursuant to subrule (4) of R 336.1301, the permittee shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of density greater than the most stringent of the following. The grading of visible emissions shall be determined in accordance with R 336.1303. (R 336.1301)
 - a) A six-minute average of 20 percent opacity, except for one six-minute average per hour of not more than 27 percent opacity.
 - b) A visible emission limit specified by an applicable federal new source performance standard.
 - c) A visible emission limit specified as a condition of this Permit to Install.
- Collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in R 336.1370(2). (R 336.1370)
- 13. The Department may require the permittee to conduct acceptable performance tests, at the permittee's expense, in accordance with R 336.2001 and R 336.2003, under any of the conditions listed in R 336.2001. (R 336.2001)

SPECIAL CONDITIONS

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Process Equipment & Control Devices)	Installation Date / Modification Date	Flexible Group ID
EU-GENP	A 1,500 kilowatts (kW) emergency generator with a 2,205 horsepower (HP) diesel-fueled engine with a model year of 2014, and a displacement of 3.14 liters/cylinder.	TBD	NA
Changes to the equipment described in this table are subject to the requirements of R 336.1201, except as allowed by R 336.1278 to R 336.1290.			

The following conditions apply to: <u>EU-GENP</u>

DESCRIPTION: A 1,500 kilowatts (kW) emergency generator with a 2,205 horsepower (HP) diesel-fueled engine with a model year of 2014, and a displacement of 3.14 liters/cylinder.

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT: NA

I. EMISSION LIMITS

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1. NMHC ^A + NO _x	6.4 g/kW-hr ^B	Test Protocol*	EU-GENP	SC V.1, SC VI.2, SC VI.3	40 CFR 60.4205(b), 60.4202(a), Table 1 of 40 CFR 89.112
2. CO	3.5 g/kW-hr ^B	Test Protocol*	EU-GENP	SC V.1, SC VI.2, SC VI.3	40 CFR 60.4205(b), 60.4202(a), Table 1 of 40 CFR 89.112
3. PM	0.20 g/kW-hr ^B	Test Protocol*	EU-GENP	SC V.1, SC VI.2, SC VI.3	40 CFR 60.4205(b), 60.4202(a), Table 1 of 40 CFR 89.112

^A NMHC = nonmethane hydrocarbon

^B These emission limits are for certified engines; if testing becomes required to demonstrate compliance, then the tested values must be compared to the Not to Exceed (NTE) requirements determined through 40 CFR 60.4212(c).

*Test Protocol shall determine averaging time.

II. MATERIAL LIMITS

1. The permittee shall burn only diesel fuel in EU-GENP with the maximum sulfur content of 15 ppm (0.0015 percent) by weight, and a minimum Cetane index of 40 or a maximum aromatic content of 35 volume percent. (R 336.1205(1)(a) & (3), 40 CFR 60.4207(b), 40 CFR 80.510(b))

III. PROCESS/OPERATIONAL RESTRICTIONS

- The permittee shall not operate EU-GENP for more than 500 hours per year on a 12-month rolling time period basis as determined at the end of each calendar month. The 500 hours includes the hours for the purpose of necessary maintenance checks and readiness testing as described in SC III.2. (R 336.1205(1)(a) & (3), R 336.1225, R 336.1702(a), 40 CFR 52.21(c) & (d))
- 2. The permittee may operate EU-GENP for no more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. EU-GENP may operate up to 50 hours per calendar year in non-emergency situations, but those 50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing. Except as provided in 40 CFR 60.4211(f)(3)(i), the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or demand response, or to generate income for the permittee to supply non-emergency power as part of a financial arrangement with another entity. (40 CFR 60.4211(f))
- If the permittee purchased a certified engine, according to procedures specified in 40 CFR Part 60 Subpart IIII, for the same model year and maximum engine power, the permittee shall meet the following requirements for EU-GENP:
 - a. Operate and maintain the certified engine and control device according to the manufacturer's emissionrelated written instructions;
 - b. Change only those emission-related settings that are permitted by the manufacturer; and
 - c. Meet the requirements as specified in 40 CFR 89, 94, and/or 1068, as they apply to EU-GENP.

If you do not operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions, the engine may be considered a non-certified engine. (40 CFR 60.4211(a) & (c))

 If the permittee purchased a non-certified engine or a certified engine operating in a non-certified manner, the permittee shall keep a maintenance plan for EU-GENP and shall, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. (40 CFR 60.4211(g)(3))

IV. DESIGN/EQUIPMENT PARAMETERS

- 1. The permittee shall equip and maintain EU-GENP with a non-resettable hours meter to track the operating hours. (R 336.1205(1)(a) & (3), R 336.1225, R 336.1702(a), 40 CFR 52.21(c) & (d), 40 CFR 60.4209(a))
- The maximum rated power output of the generator shall not exceed 1,500 kW and the engine shall not exceed a nameplate capacity of 2,205 HP, as certified by the equipment manufacturer. (R 336.1205(1)(a) & (3), R 336.1225, R 336.1702(a), 40 CFR 52.21(c) & (d), 40 CFR 60.4202, 40 CFR 89.112(a))

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. If EU-GENP is not installed, configured, operated, and maintained according to the manufacturer's emissionrelated written instructions, or the permittee changes emission-related settings in a way that is not permitted by the manufacturer, the permittee must demonstrate compliance as follows:
 - a. Conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.
 - b. If a performance test is required, the performance tests shall be conducted according to 40 CFR 60.4212.
 - c. Conduct subsequent performance testing every 8,760 hours of engine operation or every 3 years, whichever comes first, thereafter to demonstrate compliance with the applicable emission standards.

No less than 30 days prior to testing, a complete test plan shall be submitted to the AQD. Verification of emission rates includes the submittal of a complete report of the test results to the AQD within 60 days following the last date of the test. (40 CFR 60.4211(g)(3), 40 CFR 60.4212)

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the last day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition. (R 336.1205(1)(a) & (3), 40 CFR 52.21(c) & (d))
- 2. The permittee shall keep, in a satisfactory manner, the following records for EU-GENP:
 - a. For a certified engine: The permittee shall keep records of the manufacturer certification documentation.
 - b. For an uncertified engine: The permittee shall keep records of testing required in SC V.1.

The permittee shall keep all records on file and make them available to the Department upon request. (40 CFR 60.4211)

- 3. The permittee shall keep, in a satisfactory manner, the following records of maintenance activity for EU-GENP:
 - a. For a certified engine: The permittee shall keep records of the manufacturer's emission-related written instructions, and records demonstrating that the engine has been maintained according to those instructions, as specified in SC III.3.
 - b. For an uncertified engine: The permittee shall keep records of a maintenance plan, as required by SC III.4, and maintenance activities.

The permittee shall keep all records on file and make them available to the Department upon request. (40 CFR 60.4211)

- 4. The permittee shall monitor and record the total hours of operation and the hours of operation during non-emergencies for EU-GENP, on a monthly and 12-month rolling time period basis, in a manner acceptable to the AQD District Supervisor. The permittee shall document how many hours are spent for emergency operation of EU-GENP, including what classified the operation as emergency. (R 336.1205(1)(a) & (3), 40 CFR 60.4211, 40 CFR 60.4214)
- The permittee shall keep, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for each delivery of diesel fuel oil used in EU-GENP, demonstrating that the fuel meets the requirement of 40 CFR 80.510(b), as specified in SC II.1. The certification or test data shall include the name of the oil supplier or laboratory, the sulfur content, and cetane index or aromatic content of the fuel oil. (R 336.1205(1)(a) & (3), 40 CFR 60.4207(b), 40 CFR 80.510(b))

VII. <u>REPORTING</u>

 The permittee shall submit a notification specifying whether EU-GENP will be operated in a certified or a noncertified manner to the AQD District Supervisor, in writing, within 30 days following the issuance of this PTI. (40 CFR Part 60 Subpart IIII)

VIII. STACK/VENT RESTRICTIONS

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter/Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV-GENP	8	10	R 336.1225, 40 CFR 52.21(c) & (d)

IX. OTHER REQUIREMENTS

- The permittee shall comply with the provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60 Subpart A and Subpart IIII, as they apply to EU-GENP. (40 CFR Part 60 Subparts A & IIII, 40 CFR 63.6590)
- The permittee shall comply with the provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR, Part 63, Subpart A and Subpart ZZZZ, as they apply to EU-GENP, upon startup. (40 CFR Part 63 Subparts A and ZZZZ, 40 CFR 63.6595)

Footnotes:

¹This condition is state only enforceable and was established pursuant to Rule 201(1)(b).