


MICHIGAN DEPARTMENT OF PUBLIC HEALTH
WATER WELL AND PUMP RECORDPERMIT NUMBER

1 LOCATION OF WELL		2 FORMATION DESCRIPTION		3 OWNER OF WELL	
County Lapeer	Township Name Burlington	Fraction NW 1/4 NE 1/4 NW 1/4	Section Number 27	Town Number 10N N/S	Range Number 11E E/W
Distance And Direction From Road Intersection 3/8 mi. E. of Lake Pleasant Rd. on Barnes Rd.		Address Larry Peplinski 4664 Barnes Rd. Clifford, Mi			
Street Address & City of Well Location 4664 Barnes Rd. Clifford,		Address Same As Well Location? ☒ Yes ☐ No			
Locate with "X" in Section Below 		4 WELL DEPTH: 260 FT. Date Completed 12/12/89 ☒ New Well ☐ Replacement Well			
		5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Auger ☐ Jetted ☐			
		6 USE: ☒ Domestic ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat pump ☐ Test Well ☐ Type IIb Public ☐			
		7 CASING: Diameter ☐ Steel ☐ Threaded ☒ Plastic ☐ Welded 5 in. to 118 ft. depth 7 7/8 in. to 118 ft. depth Grouped Drill Hole Diameter in. to ft. depth			
		Height: Above/Below Surface 1 ft. Weight 3.75 lbs./ft. Drive Shoe ☐ Yes ☒ No			
		8 SCREEN: ☒ Not Installed Type _____ Diameter _____ Slot/Gauze _____ Length _____ Set between _____ ft. and _____ ft. FITTINGS: ☐ K-Packer ☐ Lead Packer ☐ Bremer Check ☐ Blank above screen _____ ft. Other _____			
		9 STATIC WATER LEVEL: 56 ft. below land surface ☐ Flow			
		10 PUMPING LEVEL: below land surface 260 ft. after 1 1/2 hrs. pumping at 60 G.P.M. ft. after _____ hrs. pumping at _____ G.P.M.			
		11 WELL HEAD COMPLETION: ☒ Pitless adapter ☐ 12" above grade ☐ Basement offset ☐ Approved pit			
		12 WELL GROUTED? ☐ No ☒ Yes From 0 to 118 ft. ☐ Neat cement ☐ Bentonite ☐ Other thick mud No. of bags of cement _____ Additives _____			
		13 Nearest source of possible contamination Type septic tank Distance 55 ft. Direction SW Well disinfected upon completion? ☒ Yes ☐ No Was old well plugged? ☐ Yes ☒ No			
		14 PUMP: ☐ Not Installed ☐ Pump Installation Only Manufacturer's name X-trol Red Jacket Model number 750N12BC HP 3/4 Volts 220 Length of Drop Pipe 85 ft. capacity 15 G.P.M. TYPE: ☒ Submersible ☐ Jet PRESSURE TANK: Manufacturer's name X-trol Model number 203 Capacity 9 Gallons			
15. Remarks, elevation, source of data, etc.		16. WATER WELL CONTRACTOR'S CERTIFICATION: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Charles R. Wilcox Well Drilling 0377 REGISTERED BUSINESS NAME REGISTRATION NO. Address 3838 N. Lapeer Rd. Lapeer, Signed Charles R. Wilcox Date Dec 12, 1989 AUTHORIZED REPRESENTATIVE			