



**CONTINUOUS EMISSIONS MONITORING SYSTEM  
RELATIVE ACCURACY TEST AUDIT DETERMINATION**

*Performed At*

**USG-Otsego Paper, Inc.  
USG-Otsego Facility  
EUTURBINE1 (North – Unit 24)  
EUTURBINE2 (South – Unit 25)  
Otsego, Michigan**

*Test Dates*

**April 2 and 5, 2024**

*Report No.*

**TRC Environmental Corporation Report 583368A**

*Report Submittal Date*

**May 8, 2024**


TRC Environmental Corporation  
207C Eisenhower Lane South  
Lombard, Illinois 60148  
USA

T (312) 533-2042

## Report Certification

I certify that to the best of my knowledge:

- Testing data and all corresponding information have been checked for accuracy and completeness.
- Sampling and analysis have been conducted in accordance with the approved protocol and applicable reference methods (as applicable).
- All deviations, method modifications, or sampling and analytical anomalies are summarized in the appropriate report narrative(s).



---

Gavin Lewis  
Project Manager

May 8, 2024

Date

TRC was operating in conformance with the requirements of ASTM D7036-04 during this test program.



Jon T. Howard  
TRC Emission Testing Manager



## TABLE OF CONTENTS

1.0 INTRODUCTION .....	4
1.1 Project Contact Information.....	4
2.0 FACILITY DESCRIPTION .....	5
3.0 SUMMARY OF RESULTS.....	5
3.1 CEMS RATA Test Matrix.....	5
3.2 CEMS RATA Results .....	6
4.0 DISCUSSION OF RESULTS .....	7
5.0 TEST PROCEDURES .....	7
5.1 Determination of the Concentration of Gaseous Pollutants.....	7
5.1.1 O <sub>2</sub> Determination by USEPA Method 3A.....	8
5.1.2 NO <sub>x</sub> Determination by USEPA Method 7E.....	8
5.1.3 Determination of F-Factors by USEPA Method 19.....	8
6.0 QUALITY ASSURANCE PROCEDURES.....	8
7.0 TEST RESULTS SUMMARIES.....	10
 <b>APPENDIX</b>	
Part 75 ECMPS Reporting Information.....	18
Qualified Individual Certificate(s).....	20
Continuous Emissions Monitoring System (CEMS) and Plant Operating Data.....	22
Sample Location Information .....	44
Sampling Train Diagram .....	50
Calculation Nomenclature and Formulas.....	51
Processed Field Data Sheets .....	55
Gaseous Calibration Data .....	69
NO <sub>2</sub> -to-NO Conversion Data.....	87
Response Time Data.....	91
Analyzer Interference Data .....	93
Calibration Gas Certification Data.....	95
EGLE Acknowledgement Letter and Test Protocol.....	102

**CONTINUOUS EMISSIONS MONITORING SYSTEM  
RELATIVE ACCURACY TEST AUDIT DETERMINATION**

---

**1.0 INTRODUCTION**

TRC Environmental Corporation (TRC) performed an oxide of nitrogen (NO<sub>x</sub>) and oxygen (O<sub>2</sub>) relative accuracy test audit (RATA) determination of the continuous emission monitoring system (CEMS) associated with the natural gas fired combustion turbines EUTURBINE1 (North-Unit 24) and EUTURBINE2 (South-Unit 25) on April 2 and 5, 2024 at the USG-Otsego Paper, Inc. facility located in Otsego, Michigan. The tests were authorized by and performed for USG-Otsego Paper, Inc.

This test program was performed to demonstrate compliance with Michigan Department of Environmental Quality (MDEQ) Renewable Operating Permit (ROP) No. MI-ROP-A0023-2019b. The test program was conducted according to the TRC Test Protocol 583368 dated February 6, 2024.

**1.1 Project Contact Information**

Participants		
Test Facility	USG-Otsego Paper, Inc. USG-Otsego Facility 320 N. Farmer Street Otsego, Michigan 49078	Franklin Knowles Environmental Compliance Supervisor 269-384-6351 (phone) <a href="mailto:fknowles@usg.com">fknowles@usg.com</a>
Air Emissions Testing Body (AETB)	TRC Environmental Corporation 207C Eisenhower Lane South Lombard, Illinois 60148	Gavin Lewis Project Manager 219-613-0163 (phone) <a href="mailto:glewis@trccompanies.com">glewis@trccompanies.com</a>

The tests were coordinated through Franklin Knowles, Environmental Compliance Supervisor, of Otsego Paper and conducted by Rome Rothgeb, Ryan Novosel and Gavin Lewis of TRC. Documentation of the on-site ASTM D7036-04 Qualified Individual(s) (QI) can be found in the appendix to this report.

Cody Yazzie from the Michigan Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) observed the testing.



## 2.0 FACILITY DESCRIPTION

Otsego Paper, Inc is a subsidiary of the United States Gypsum Company. The facility manufactures gypsum paper.

The Otsego Paper facility produces electricity from two (2) Mars gas turbines. Turbine 1 is a Mars T-15000 gas turbine and Turbine 2 is a Mars T-16000 designated as EUTURBINE1 and EUTURBINE2, with a maximum heat input rate of 141.5 million British thermal unit per hour (MMBtu/hr) on EUTURBINE1 and a maximum heat input rate of 150.8 MMBtu/hr on EUTURBINE2 at low temperature operating conditions as measured on a higher heating value (HHV) basis. Energy is generated at the combustion turbine by drawing in ambient air by means of burning fuel and expanding the hot combustion gases in the turbine. The hot exhaust gases of each turbine are directed to a multi-pressure ABCO heat recovery steam generator (HRSG). There are also natural gas-fired duct burners associated with each HRSG and coupled to a turbine, designated as EUDUCTBURNER1 and EUDUCTBURNER2, respectively.

The facility has one paper machine, No. 1 Paper Machine (EUPAPERMACHINE1), used to produce paper from 100 percent recycle stock and corrugated material. The paper machine has three fourdriniers and is capable of producing a triple ply sheet.

Plant capacity for base load operations is 11 megawatts (MW) for each turbine and 160,000 pounds per hour (lb/hr) of steam for each HRSG.

EUTURBINE1 has a maximum heat input rate of 141.5 MMBtu/hr, and EUTURBINE2 has a maximum heat input rate of 150.8 MMBtu/hr at low temperature operating conditions.

## 3.0 SUMMARY OF RESULTS

### 3.1 CEMS RATA Test Matrix

Location	Parameter	Reference Methods (RM)	No. of Test Runs	Test Run Length (min)
EUTURBINE1 (Unit 24)	NO <sub>x</sub>	7E, 3A	10	21
	O <sub>2</sub>	3A	10	21
EUTURBINE2 (Unit 25)	NO <sub>x</sub>	7E, 3A	10	21
	O <sub>2</sub>	3A	10	21

### 3.2 CEMS RATA Results

EUTURBINE1 (Unit 24)						
Load (MW)	Parameter	Units	Performance Specifications (40CFR75)		CEMS Performance	
			Semi-Annual	Annual	Relative Accuracy	Bias Adjustment Factor
~10.3	NO <sub>x</sub>	lb/MMBtu	7.5% < RA ≤ 10.0%	RA ≤ 7.5%	4.28 %	1.025
Load (MW)	Parameter	Units	Performance Specifications (40CFR60)		CEMS Performance	
			Specification No.	Acceptance Criteria	Relative Accuracy	
~10.3	NO <sub>x</sub>	ppmvd @ 15% O <sub>2</sub>	2	RA ≤ 20%	3.09 %	
	O <sub>2</sub>	%	3	RA ≤ 1.0% difference for %O <sub>2</sub>	0.09 %	

EUTURBINE2 (Unit 25)						
Load (MW)	Parameter	Units	Performance Specifications (40CFR75)		CEMS Performance	
			Semi-Annual	Annual	Relative Accuracy	Bias Adjustment Factor
~11.3	NO <sub>x</sub>	lb/MMBtu	7.5% < RA ≤ 10.0%	RA ≤ 7.5%	4.48 %	1.043
Load (MW)	Parameter	Units	Performance Specifications (40CFR60)		CEMS Performance	
			Specification No.	Acceptance Criteria	Relative Accuracy	
~11.3	NO <sub>x</sub>	ppmvd @ 15% O <sub>2</sub>	2	RA ≤ 20%	4.75 %	
	O <sub>2</sub>	%	3	RA ≤ 1.0% difference for %O <sub>2</sub>	0.02 %	

Based on the above summary of results, the facility CEMS passed the RATA. The complete test results from this program are tabulated in Section 7.0

#### **4.0 DISCUSSION OF RESULTS**

The data acquisition and handling system (DAHS) computer printout for the same time periods as TRC's reference method (RM) testing was used to determine the relative accuracy (RA) of the CEMS. The watches of the test crew were synchronized with the facility's CEM system prior to the commencement of and during each test run. A minimum of ten (10) RATA runs, each 21-minutes in duration, were performed at each turbine unit location while operating greater than 75% of maximum load. The CEMS RATA data, comprised of twenty-one (21) minutes of data points for each test run, was provided to TRC by the facility.

Source operation appeared normal during the entire test program. Each turbine was operated near base load during the RATA.

Data collected from the O<sub>2</sub> and NO<sub>x</sub> analyzers were averaged for each test run. A standard fuel factor of 8,710 dscf/MMBtu was used to calculate the NO<sub>x</sub> emission rates on a pound per million Btu basis (lb/MMBtu) following the guidelines of USEPA Method 19.

#### **5.0 TEST PROCEDURES**

All testing, sampling, analytical, and calibration procedures used for this test program were performed in accordance with the methods presented in the following sections. Where applicable, the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, Stationary Source Specific Methods, USEPA 600/R-94/038c, September 1994 was used to supplement procedures.

##### **5.1 Determination of the Concentration of Gaseous Pollutants**

Concentrations of the pollutants in the following sub-sections were determined using one sampling system. The number of points at which sample was collected was determined in accordance with 40CFR75 Appendix A, Section 6.5.6. Sampling was performed at three points (16.7%, 50%, and 83.3%) across one diameter of each turbine exhaust stack.

A straight-extractive sampling system was used. A data logger continuously recorded pollutant concentrations and generated one-minute averages of those concentrations. All calibrations and system checks were conducted using USEPA Protocol gases. Three-point linearity checks were performed prior to sampling, and in the event of a failing system bias or drift test (and subsequent corrective action). System bias and drift checks were performed using the low-level gas and either the mid- or high-level gas prior to and following each test run.

The Low Concentration Analyzers (those that routinely operate with a calibration span of less than 20 ppm) used by TRC are ambient-level analyzers. Per Section 3.12 of Method



7E, a Manufacturer's Stability Test is not required for ambient-level analyzers. Analyzer interference tests were conducted in accordance with the regulations in effect at the time that TRC placed an analyzer model in service.

#### **5.1.1 O<sub>2</sub> Determination by USEPA Method 3A**

This method is applicable for the determination of O<sub>2</sub> concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The O<sub>2</sub> analyzer was equipped with a paramagnetic-based detector.

#### **5.1.2 NO<sub>x</sub> Determination by USEPA Method 7E**

This method is applicable for the determination of NO<sub>x</sub> concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The NO<sub>x</sub> analyzer used a photomultiplier tube to measure the light emitted from the chemiluminescent decomposition of NO<sub>2</sub>. A NO<sub>x</sub> converter efficiency test was performed on site. The results show the NO<sub>x</sub> analyzer passed. Results are appended.

#### **5.1.3 Determination of F-Factors by USEPA Method 19**

This method is applicable for the determination of the pollutant emission rate using oxygen (O<sub>2</sub>) concentrations and the appropriate F factor (the ratio of combustion gas volumes to heat inputs) and the pollutant concentration. The appropriate F-Factor was selected from Table 19-2 of Method 19.

### **6.0 QUALITY ASSURANCE PROCEDURES**

TRC integrates our Quality Management System (QMS) into every aspect of our testing service. We follow the procedures specified in current published versions of the test Method(s) referenced in this report. Any modifications or deviations are specifically identified in the body of the report. We routinely participate in independent, third-party audits of our activities, and maintain:

- Accreditation from the Louisiana Environmental Laboratory Accreditation Program (LELAP).
- Accreditation from the Stack Testing Accreditation Council (STAC) and the American Association for Laboratory Accreditation (A2LA) that our operations conform with the requirements of ASTM D 7036 as an Air Emission Testing Body (AETB).

These accreditations demonstrate that our systems for training, equipment maintenance and calibration, document control and project management will fully ensure that project objectives are achieved in a timely and efficient manner with a strict commitment to quality.



All calibrations are performed in accordance with the test Method(s) identified in this report. If a Method allows for more than one calibration approach, or if approved alternatives are available, the calibration documentation in the appendices specifies which approach was used. All measurement devices are calibrated or verified at set intervals against standards traceable to the National Institute of Standards and Technology (NIST). NIST traceability information is available upon request.

ASTM D7036-04 specifies that: *"AETBs shall have and shall apply procedures for estimating the uncertainty of measurement. Conformance with this section may be demonstrated by the use of approved test protocols for all tests. When such protocols are used, reference shall be made to published literature, when available, where estimates of uncertainty for test methods may be found."* TRC conforms with this section by using approved test protocols for all tests.

## 7.0 TEST RESULTS SUMMARIES

RATA Type: Nitrogen Oxides (NO<sub>x</sub>), lb/MMBtu  
 Regulation: 40CFR75  
 RM Used: 3A, 7E

Customer:		USG-Otsego Paper		Project #:		583368		
Unit ID:		EUTURBINE1 (North-U24)		CEM Model:		Horiba/CMA-EC622		
Sample Loc:		Stack		CEM Serial #:		41678240071		
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO <sub>x</sub> lb/MMBtu	CEM NO <sub>x</sub> lb/MMBtu	(RM-CEM) Difference (di)	Unit Load (MW)
1	1	4/2/2024	7:35	7:55	0.022	0.021	0.001	10.3
1	2	4/2/2024	8:10	8:30	0.023	0.022	0.001	10.4
1	3	4/2/2024	8:45	9:05	0.023	0.022	0.001	10.4
1	4	4/2/2024	9:19	9:39	0.023	0.022	0.001	10.3
1	5	4/2/2024	9:54	10:14	0.022	0.022	0.000	10.3
1	6	4/2/2024	10:29	10:49	0.022	0.021	0.001	10.2
1	7	4/2/2024	11:03	11:23	0.023	0.023	0.000	10.3
1	8	4/2/2024	11:37	11:57	0.022	0.022	0.000	10.2
1	9	4/2/2024	12:15	12:35	0.022	0.022	0.000	10.2
0	10	4/2/2024	12:53	13:13	0.022	0.021	0.001	10.2

n	9
t(0.025)	2.306
Mean RM Value	0.022 RM avg
Mean CEM Value	0.022 CEM avg
Sum of Differences	0.005 di
Mean Difference	0.0006 d avg
Sum of Differences <sup>2</sup>	0.000 di^2
Standard Deviation	0.001 sd
Confidence Coefficient	0.000 CC
RA based on RM	4.28 %
Bias Adjustment Factor	1.025 BAF

RATA Type: Nitrogen Oxides (NO<sub>x</sub>), ppmvd at 15% Oxygen  
 Regulation: 40CFR60  
 RM Used: 7E

Customer:		USG-Otsego Paper			Project #:		583368	
Unit ID:		EUTURBINE1 (North-U24)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240071	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO <sub>x</sub> ppmvd at 15% Oxygen	CEM NO <sub>x</sub> ppmvd at 15% Oxygen	(RM-CEM) Difference (di)	Unit Load (MW)
1	1	4/2/2024	7:35	7:55	6.0	5.8	0.200	10.3
0	2	4/2/2024	8:10	8:30	6.3	6.0	0.300	10.4
1	3	4/2/2024	8:45	9:05	6.3	6.1	0.200	10.4
1	4	4/2/2024	9:19	9:39	6.1	6.0	0.100	10.3
1	5	4/2/2024	9:54	10:14	6.1	5.9	0.200	10.3
1	6	4/2/2024	10:29	10:49	5.9	5.7	0.200	10.2
1	7	4/2/2024	11:03	11:23	6.3	6.3	0.000	10.3
1	8	4/2/2024	11:37	11:57	6.0	5.9	0.100	10.2
1	9	4/2/2024	12:15	12:35	6.1	6.0	0.100	10.2
1	10	4/2/2024	12:53	13:13	5.9	5.8	0.100	10.2

n	9
t(0.975)	2.306
Mean RM Value	6.078 RM avg
Mean CEM Value	5.944 CEM avg
Sum of Differences	1.200 di
Mean Difference	0.133 d avg
Sum of Differences <sup>2</sup>	0.200 di <sup>2</sup>
Standard Deviation	0.071 sd
Confidence Coefficient	0.054 CC
RA based on RM	3.09 %



RATA Type: Oxygen (O<sub>2</sub>), % by volume  
 Regulation: 40CFR60  
 RM Used: 3A

Customer:		USG-Otsego Paper			Project #:		583368	
Unit ID:		EUTURBINE1 (North-U24)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240071	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM O <sub>2</sub> % v/v dry	CEM O <sub>2</sub> % v/v dry	(RM-CEM) Difference (di)	Unit Load (MW)
1	1	4/2/2024	7:35	7:55	15.5	15.6	-0.100	10.3
1	2	4/2/2024	8:10	8:30	15.5	15.6	-0.100	10.4
1	3	4/2/2024	8:45	9:05	15.5	15.6	-0.100	10.4
1	4	4/2/2024	9:19	9:39	15.5	15.6	-0.100	10.3
1	5	4/2/2024	9:54	10:14	15.5	15.6	-0.100	10.3
1	6	4/2/2024	10:29	10:49	15.6	15.6	0.000	10.2
1	7	4/2/2024	11:03	11:23	15.5	15.6	-0.100	10.3
1	8	4/2/2024	11:37	11:57	15.5	15.6	-0.100	10.2
1	9	4/2/2024	12:15	12:35	15.5	15.6	-0.100	10.2
0	10	4/2/2024	12:53	13:13	15.5	15.6	-0.100	10.2

n	9
t(0.975)	2.306
Mean RM Value	15.511 RM avg
Mean CEM Value	15.600 CEM avg
Mean Difference	-0.089 d avg
Standard Deviation	0.033 sd
Confidence Coefficient	0.026 CC
RA based on RM	0.74 %
RA (Absolute Mean Difference)	0.09 % vol diff.

RATA Type: Nitrogen Oxides (NO<sub>x</sub>), lb/MMBtu  
 Regulation: 40CFR75  
 RM Used: 3A, 7E

Customer:		USG-Otsego Paper		Project #:		583368		
Unit ID:		EUTURBINE2 (South)		CEM Model:		Horiba/CMA-EC622		
Sample Loc:		Stack		CEM Serial #:		41678240073		
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO <sub>x</sub> lb/MMBtu	CEM NO <sub>x</sub> lb/MMBtu	(RM-CEM) Difference (di)	Unit Load (MW)
1	1	4/5/2024	7:23	7:43	0.068	0.065	0.003	11.3
0	2	4/5/2024	7:58	8:18	0.067	0.064	0.003	11.3
1	3	4/5/2024	8:33	8:53	0.067	0.065	0.002	11.3
1	4	4/5/2024	9:08	9:28	0.069	0.066	0.003	11.3
1	5	4/5/2024	9:41	10:01	0.070	0.067	0.003	11.3
1	6	4/5/2024	10:14	10:34	0.071	0.068	0.003	11.2
1	7	4/5/2024	10:50	11:10	0.071	0.068	0.003	11.2
1	8	4/5/2024	11:23	11:43	0.071	0.068	0.003	11.2
1	9	4/2/2024	11:57	12:17	0.073	0.070	0.003	11.2
1	10	4/2/2024	12:30	12:50	0.072	0.069	0.003	11.2

n	9
t(0.025)	2.306
Mean RM Value	0.070 RM avg
Mean CEM Value	0.067 CEM avg
Sum of Differences	0.026 di
Mean Difference	0.0029 d avg
Sum of Differences <sup>2</sup>	0.000 di^2
Standard Deviation	0.000 sd
Confidence Coefficient	0.000 CC
RA based on RM	4.48 %
Bias Adjustment Factor	1.043 BAF

RATA Type: Nitrogen Oxides (NO<sub>x</sub>), ppmvd at 15% Oxygen  
 Regulation: 40CFR60  
 RM Used: 7E

Customer: USG-Otsego Paper

Unit ID: EUTURBINE2 (South)

Sample Loc: Stack

Project #: 583368

CEM Model: Horiba/CMA-EC622

CEM Serial #: 41678240073

Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO <sub>x</sub> ppmvd at 15% Oxygen	CEM NO <sub>x</sub> ppmvd at 15% Oxygen	(RM-CEM) Difference (di)	Unit Load (MW)
1	1	4/5/2024	7:23	7:43	18.4	17.5	0.900	11.3
1	2	4/5/2024	7:58	8:18	18.2	17.4	0.800	11.3
1	3	4/5/2024	8:33	8:53	18.3	17.5	0.800	11.3
1	4	4/5/2024	9:08	9:28	18.6	18.0	0.600	11.3
1	5	4/5/2024	9:41	10:01	19.1	18.3	0.800	11.3
1	6	4/5/2024	10:14	10:34	19.4	18.4	1.000	11.2
0	7	4/5/2024	10:50	11:10	19.4	18.4	1.000	11.2
1	8	4/5/2024	11:23	11:43	19.3	18.5	0.800	11.2
1	9	4/2/2024	11:57	12:17	19.8	18.9	0.900	11.2
1	10	4/2/2024	12:30	12:50	19.6	18.9	0.700	11.2

n	9
t(0.975)	2.306
Mean RM Value	18.967 RM avg
Mean CEM Value	18.156 CEM avg
Sum of Differences	7.300 di
Mean Difference	0.811 d avg
Sum of Differences <sup>2</sup>	6.030 di^2
Standard Deviation	0.117 sd
Confidence Coefficient	0.090 CC
RA based on RM	4.75 %

RATA Type: Oxygen (O<sub>2</sub>), % by volume  
 Regulation: 40CFR60  
 RM Used: 3A

Customer:		USG-Otsego Paper			Project #:		583368	
Unit ID:		EUTURBINE2 (South)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240073	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM O <sub>2</sub> % v/v dry	CEM O <sub>2</sub> % v/v dry	(RM-CEM) Difference (di)	Unit Load (MW)
0	1	4/5/2024	7:23	7:43	15.4	15.5	-0.100	11.3
1	2	4/5/2024	7:58	8:18	15.4	15.4	0.000	11.3
1	3	4/5/2024	8:33	8:53	15.4	15.4	0.000	11.3
1	4	4/5/2024	9:08	9:28	15.4	15.5	-0.100	11.3
1	5	4/5/2024	9:41	10:01	15.4	15.4	0.000	11.3
1	6	4/5/2024	10:14	10:34	15.4	15.4	0.000	11.2
1	7	4/5/2024	10:50	11:10	15.4	15.4	0.000	11.2
1	8	4/5/2024	11:23	11:43	15.4	15.4	0.000	11.2
1	9	4/2/2024	11:57	12:17	15.4	15.4	0.000	11.2
1	10	4/2/2024	12:30	12:50	15.4	15.5	-0.100	11.2

n	9
t(0.975)	2.306
Mean RM Value	15.400 RM avg
Mean CEM Value	15.422 CEM avg
Mean Difference	-0.022 d avg
Standard Deviation	0.044 sd
Confidence Coefficient	0.034 CC
RA based on RM	0.36 %
RA (Absolute Mean Difference)	0.02 % vol diff.



## APPENDIX



### Part 75 ECMPs Reporting Information - PGVP

<b>Facility Name:</b>	USG-Otsego Paper
<b>Location ID:</b>	EUTURBINE1 (North-U24) - Stack
<b>Test Date(s):</b>	4/2/2024

<b>Testing Parameter</b>	<b>Gas Level Code</b>	<b>Gas Type Code</b>	<b>Cylinder ID No.</b>	<b>Vendor Identifier</b>	<b>Expiration Date</b>
<b>NO<sub>x</sub>-Diluent</b>	<i>Low</i>	O2, BALN	CC478855	—	1/14/2032
	<i>Mid</i>	CO, CO2, NO, NOX, SO2, BALN	CC160338	B12023	7/6/2026
	<i>High</i>	CO, CO2, NO, NOX, SO2, BALN	CC199692	B32024	2/28/2027
<b>Diluent - O<sub>2</sub></b>	<i>Low</i>	CO, CO2, NO, NOX, SO2, BALN	CC478855	—	1/14/2032
	<i>Mid</i>	CO2, O2, BALN	CC19849	B12023	7/10/2031
	<i>High</i>	CO2, O2, BALN	CC342262	B12023	6/16/2031