

RECEIVED

JUL 11 2023

AIR QUALITY DIVISION

40 CFR 63 Subpart ZZZZ  
Reciprocating Internal Combustion  
Engines (RICE MACT)  
Diversion Diesel Pump  
Engine B (D-200B)

Project number: 60699646

May 15, 2023

Quality information

**Prepared by**



Christopher Trevillian  
Air Quality Scientist III

**Checked by**



Rob Sava, QSTI  
Environmental Engineer IV

**Reviewed by**



James Edmister  
Project Manager

Revision History

Revision	Revision date	Details	Authorized	Name	Position
0	May 12, 2023		Draft	Chris Trevillian	Air Qual. Scientist
1	May 15, 2023		Review	Rob Sava	Env. Eng.

Distribution List

# Hard Copies	PDF Required	Association / Company Name
0	1	Dow Chemical Company

Prepared for:

Chuck Glenn  
Air SME  
The Dow Chemical Company  
Freeport, Texas, 77541  
T: 979.709.2307  
E: [cglenn@dow.com](mailto:cglenn@dow.com)

Prepared by:

AECOM  
3700 James Savage Rd  
Midland, MI 48642  
USA  
[www.aecom.com](http://www.aecom.com)

Managed by:

James Edmister  
Project Manager  
M: (585) 721-9128 (cell)  
E: [James.Edmister@aecom.com](mailto:James.Edmister@aecom.com)

Copyright © 2023 by AECOM

All rights reserved. No part of this copyrighted work may be reproduced, distributed, or transmitted in any form or by any means without the prior written permission of AECOM.

RECEIVED

JUL 11 2023

AIR QUALITY DIVISION

AECOM

ii

## Table of Contents

1.	Introduction.....	2-9
1.	Introduction .....	1-1
	1.1 Summary of Test Program .....	1-1
	1.2 Key Personnel .....	1-2
2.	Plant and Sampling Location Description .....	2-1
	2.1 Facility Description.....	2-1
3.	Summary and Discussion of Test Results .....	3-1
	3.2 Facility Operations .....	3-1
4.	Sampling and Analytical Procedures .....	4-1
	4.1 Test Methods .....	4-1
	4.2 Procedures .....	4-1
	4.3 List of Sampling Equipment.....	4-2
5.	Calculations .....	5-1
	5.1 Calibration Error - Equation 7E-1 .....	5-1
	5.2 System Bias - Equation 7E-2.....	5-2
	5.3 System Drift - Equation 7E-4 .....	5-3
	5.4 Effluent Concentration - Equation 7E-5b.....	5-4
	5.5 Effluent Concentration Corrected for Oxygen Concentration .....	5-5
	5.6 CO Reduction Efficiency.....	5-6
6.	Engine B Run Data .....	6-1
	6.1 Outlet Oxygen Calibration Data Summary .....	6-1
	6.2 Outlet Carbon Monoxide Calibration Data Summary .....	6-2
	6.3 Inlet Oxygen Calibration Data Summary .....	6-3
	6.4 Inlet Carbon Monoxide Calibration Data Summary .....	6-4
	6.5 Response Time Engine B .....	6-1
	6.6 Stratification Test Engine B.....	6-1
	6.7 Compliance Corrected Concentration Engine B.....	6-2
	6.8 Compliance Summary Engine B.....	6-3
	6.9 Summary Data Engine B .....	6-4
7.	Process Data .....	7-1
8.	Field Data Sheets Engine B.....	8-1
9.	Certificates of Analysis.....	9-1

## Figures

Figure 2-1.	Sampling Location Diagram .....	2-1
Figure 4-1.	Sampling Train Used for CO & O <sub>2</sub> (M10 & M3A).....	4-3

## Tables

Table 1-1. General Summary Information .....	1-1
Table 1-2. Test Program Personnel Summary .....	1-2
Table 3-1. Summary of Results .....	3-1
Table 3-2. Test Run Data.....	3-1
Table 3-4. Engine B Process Data .....	3-2
Table 4-1: Sampling Equipment .....	4-2

# 1. Introduction

## 1.1 Summary of Test Program

The Dow Chemical Company (Dow) in Midland, Michigan, is a large complex with manufacturing and utility plants. Dow's Michigan Operations (MiOps) is a major source of Hazardous Air Pollutants (HAPS).

AECOM was contracted to conduct a retest of compliance sampling on one 1050 horsepower (hp) non-emergency diesel engine (called Engine B), due to a process condition that was present during the February 2023, compliance sampling in order to demonstrate compliance with the RICE MACT, 40CFR63, Subpart ZZZZ. While the February compliance testing showed that the engine met the RICE MACT CO reduction efficiency, the process condition that was present prevented the engine from being operated at ideal conditions. The process condition was corrected, and the compliance sampling was recompleted on May 2, 2023 as summarized in this report. Additional process data, namely operating horse power of the engine and percent load, was collected during this test to ensure that the engine was tested under ideal conditions.

The engine is operated to divert influent wastewater and storm water away from the on-site wastewater treatment plant (WWTP) to wastewater storage tanks for a variety of reasons. The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2c of the RICE MACT, 40CFR63, Subpart ZZZZ.

The following table summarizes the pertinent data for this compliance test:

**Table 1-1. General Summary Information**

Responsible Groups	<ul style="list-style-type: none"> <li>The Dow Chemical Company</li> <li>Michigan Department of Energy, Great Lakes, and Environment. (EGLE)</li> <li>Environmental Protection Agency (EPA)</li> </ul>
Applicable Regulations	<ul style="list-style-type: none"> <li>ROP- MI-A4033-2017b</li> <li>40 CFR 63 Subpart ZZZZ (RICE MACT)</li> </ul>
Industry / Plant	<ul style="list-style-type: none"> <li>Environmental Operations Plant (EVO)</li> </ul>
Plant Location	<ul style="list-style-type: none"> <li>The Dow Chemical Company Midland, MI, 48667</li> </ul>
Unit Installation Date	<ul style="list-style-type: none"> <li>Engine B 3/17/2022</li> </ul>
Unit Initial Compliance Date	<ul style="list-style-type: none"> <li>Engine B 8/03/2022</li> </ul>
Air Pollution Control Equipment	<ul style="list-style-type: none"> <li>Engine B is equipped with dual single stage catalytic reduction and closed crankcase filtration emission control system</li> </ul>
Emission Points	<ul style="list-style-type: none"> <li>P200 Diesel Engine B</li> </ul>
Pollutants/Diluent Measured	<ul style="list-style-type: none"> <li>Carbon Monoxide (CO)</li> <li>Oxygen (O<sub>2</sub>)</li> </ul>
Test Dates	<ul style="list-style-type: none"> <li>May 2, 2023</li> </ul>

RECEIVED

JUL 11 2023

AIR QUALITY DIVISION

## 1.2 Key Personnel

Names and affiliations of personnel, including their roles in the test program, are summarized in the following table.

**Table 1-2. Test Program Personnel Summary**

Role	Role Description	Name	Affiliation
Process Focal Point	<ul style="list-style-type: none"> <li>• Coordinate plant operation during the test.</li> <li>• Ensure the unit is operating at the agreed upon conditions in the test plan.</li> <li>• Collect any process data required.</li> <li>• Provide all technical support related to process operation.</li> </ul>	Morgan Raup	Dow Chemical
Environmental Focal Point	<ul style="list-style-type: none"> <li>• Ensure all regulatory requirements and citations are reviewed and considered for the testing.</li> </ul>	Becky Meyerholt	Dow Chemical
Air SME	<ul style="list-style-type: none"> <li>• Leadership of the sampling program.</li> <li>• Develop the overall testing plan.</li> <li>• Determine the correct sample methods.</li> </ul>	Chuck Glenn	Dow Chemical
Technical Reviewer	<ul style="list-style-type: none"> <li>• Completes technical review of the test data.</li> </ul>	Chris Trevillian	AECOM
Field Team Leader	<ul style="list-style-type: none"> <li>• Ensures field sampling meets the quality assurance objectives of the plan.</li> </ul>	Peter Becker	AECOM
Sample Project Leader	<ul style="list-style-type: none"> <li>• Ensures data generated meets the quality assurance objectives of the plan.</li> </ul>	James Edmister	AECOM

## 2. Plant and Sampling Location Description

### 2.1 Facility Description

Dow operates a chemical manufacturing facility in Midland, Michigan. Environmental Operations (EVO) operates two diesel 1050 hp engines to divert influent wastewater and storm water away from the on-site wastewater treatment plant (WWTP) to wastewater storage tanks for a variety of reasons.

The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2b of the RICE MACT, 40CFR63, Subpart ZZZZ.


### 2.2 Control Equipment

CO emissions are controlled by catalytic reduction.

### 2.3 Flue Gas Sampling Locations

Sampling was conducted on Engine B prior to and after the dual (in parallel) single stage catalytic reduction. Flue gas sample locations met the minimum guidelines for carbon monoxide (CO) and oxygen (O<sub>2</sub>) sampling.

Figure 2-1. Sampling Location Diagram



### 3. Summary and Discussion of Test Results

#### 3.1 Objectives and Test Matrix

Under contract with Dow, Midland Operations, AECOM, Inc., conducted compliance sampling on the engine located at the Environmental Operations Plant (EVO) at Dow's Michigan Operations facility (MiOps). This engine is operated in non-emergency situations to manage wastewater and storm water at the MiOps site. The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2c. The specific objectives of this test were to:

- Verify the reduction efficiency (RE) for CO is greater than 70%

#### 3.2 Facility Operations

For engines >500HP the facility must:

- Minimize idle time at startup to <30 minutes
- Maintain the catalyst so the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; AND
- Exhaust maintained such that 450°F ≥ catalyst inlet temperature ≤ 1350°F

For the EVO Engine B, percent load is measured directly from a field mounted instrument display panel. The Engine is designed with a max load (100%) at 1050 Hp. Based on site conditions the maximum Hp we can get is 914, (87% load). Per the RICE MACT we are required to perform the testing at 100% load plus or minus 10% of the site conditions.

#### 3.3 Comments / Exceptions

- As allowed by 40 CFR Part 60 ZZZZ, this Compliance Test consisted of three, one hour test runs.

**Table 3-1. Summary of Results**

SAMPLE TYPE	TEST METHOD	*ACTUAL EMISSION REDUCTION	REQUIRED EMISSION REDUCTION
CO Emissions (RE) Engine B	EPA Method 10	97.02 %	70 %

**Table 3-2. Test Run Data**

P200 Engine B Test Run Data				
PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE
Sample Date	05/02/2023	05/02/2023	05/02/2023	--
Sample Times (start/end)	08:42-09:42	10:08-11:08	11:24-12:24	--
Outlet CO (ppmv @ 15% O <sub>2</sub> )	1.50	1.36	1.32	1.39
Inlet CO (ppmv @ 15% O <sub>2</sub> )	48.86	45.93	45.36	46.72
CO (RE %)	96.94	97.03	97.10	97.02

**Table 3-3. Engine B Process Data**

PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE
Sample Date	05/02/2023	05/02/2023	05/02/2023	--
Sample Times (start-end)	08:42-09:42	10:08-11:08	11:24-12:24	--
Engine RPM (RPM)	1850.01	1848.67	1849.09	1849.26
Engine Load Speed	100.00	100.00	100.00	100.00
Fuel Consumed (Gallons)	48	49	53	50
Engine % load <sup>a</sup>	N/A	N/A	N/A	86.2
Engine Horse power	N/A	N/A	N/A	913.25
<b>Catalyst A</b>				
Catalyst Inlet Temp (Deg F)	726.35	730.51	730.26	729.04
Differential Pressure (IWC)	19.03	19.07	19.10	19.07
<b>Catalyst B</b>				
Catalyst Inlet Temp (Deg F)	730.84	736.66	736.09	734.53
Differential Pressure (IWC)	19.49	19.51	19.51	19.50

\*1 gallon of distillate fuel with 15 ppm of sulfur or less produces 137,381 Btu.

A % load and Horse power was read periodically from the field mounted display only the average of all of the readings is reported

## 4. Sampling and Analytical Procedures

### 4.1 Test Methods

All sampling and analytical procedures are EPA published methods or methods allowed by 63.6610. This compliance test utilized the following methods:

- EPA Method 3A for O<sub>2</sub> Concentration
- EPA Method 10 for CO Concentration

#### **EPA Method 3A (Flue Gas Composition and Molecular Weight)**

EPA Method 3A (Instrumental Method) was utilized to determine the diluent during each run on the outlet.

An analyzer measured O<sub>2</sub> content on the basis of the strong paramagnetic properties of O<sub>2</sub> relative to other compounds present in combustion gases. In the presence of a magnetic field, O<sub>2</sub> molecules become temporary magnets. The analyzer determines the sample gas O<sub>2</sub> concentration by detecting the displacement torque of the sample test body in the presence of a magnetic field.

#### **EPA Method 10 (CO Sampling and Analysis)**

EPA Method 10 was utilized to determine carbon monoxide concentrations during each run on the outlet.

An analyzer measured CO based on its absorption of infrared radiation. The infrared unit uses a single beam, single wavelength technique, with wavelength selection being achieved by a carefully specified narrow band optical filter making it highly selective for CO measurement in the presence of other infrared-absorbing gases.

### 4.2 Procedures

The above methods will be performed using mobile continuous emission monitors. Gases will be withdrawn from the stack and transported to monitors located at ground level. A stainless-steel probe will be inserted into the stack and used to collect sample gas. A Teflon sample line heated to 250°F will transport sample gas from the probe to the analyzers. The analyzers will be kept at a constant temperature inside the mobile laboratory.

Sample gas will be collected continuously from the stack for a period of one hour. A stratification test will be performed during run one at the three traverse points of 16.7%, 50% and 83.3% of the measurement line that passes through the centroidal area of the stack or duct cross section. At the mobile laboratory, the stack gas will be routed to a condenser and then transported to the analyzers for analysis.

The Reduction Efficiency (RE) tests will be conducted by measuring the Oxygen and Carbon Monoxide concentrations within the inlet and outlet and then corrected to 15% oxygen.

RECEIVED

JUL 11 2023


AIR QUALITY DIVISION  
AECOM

### 4.3 List of Sampling Equipment

Table 4-1: Sampling Equipment

<b>Instrument</b>	<b>System</b>	<b>Range</b>	<b>Make</b>	<b>Model</b>	<b>Serial # or ID #</b>
Method 3A (O <sub>2</sub> )	Inlet O <sub>2</sub>	20.1%	Servomex	1440	OXC-1601
Method 10 (CO)	Inlet CO	124.5 ppm	Thermo	48c	CO-A1601
Method 3A (O <sub>2</sub> )	Outlet O <sub>2</sub>	20.1%	Servomex	1440	OXC-1602
Method 10 (CO)	Outlet CO	29.9 ppm	Thermo	48i	CO-A1604

Figure 4-1. Sampling Train Used for CO & O<sub>2</sub> (M10 & M3A)



L:\MBSA\VGR0\PHICS\Figures\CEMS System\_G Youngerman\_CEMS System\_Schematic Full System