

RECEIVED
OCT 11 2021
AIR QUALITY DIVISION

1.0 EXECUTIVE SUMMARY

Mostardi Platt conducted a compliance particulate test program for St Marys Cement at the Charlevoix Plant in Charlevoix, Michigan on the Main Kiln Stack and Cooler Stack. Main Kiln testing was performed during both “mill on” and “mill off” conditions.

The test locations, test dates, and test parameter are summarized below.

TEST INFORMATION		
Test Locations	Test Dates	Test Parameters
Main Kiln Stack (Mill On)	August 10, 2021	Filterable Particulate Matter (FPM), Condensable Particulate Matter (CPM), Total Particulate Matter (TPM), Particulate Matter less than 10 microns (PM ₁₀), and Particulate Matter less than 2.5 microns (PM _{2.5})
Main Kiln Stack (Mill Off)	August 12, 2021	
Clinker Cooler Stack	August 11, 2021	

The purpose of the test program was to demonstrate compliance with Title 40, *Code of Federal Regulations*, Part 63 (40CFR63), Subpart LLL “*National Emission Standards for Hazardous Air Pollutants (NESHAP) for the Portland Cement Manufacturing Industry and Standards of Performance for Portland Cement Plants.*” Specifically, to demonstrate that each of the below listed sources meet their FPM emission limit and to establish a site-specific operating limit (SSOL) for each emission point’s continuous parameter monitoring system (CPMS). Additionally, PM/PM₁₀/PM_{2.5} testing was performed in conjunction with the above testing on the Main Kiln Stack in order to demonstrate compliance with Michigan Permit to Install 140-15B and Consent Order AQD No. 2021-09. For reporting purposes, all particulate matter collected (TPM) is considered to be less than PM₁₀/PM_{2.5}.

1.1 SSOL Results

Test Location	Parameter	Emission Rate	Filterable Particulate Matter, % of Emissions Limit	Emission Limit	CPMS 3-run Average	CPMS SSOL ¹
Main Kiln Stack (Mill On)	FPM	0.015 lb/ton	20.8	0.07 lb/ton	12.48 mg/m ³	44.16
Main Kiln Stack (Mill Off)	FPM	0.004 lb/ton	6.1	0.07 lb/ton	1.68 mg/m ³	
Clinker Cooler Stack	FPM	0.003 lb/ton	16.8	0.02 lb/ton	0.59 mg/m ³	2.61

¹ Main Kiln SSOL is prorated based upon the time weighted average for mill on (90%) and mill off (10%) conditions

1.2 Compliance Results

Test Location	Parameter	Emission Limit	Test Result (Mill On)	Test Result (Mill Off)
Main Kiln Stack	PM ₁₀ /PM _{2.5}	Emission Factor established during test	0.324 lb/ton clinker	1.479 lb/ton clinker

The identifications of the individuals associated with the test program are summarized below.

TEST PERSONNEL INFORMATION		
Location	Address	Contact
Test Facility	St Marys Cement Charlevoix Cement Plant 16000 Bells Bay Road Charlevoix, Michigan 49720	Ms. Laurie Leaman Environmental Manager (231) 237-1387 laurie.leaman@vcimentos.com
Testing Company Supervisor	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Mr. Charles Reice Project Supervisor 630-993-2100 (phone) creice@mp-mail.com

The test crew consisted of Messrs. J. Priesz, M. Friduss and C. Reice.

2.0 TEST METHODOLOGY

Emission testing was conducted following the United States Environmental Protection Agency (USEPA) methods specified in 40CFR60, Appendix A and 40CFR51, Appendix M in addition the Mostardi Platt Quality Manual. Schematics of the test section diagrams and sampling trains used are included in Appendix A and B respectively. Calculation nomenclature are included in Appendix C. Laboratory analysis for each test run are included in Appendix D. The computerized reference method test data is included in Appendix E. CPMS data and process data as provided by St Marys Cement are also included in Appendix F.

The following methodologies were used during the test program:

Method 1 Sample and Velocity Traverse Determination

Test measurement points were selected in accordance with USEPA Method 1, 40CFR60, Appendix A. The characteristics of the measurement location are summarized below.

TEST POINT INFORMATION							
Test Location	Stack Dimensions	No. of Ports	Port Length (Inches)	Upstream Diameters	Downstream Diameters	Test Parameters	Number of Sampling Points
Main Kiln Stack	10.58'	2	6	7.86	15.72	PM/PM ₁₀ /PM _{2.5}	12
Clinker Cooler Stack	10.22'	4	6.5	2.0	8.0	PM/PM ₁₀ /PM _{2.5}	12

Method 2 Volumetric Flow Rate Determination

Gas velocity was measured following USEPA Method 2, 40CFR60, Appendix A, for purposes of calculating stack gas volumetric flow rate and emission rates on a lb/hr basis. S-type pitot tubes, 0-10" differential pressure gauge, and K-type thermocouple and temperature readout were used to determine gas velocity at each sample point. All of the equipment used was calibrated in accordance with the specifications of the Method. Copies of field data sheets are included in Appendix G. Calibration data are presented in Appendix H. This testing met the performance specifications as outlined in the Method.

Method 3A Oxygen (O₂)/Carbon Dioxide (CO₂) Determination

Flue gas O₂ and CO₂ concentrations for the Main Kiln Stack were determined in accordance with USEPA Method 3A. A Servomex analyzer was used to determine the O₂ and CO₂ concentrations by connecting the analyzer to the exit of the dry gas meter. The O₂ instrument operates in the nominal range of 0% to 25% with the specific range determined by the high-level calibration gas. The CO₂ instrument operates in the nominal range of 0% to 80% with the specific range determined by the high-level calibration gas. High and mid-range calibrations were performed using USEPA Protocol gas. Zero nitrogen (a low ppm pollutant in balance nitrogen calibration gases) was introduced during other instrument calibrations to check instrument zero. Zero and mid-range calibrations were performed using USEPA Protocol gas after each test run. Copies of the gas cylinder certifications are found in Appendix H. For testing on the Clinker Cooler Stack, per section 8.6 of USEPA Method 2, this source is a non-combustion source and a dry molecular weight of 29.0 was utilized.

Method 5 Filterable Particulate Matter (FPM) Determination

FPM runs were performed at the Main Stack during Raw Mill On and Raw Mill Off conditions, while Clinker Cooler runs were performed at one condition in accordance with USEPA Method 5, 40CFR60, Appendix A. Each run was a minimum one hundred twenty (120) minutes in duration and sampled a minimum volume of 2.0 dry standard cubic meters (dscm). Results were reported in lb/hr, and pounds per ton of clinker produced (lb/ton). Results were used to determine the Site-Specific Operating Limit (SSOL).

The particulate matter sampling train was manufactured by Environmental Supply Corporation and meets all specifications required by Method 5. Velocity pressures were determined simultaneously during sampling with an S-type pitot tube and inclined manometer. All temperatures will be measured using K-type thermocouples with calibrated digital temperature indicators. The probe and filter temperatures were maintained at 248°F ± 25°F throughout sampling.

The filter media are high purity quartz that meet all requirements of Method 5. All sample contact surfaces of the train were washed with HPLC reagent-grade acetone. These washes were placed in sealed and marked containers for analysis.

All sample recoveries were performed at the test site by the test crew. All final particulate sample analyses were performed by Mostardi Platt personnel at the laboratory in Elmhurst, Illinois.

Laboratory analysis data are found in Appendix D. Calibration data are presented in Appendix H.

Method 202 Condensable Particulate Determination

Stack gas condensable particulate matter concentrations and emission rates were determined in accordance with USEPA Method 202, in conjunction with Method 5 filterable particulate sampling. This method applies to the determination of CPM emissions from stationary sources. It is intended to represent condensable matter as material that condenses after passing through a filter and as measured by this method.

The CPM was collected in impingers after filterable particulate material was collected using Method 202. Compared to the December 17, 1991 promulgated Method 202, this Method includes the addition of a condenser, followed by a water dropout impinger immediately after the final heated filter. One modified Greenburg Smith impinger and an ambient temperature filter follow the water dropout impinger.

CPM was collected in the water dropout, modified Greenburg Smith impinger and ambient filter portion of the sampling train as described in this Method. The impinger contents were purged with nitrogen (N₂) immediately after sample collection to remove dissolved sulfur dioxide (SO₂) gases from the impingers. The impinger solution was then extracted with deionized water and hexane. The organic and aqueous fractions were dried and the residues weighed. The total of the aqueous, organic, and ambient filter fractions represents the CPM.

All sample recovery was performed at the test site by the test crew. Mostardi Platt personnel at the laboratory in Elmhurst, Illinois, performed all final particulate sample analyses as provided in Appendix D. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix H.

3.0 TEST RESULT SUMMARIES

Client: St Marys Cement
Facility: Charlevoix, Michigan
Test Location: Main Kiln Stack
Test Method: 5/202

Source Condition	Mill On	Mill On	Mill On	Mill On	
Date	8/10/21	8/10/21	8/10/21	8/10/21	
Start Time	8:45	11:48	15:07	17:30	
End Time	11:06	13:52	17:11	19:34	
	Run 1	Run 2*	Run 3	Run 4	Average
Stack Conditions					
Average Gas Temperature, °F	218.8	215.3	220.5	220.0	219.8
Flue Gas Moisture, percent by volume	14.0%	11.9%	13.7%	14.3%	14.0%
Average Flue Pressure, in. Hg	29.28	29.28	29.28	29.28	29.28
Gas Sample Volume, dscf	103.351	99.479	102.041	99.731	101.708
Average Gas Velocity, ft/sec	84.971	84.681	86.188	85.092	85.417
Gas Volumetric Flow Rate, acfm	448,210	446,682	454,630	448,850	450,563
Gas Volumetric Flow Rate, dscfm	293,429	301,183	297,784	292,379	294,531
Gas Volumetric Flow Rate, scfm	341,249	341,805	345,246	341,108	342,534
Average %CO ₂ by volume, dry basis	21.2	21.4	19.8	21.4	20.8
Average %O ₂ by volume, dry basis	8.8	8.9	9.6	9.0	9.1
Isokinetic Variance	103.4	100.2	100.6	100.1	101.4
Clinker Production Rate, ton/hr	249.62	249.63	249.64	249.61	249.62
CPMS Response, mg/m ³	13.77	11.10	11.88	11.78	12.48
Filterable Particulate Matter (Method 5)					
grams collected	0.00807	0.00852	0.01100	0.00939	0.00949
grains/acf	0.0008	0.0009	0.0011	0.0009	0.0009
grains/dscf	0.0012	0.0013	0.0017	0.0015	0.0015
lb/hr	3.032	3.300	4.244	3.641	3.639
lb/1000 lb of stack gas	0.002	0.002	0.003	0.003	0.003
lb/ton of clinker	0.012	0.013	0.017	0.015	0.015
Condensable Particulate Matter (Method 202)					
grams collected	0.21219	0.15621	0.20900	0.18480	0.20200
grains/acf	0.0207	0.0158	0.0207	0.0186	0.0200
grains/dscf	0.0317	0.0234	0.0316	0.0286	0.0306
lb/hr	79.677	60.505	80.666	71.650	77.331
lb/ton of clinker	0.319	0.242	0.323	0.287	0.310
Total Particulate Matter (5/202)					
grams collected	0.22026	0.16473	0.22000	0.19420	0.21149
grains/acf	0.0215	0.0167	0.0218	0.0195	0.0209
grains/dscf	0.0329	0.0247	0.0333	0.0301	0.0321
lb/hr	82.709	63.805	84.910	75.291	80.970
lb/ton of clinker	0.331	0.256	0.340	0.302	0.324

*Run 2 not included in the three run average due to a post-test leak check failure. Standard volume has been corrected for this leak rate.

Client: St Marys Cement
Facility: Charlevoix, Michigan
Test Location: Main Kiln Stack
Test Method: 5/202

	Source Condition	Mill Off	Mill Off	Mill Off	
	Date	8/12/21	8/12/21	8/12/21	
	Start Time	9:35	12:13	14:45	
	End Time	11:39	14:17	16:48	
		Run 1	Run 2	Run 3	Average
Stack Conditions					
Average Gas Temperature, °F		358.0	356.3	355.7	356.7
Flue Gas Moisture, percent by volume		11.7%	12.1%	12.0%	11.9%
Average Flue Pressure, in. Hg		29.28	29.28	29.28	29.28
Gas Sample Volume, dscf		91.553	88.588	90.343	90.161
Average Gas Velocity, ft/sec		88.113	87.827	88.532	88.157
Gas Volumetric Flow Rate, acfm		464,786	463,275	466,994	465,018
Gas Volumetric Flow Rate, dscfm		259,185	257,861	260,407	259,151
Gas Volumetric Flow Rate, scfm		293,613	293,302	295,868	294,261
Average %CO ₂ by volume, dry basis		23.5	23.9	23.4	23.6
Average %O ₂ by volume, dry basis		7.3	7.2	7.3	7.3
Isokinetic Variance		103.7	100.8	101.8	102.1
Clinker Production Rate, ton/hr		240.90	240.91	240.92	240.91
CPMS Response, mg/m ³		1.48	1.97	1.60	1.68
Filterable Particulate Matter (Method 5)					
grams collected		0.00297	0.00383	0.00137	0.00272
grains/acf		0.0003	0.0004	0.0001	0.0003
grains/dscf		0.0005	0.0007	0.0002	0.0005
lb/hr		1.112	1.474	0.522	1.036
lb/1000 lb of stack gas		0.001	0.001	0.000	0.001
lb/ton of clinker		0.005	0.006	0.002	0.004
Condensable Particulate Matter (Method 202)					
grams collected		0.89458	0.91456	0.99416	0.93443
grains/acf		0.0841	0.0887	0.0947	0.0892
grains/dscf		0.1508	0.1593	0.1698	0.1600
lb/hr		334.946	352.082	378.996	355.341
lb/ton of clinker		1.390	1.461	1.573	1.475
Total Particulate Matter (5/202)					
grams collected		0.89755	0.91839	0.99553	0.93716
grains/acf		0.0844	0.0891	0.0948	0.0894
grains/dscf		0.1513	0.1600	0.1700	0.1604
lb/hr		336.058	353.556	379.518	356.377
lb/ton of clinker		1.395	1.468	1.575	1.479

Client: St Marys Cement
Facility: Charlevoix, Michigan
Test Location: Clinker Cooler Stack
Test Method: 5/202

	Normal	Normal	Normal	
Source Condition	Normal	Normal	Normal	
Date	8/11/21	8/11/21	8/11/21	
Start Time	9:04	12:05	14:45	
End Time	11:20	14:14	17:00	
	Run 1	Run 2	Run 3	Average
Stack Conditions				
Average Gas Temperature, °F	206.8	210.3	199.6	205.6
Flue Gas Moisture, percent by volume	1.8%	2.4%	2.5%	2.2%
Average Flue Pressure, in. Hg	29.01	29.01	29.01	29.01
Gas Sample Volume, dscf	101.24	81.253	87.008	89.834
Average Gas Velocity, ft/sec	44.959	42.578	43.213	43.583
Gas Volumetric Flow Rate, acfm	221,289	209,569	212,696	214,518
Gas Volumetric Flow Rate, dscfm	166,936	156,245	160,911	161,364
Gas Volumetric Flow Rate, scfm	169,926	160,085	165,118	165,043
Isokinetic Variance	102.1	103.5	107.6	104.4
Clinker Production Rate, ton/hr	258.33	258.34	258.33	258.33
CPMS Response, mg/m ³	0.50	0.58	0.68	0.59
Filterable Particulate Matter (Method 5)				
grams collected	0.00279	0.00410	0.00392	0.00360
grains/acf	0.0003	0.0006	0.0005	0.0005
grains/dscf	0.0004	0.0008	0.0007	0.0006
lb/hr	0.608	1.043	0.959	0.870
lb/ton of clinker	0.002	0.004	0.004	0.003
Condensable Particulate Matter (Method 202)				
grams collected	0.00033	0.00107	0.00145	0.00095
grains/acf	0.0000	0.0002	0.0002	0.0001
grains/dscf	0.0001	0.0002	0.0003	0.0002
lb/hr	0.072	0.272	0.355	0.233
lb/ton of clinker	0.000	0.001	0.001	0.001
Total Particulate Matter (5/202)				
grams collected	0.00312	0.00517	0.00537	0.00455
grains/acf	0.0003	0.0008	0.0007	0.0006
grains/dscf	0.0005	0.0010	0.0010	0.0008
lb/hr	0.680	1.315	1.314	1.103
lb/ton of clinker	0.003	0.005	0.005	0.004
Site Specific Operating Limit (SSOL) Determination				
Source Emissions Limit, lb/ton			0.02	
CPMS Zero, mg/m ³			0.00	
Filterable Particulate Matter, % of Emissions Limit			16.8%	
SSOL			2.61	

4.0 Particulate Matter Continuous Parameter Monitoring System

Per St Marys Cement a Relative Accuracy Test Audit (RATA) report summarizing the calibration and monitor certification will be submitted under separate cover for EGLE review. In addition to the monitor certification, the PC MACT requires that all data recorded and used to establish parameters for monitoring are to be submitted, including the following, per 1349(b)(1)(vii):

- Make and Model
 - All units are Sick SP100
- Serial Number
 - Main Stack PM Monitor s/n 17398675 Probe 16408330
 - Clinker PM Monitor s/n 17278571 Probe 17258401
- Analytical Principal
 - The measuring system works according to the *scattered light measurement* principle (i.e., forward dispersion). A laser diode beams the dust particles in the gas flow with modulated light in the visual range (wavelength approximately 650 nanometers [nm]). A highly sensitive detector registers the light scattered by the particles, amplifies the light electrically, and feeds it to the measuring channel of a microprocessor as a central part of the measuring, control, and evaluation electronics. The measuring volume in the gas duct is defined through the intersection of the sender beam and the receiving aperture.
 - Continuous monitoring of the sender output registers the smallest changes in brightness of the light beam sent, which then serves to determine the measurement signal
- Span of Primary Analytical Range
 - The original system specifications were for a range of 0 to 200 milligrams per dry standard cubic meter (mg/dscm)
- Milliamp Value or Digital Equivalent to the Zero Output
 - The monitor output is in milligrams, with zero equal to zero
- Technique to Determine the Zero Value
 - The sender diode is switched off for *zero-point control* so that no signal is received. This means possible *drifts* or zero-point deviations are reliably detected in the overall system (e.g., due to an electronic defect). An error signal is generated when the *zero value* is outside the specified range.
- Average Milliamp or Digital Equivalent Signals Corresponding to Each PM Compliance Run
 - See Appendix A, raw data recorded by the CPMS monitors is attached.

5.0 CERTIFICATION

Mostardi Platt is pleased to have been of service to St Marys Cement. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

As the program manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results. The test program was performed in accordance with the test methods and the Mostardi Platt Quality Manual, as applicable.

MOSTARDI PLATT



Charles R. Reice

Project Manager




Eric L. Ehlers

Quality Assurance

APPENDICES

Appendix A - Test Section Diagrams

EQUAL AREA TRAVERSE FOR ROUND DUCTS



Project: St Mary's Cement
Charlevoix Plant
Charlevoix, Michigan

Test Location: Main Kiln Stack

Test Dates: August 10 and 12, 2021

No. Sample Points: 12



Diameter: 10.58 Feet

Flue Area: 92.459 Square Feet

Upstream Diameters: 7.9

Downstream
Diameters: 15.7

EQUAL AREA TRAVERSE FOR ROUND DUCTS



Project: St Mary's Cement
Charlevoix Plant
Charlevoix, Michigan

Test Location: Clinker Cooler Exhaust

Test Date: August 11, 2021

No. Sample Points: 12

Diameter: 10.22 Feet


Flue Area: 82.03 Square Feet

Upstream Diameters: 2.0


Downstream
Diameters: 8.0

Appendix B - Sample Train Diagrams


USEPA Method 2 – Type S Pitot Tube Manometer Assembly



USEPA Method 5/202- Filterable/Condensable Particulate Matter



USEPA Method 3A Extractive Gaseous Sampling Diagram



Appendix C - Calculation Nomenclature and Formulas