

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**FCE Summary Report**

Facility : Clinton River WRRF	SRN : B1950
Location : 155 N OPDYKE ROAD	District : Southeast Michigan
	County : OAKLAND
City : PONTIAC      State: MI    Zip Code : 48342	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Sebastian Kallumkal
FCE Begin Date : 1/1/2018	FCE Completion Date : 2/26/2019
Comments : Facility appears to be in compliance with the requirements of PTI No. 195-15A and federal standards 40 CFR 60, Subpart JJJJ for the two new emergency generators. Facility needs to verify compliance with 40 CFR 63, Subpart ZZZZ for the RICEs.	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
02/05/2019	Scheduled Inspection	Compliance	Onsite Inspection
10/26/2018	NSPS (Part 60)	Compliance	NSPS Emission Test Report. NSPS Subpart JJJJ test for two emergency engines. Compliance with the emission limits for NOx, CO, & NMOC (VOC).
09/27/2018	Stack Test Observation	Compliance	Engine tests
05/17/2018	MAERS	Compliance	MAERS Report submission. Reviewed and uploaded.

Name: Sebastian Kallumkal      Date: 2/26/2019      Supervisor: Joyce BL