

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Par Sterile Products LLC	SRN : B2329
Location : 870 PARKDALE RD	District : Warren
	County : OAKLAND
City : ROCHESTER State: MI Zip Code : 48307	Compliance Status : Non Compliance
Source Class : SM OPT OUT	Staff : Adam Bognar
FCE Begin Date : 9/25/2021	FCE Completion Date : 9/30/2022
Comments : Facility installed and commenced operation of an non EPA certified emergency generator without conducting the necessary performance testing.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
09/16/2022	On-site Inspection	Non Compliance	Scheduled Inspection
05/25/2022	MAERS	Compliance	MAERS review complete. Audit passed on 05/25/22. Reported facility-wide emissions were 14370.95 lbs VOCs and 1383.77 lbs NOx. EULABDIESELGEN and EUDIESELGEN in PTI 73-21 added by Annette Sommers on 05/24/22.
04/07/2022	ROP Annual Cert	Compliance	facility indicated compliance with all conditions of the ROP for this period.
04/07/2022	ROP SEMI 2 CERT	Compliance	facility indicated they are in compliance with all conditions in the ROP for this period.

Name: Adam BognarDate: 9/30/2022

Supervisor:

K. Kelly