



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING DISTRICT OFFICE



DAN WYANT
DIRECTOR

March 5, 2014

Mr. Mark Matus
Environmental Services Manager
Lansing Board of Water and Light
1201 S. Washington Avenue
Lansing, MI 48910

SRN: B2647, Ingham County

Dear Mr. Matus:

VIOLATION NOTICE

On February 11, 2014, staff of the Department of Environmental Quality (DEQ), Air Quality Division (AQD) observed visible emissions from Lansing Board of Water and Light (LBWL) Eckert Station located at 601 Island Avenue in Lansing and subsequently received an opacity report on February 12, 2014, for Boiler Units 1-6. The opacity report indicated the following violation occurred on February 11, 2014, between the hours of 8:00 a.m. and 2:00 p.m.

| Process Description | Permit Condition/Rule Violated | Comments |
|---------------------|--|--|
| FGECKERT | MI-ROP-B2647-2012, FGECKERT Flexible Group Condition 1.2 and Rule 301. | Opacity in excess of 20 percent from EUBOILER5 |

The AQD received and reviewed your written Rule 912 Report in response to this visible emissions incident. In addition to the actions taken to correct the condition and the actions to be taken to prevent a reoccurrence, please provide AQD with steps that will be taken to ensure the appropriate LBWL personnel are notified in a timely fashion in the event of reoccurrences.

If LBWL believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the telephone number listed below.

Sincerely,

A handwritten signature in black ink, appearing to read "Brad Myott". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

Brad Myott
Senior Environmental Engineer
Air Quality Division
517-284-6639

BAM:TG

cc: Mr. Michael McClellan, DEQ
cc/via email: Ms. Lynn Fiedler, DEQ
Ms. Teresa Seidel, DEQ
Mr. Thomas Hess, DEQ