

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**FCE Summary Report**

<b>Facility :</b> DTE Electric Company - Colfax Peaking Facility	<b>SRN :</b> B2795
<b>Location :</b> 4025 GREGORY	<b>District :</b> Lansing
	<b>County :</b> LIVINGSTON
<b>City :</b> FOWLERVILLE <b>State:</b> MI <b>Zip Code :</b> 48836	<b>Compliance Status :</b> Compliance
<b>Source Class :</b> MAJOR	<b>Staff :</b> Samantha Davis
<b>FCE Begin Date :</b> 9/16/2020	<b>FCE Completion Date :</b> 9/16/2021
<b>Comments :</b>	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
09/15/2021	Stack Test Observation	Unknown	Stack testing for EUDG11-2, EUDG11-4 and EUDG11-5 for compliance with 40 CFR 63, Subpart ZZZZ. Units 11-1 and 11-3 are down for repair and will be tested on a different date. Observed Engine 11-2 stack test on the day of observation, 09/15/21.
07/22/2021	ROP Annual Cert	Compliance	Annual compliance certification for ROP No. MI-ROP-B2795-2016a. Reporting no deviations.
07/22/2021	ROP SEMI 2 CERT	Compliance	ROP No. MI-ROP-B2795-2016a. Reporting no deviations.
07/22/2021	MACT (Part 63)	Compliance	40 CFR Part 63 Subpart ZZZ Semi-Annual Compliance report per FGPEAKERS VII.10.(63.6650 (f) VII.9(e) & VII.9(f). No deviations reported.
07/22/2021	On-site Inspection	Compliance	Routine inspection for compliance with MI-ROP-B2796-2016 as part of FCE.
03/04/2021	MAERS	Compliance	2020 MAERS received electronically. Audited 6/1. See MAERS for any comments.
09/24/2020	ROP Semi 1 Cert	Compliance	Semi-Annual Compliance report for MI-ROP-B2795-2016a. No deviations report.
09/24/2020	MACT (Part 63)	Compliance	40 CFR Part 63 Subpart ZZZ Semi-Annual Compliance report per FGPEAKERS VII.10.(63.6650 (f) VII.9(e) & VII.9(f). No deviations reported.

**Name:** Samantha Davis **Date:** 9/16/21 **Supervisor:** B.M.