

FCE B2798
ORANGE


DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : DTE - Electric Company DELRAY POWER PLANT	SRN : B2798
Location : 6603 W JEFFERSON	District : Detroit
	County : WAYNE
City : DETROIT State: MI Zip Code : 48217	Compliance Status : Compliance
Source Class : MAJOR	Staff : Jorge Acevedo
FCE Begin Date : 10/01/2014	FCE Completion Date : 9/9/15
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
08/12/2015	Scheduled Inspection	Compliance	
08/04/2015	Other Non ROP	Compliance	DTE Delray submitted their Ozone Season 2014 NOx Allowance Deduction report as required by R336.1805.
08/03/2015	Other Non ROP	Compliance	DTE Delray submitted their Annual Cair NOx Allowance Deduction report as required by R336.1805.
06/15/2015	ROP Other	Compliance	2014 MAERS ROP Certification Form
06/15/2015	ROP Annual Cert	Compliance	
06/15/2015	ROP SEMI 2 CERT	Compliance	
05/14/2015	Stack Test	Compliance	Stack Test Report- NOx averaged less than 15 PPM and CO averaged less than 64 lbs/hr.
05/05/2015	MAERS	Compliance	Verified emissions with what facility reported to EPA. Calculations appeared correct.
10/20/2014	ROP Semi 1 Cert	Compliance	

Name:  Date: 9/9/15 Supervisor: 