



COMPLIANCE TEST REPORT

for

QUARTERLY HYDROGEN CHLORIDE (HCL) EMISSIONS

EU-BOILER#3

(SRN: B2810)

1st Quarter 2021

**River Rouge Power Plant
River Rouge, Michigan**

February 15, 2021

**Prepared By:
Environmental Management & Safety
Environmental Field Services Group
DTE Corporate Services, LLC
7940 Livernois G4-S
Detroit, MI 48210**

CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	1
2.0 SOURCE DESCRIPTION	1
3.0 SAMPLING AND ANALYTICAL PROCEDURES	1
3.2 MOISTURE DETERMINATION (USEPA METHOD 4).....	2
3.2.1 Sampling Method.....	2
3.3 HYDROGEN CHLORIDE (USEPA METHOD 26A).....	2
3.3.1 HCl Sampling Method	2
3.3.2 Quality Control and Assurance.....	3
3.3.3 Data Reduction.....	3
4.0 OPERATING PARAMETERS.....	3
5.0 DISCUSSION OF RESULTS	4
6.0 CERTIFICATION STATEMENT	5

RESULTS TABLES

Table No. 1: HCl Emissions Testing Summary – EU-BOILER#3

FIGURES

- 1 Sampling Location – EU-BOILER#3
- 2 USEPA Method 26A Sampling Train

APPENDICES

- A Test Plan
- B Field Sampling Data
- C Process Operational Data
- D Example Calculations
- E Analytical Data
- F Calibration Data



EXECUTIVE SUMMARY

DTE Energy's Environmental Management and Safety (EM&S) Field Services Group performed 1st Quarter – 2021 Hydrogen Chloride (HCl) emissions testing on the exhaust of EU-BOILER#3 at the River Rouge Power Plant, located in River Rouge, Michigan. Testing is required by 40 CFR Part 63, Subpart UUUUU (Mercury and Air Toxics Standards - MATS) to document quarterly HCl stack emissions. Testing was conducted on February 15, 2021.

A summary of the emission test results is shown below:

Emissions Testing Summary River Rouge Power Plant EU-BOILER#3

Source	Date	Load (GMW)	HCl (lbs/MmBtu) ⁽¹⁾
EU-BOILER#3	2/15/21	54.5	0.0003

(1) MATS Limit 0.0020 lbs/MMBtu



1.0 INTRODUCTION

DTE Energy's Environmental Management and Safety (EM&S) Field Services Group performed 1st Quarter – 2021 Hydrogen Chloride (HCl) emissions testing on the exhaust of EU-BOILER#3 at the River Rouge Power Plant, located in River Rouge, Michigan. Testing was required by the 40 CFR Part 63, Subpart UUUUU (Mercury and Air Toxics Standards - MATS) to document quarterly HCl stack emissions. Testing was conducted on February 15, 2021.

The fieldwork was performed in accordance with EPA Reference Methods and DTE Energy Intent to Test¹. The following DTE Energy personnel participated in the testing program: Mr. Jason Logan, Environmental Specialist, and Mr. Mark Westerberg, Senior Environmental Specialist. Mr. Logan was the project leader.

2.0 SOURCE DESCRIPTION

The River Rouge Power Plant (RRPP), located at 1 Belanger Park Dr. River Rouge, Michigan, employs the use of one coal-fired boiler. EU-Boiler#3 is a Foster-Wheeler Boiler, nominally rated at 278 GMW. Particulate emissions from EU-Boiler#3 are controlled via a Wheelabrator-Fry electrostatic precipitator (ESP). The air pollution control equipment has a designed collection efficiency of 99.9%.

The boiler is equipped with a Dry Sorbent Injection (DSI) and Activated Carbon Injection (ACI) air quality control system. The DSI system is used to control acid gas, PM, PM10, PM2.5, and NOx emissions from the unit. Trona is received at the plant where inline mills further refine the Trona. The ACI system is used to control Mercury emissions. Currently, and at the time of testing, Boiler 3 is combusting natural gas, which does not require DSI or ACI injections to control emissions.

Testing was performed on EU-Boiler#3 while operating at normal load conditions, per Subpart UUUUU.

3.0 SAMPLING AND ANALYTICAL PROCEDURES

DTE Energy obtained emissions measurements in accordance with procedures specified in the USEPA *Standards of Performance for New Stationary Sources* or listed as an approved "Other Test Method". The sampling and analytical methods used in the testing program are indicated in the table below:

¹ Test Plan, Submitted October 2, 2020 (Attached-Appendix A)

Sampling Method	Parameter	Analysis
USEPA Method 4	Moisture Content	Field data analysis and reduction
USEPA Method 26A	Hydrogen Chloride	Ion Chromatography
USEPA Method 19	Emission Rate Calculations	Stoichiometric Calculations

3.2 MOISTURE DETERMINATION (USEPA Method 4)

3.2.1 Sampling Method

Determination of the moisture content of the exhaust gas was performed using the method described in USEPA Method 4, "Determination of Moisture Content in Stack Gases". The exhaust gas condensate was collected in glass impingers and the percentage of moisture was derived from calculations outlined in USEPA Method 4 as a component of the HCl sampling train.

3.3 HYDROGEN CHLORIDE (USEPA Method 26A)

3.3.1 HCl Sampling Method

USEPA Method 26A, "Determination of Hydrogen Halide and Halogen Emissions" was used to measure the Hydrochloric Acid (HCl) emissions (see Figure 2 for a schematic of the sampling train). Method 26A uses impingers containing 0.1N H₂SO₄ to capture the HCl. Triplicate, 60-minute test runs were conducted. Method 26A sampling was performed as a single point sample per Method 26 procedures.

The Method 26A stack sampling system (Figure 2) consisted of the following:

- (1) Heated glass-lined probe (Maintained 248 °F > T > 273 °F)
- (2) Heated 3" glass filter holder with a PTFE filter (maintained at a temperature of 248 °F > T > 273 °F)
- (3) Set of impingers for the collection HCl and condensate for moisture determination (Impingers containing 0.1N H₂SO₄)
- (4) Length of sample line
- (5) Environmental Supply® control case equipped with a pump, dry gas meter, and calibrated orifice.

After completion of each run, a leak test was conducted. All the impingers were measured for moisture gain. The contents of impingers 1 and 2 were collected in a

designated sample container. Impingers 1 and 2, the back half of the filter holder, the Z-fitting connecting the filter holder to the first impinger, and the U-tube between the first and second impingers were then rinsed with DI water and collected in the same sample container. Each container was labeled with the test number, test location, test date, and the level of liquid marked on the outside of the container. Immediately after recovery, the sample containers were placed in a cooler for storage.

Collected field blanks consisted of a 0.1N H₂SO₄ solution blank. 200ml of 0.1N H₂SO₄ was collected and diluted with DI water, from the same bottle used in sample recovery, to the liquid level of the three test runs. The blank was collected and analyzed following the same procedures used to recover and analyze the field samples.

Analysis of the Method 26A samples and blanks were conducted by Enthalpy Analytical. All analysis followed the procedures listed in USEPA Method 26A. A complete laboratory report is in Appendix E.

Field data sheets for the Method 26A sampling are in Appendix B.

3.3.2 Quality Control and Assurance

All sampling and analytical equipment was calibrated per the guidelines referenced in EPA Method 5 and 26A.

3.3.3 Data Reduction

HCl emissions data collected during the testing were calculated and reported as parts per million (ppm) and pounds per million Btu (lb/MMBtu). Pounds per million BTU was calculated using the wet CO₂ and fuel factor (F_c) averages from the DAHS for each test period and eq. 19-7 in Method 19.

Analysis of the Method 26A samples and blanks were conducted by Enthalpy Analytical. All analyses followed the procedures listed in USEPA Method 26A. A complete laboratory report is in Appendix E.

Field data sheets for the Method 26A sampling are in Appendix B.

4.0 OPERATING PARAMETERS

The test program included the collection of boiler load and stack emissions CEMs data during each test run. Parameters recorded included gross Megawatts (GMW), CO₂ (%), and the plant specific fuel factor (F_c). Operational Data collected during the testing is presented in Appendix C.



HCl emissions testing was performed at normal operating load and representative of site specific normal operating conditions according to 40 CFR part 63.10007.

5.0 DISCUSSION OF RESULTS

Table 1 presents the HCl emission testing results from EU-BOILER#3. HCl emissions are presented in parts per million on a wet basis (ppm_w) and pounds per million BTU (lb/MMBtu). The EU-BOILER#3 HCl emissions during the testing demonstrated an average HCl concentration of 0.09 ppm and 0.0003 lb/MMBtu . The average EU-BOILER#3 HCl emissions were within the Subpart UUUUU limit of 0.0020 lb/MMBtu .

The auxiliary test data presented in the results table for each test includes the unit load in gross megawatts (GMW) and CO_2 concentration ($\%_{wet}$).

RECEIVED

MAR 12 2021

AIR QUALITY DIVISION

6.0 CERTIFICATION STATEMENT

"I certify that I believe the information provided in this document is true, accurate, and complete. Results of testing are based on the good faith application of sound professional judgment, using techniques, factors, or standards approved by the Local, State, or Federal Governing body, or generally accepted in the trade."



Mr. Jason Logan, QSTI

This report prepared by: _____



Mr. Jason Logan, QSTI
Environmental Specialist, Field Services Group
Environmental Management and Safety
DTE Energy Corporate Services, LLC

This report reviewed by: _____



Mr. Mark Grigereit, QSTI
Principal Engineer, Field Services Group
Environmental Management and Safety
DTE Energy Corporate Services, LLC

DTE

RESULTS TABLES




TABLE NO. 1
HYDROGEN CHLORIDE EMISSIONS TESTING RESULTS
River Rouge Power Plant - Unit 3
February 15, 2021


Test	Test Date	Test Time	Unit Load (GMW)	CO ₂ Concentration (% wet)	HCl Concentration (ppmv wet)	HCl Emissions (lbs/MMBtu) ⁽¹⁾
HCl-1	15-Feb-21	11:02-12:02	54	2.6	0.07	0.0002
HCl-2		12:18-13:18	55	2.7	0.09	0.0003
HCl-3		13:33-14:33	<u>55</u>	<u>2.7</u>	<u>0.10</u>	<u>0.0003</u>
		<i>Average:</i>	<i>55</i>	<i>2.7</i>	<i>0.09</i>	<i>0.0003</i>

(1) MATS Limit = 0.0020 lb/MMBtu

DTE


FIGURES

Figure 1 – Sampling Location
River Rouge Power Plant – EU-BOILER#3
May 28, 2020



DTE

Figure 2 – USEPA Method 26A (Modified)
- River Rouge Power Plant



DTE

APPENDIX A

TEST PLAN