

October 10, 2022

Lindsey Wells  
EGLE, Air Quality Division  
Constitution Hall, 2nd Floor South  
525 West Allegan Street  
Lansing, Michigan 48933

Jenine Camilleri  
EGLE, Air Quality Division  
Constitution Hall, 2nd Floor South  
525 West Allegan Street  
Lansing, Michigan 48933

RECEIVED

OCT 13 2022

AIR QUALITY DIVISION

Subject: Response to Violation Notice Dated September 19, 2022  
MI-ROP-B2876-2019a  
Michigan Sugar Company – Crosswell Factory

Dear Ms. Wells and Ms. Camilleri,

MSC is in receipt of the violation issued by EGLE on September 19, 2022. MSC's response is as follows. MSC completed operations of beet processing on March 29, 2022 at approximately 8:00 am. MSC anticipated that the shutdown process would be completed on or before Midnight of 3/31/22.

However, in order to complete the shutdown in a manner that would not cause more harm to the environment, the process could not be completed until approximately 10:00 am on 4/1/22. Please note that this was only 10 hours in to the second quarter and during those hours the boiler was only in shutdown mode, because of this, MSC did not believe that a CGA was necessary or appropriate. Moreover, MSC did in fact calibrate the monitor and continuously monitor emissions during the 10-hour period.

Please feel free to contact me with any questions or comments of the forgoing.

Sincerely,



Meaghan Martuch  
Air Compliance Manager  
Michigan Sugar Company  
Office: 989-686-0161, ext. 2236  
Cell: 989-780-2550

B2876-RVN-20221013