

# FINAL REPORT



RECEIVED

MAY 03 2023

AIR QUALITY DIVISION

## GENERAL MOTORS LLC GM TECHNICAL CENTER

WARREN, MICHIGAN

### 2023 RELATIVE ACCURACY TESTING AUDIT (RATA) SOURCE TESTING REPORT: EU-BOILER1, EU-BOILER2, AND EU-BOILER3

RWDI #2302580

April 20, 2023

#### SUBMITTED TO

**TPU Supervisor**  
Michigan Department of Environment, Great Lakes  
and Energy  
Air Quality Division Technical  
Programs Unit (TPU)  
Constitution Hall 2<sup>nd</sup> Floor, South  
525 West Allegan Street  
Lansing, Michigan 48909-7760

**Joyce Zhu**  
Michigan Department of Environment, Great Lakes  
and Energy (EGLE) Air Quality Division  
Air Quality District Manager  
27700 Donald Court  
Warren, Michigan 48092-2793

**Hunter Lyons**  
Environmental Engineer  
Hunter.1.Lyons@gm.com

**General Motors LLC**  
Global Technical Center  
30001 VanDyke Avenue  
Warren, Michigan 48093

#### SUBMITTED BY

**Ben Durham**  
Senior Field Technician  
Ben.Durham@rwdi.com

**Steve Smith, B.Sc., QSTI**  
Project Manager  
Steve.Smith@rwdi.com

**Brad Bergeron, A.Sc.T., D.E.T.**  
Project Director  
Brad.Bergeron@rwdi.com

**RWDI USA LLC**  
Consulting Engineers & Scientists  
2239 Star Court  
Rochester Hills, Michigan 48309

T: 248.841.8442  
F: 519.823.1316

B4049\_test\_20230314



rwdi.com

© 2023 RWDI USA LLC ("RWDI") ALL RIGHTS RESERVED.  
This document is intended for the sole use of the party to whom it is addressed and may contain information that is privileged  
and/or confidential. If you have received this in error, please notify us immediately. Accessible document formats provided upon request.  
© RWDI name and logo are registered trademarks in Canada and the United States of America.



# EXECUTIVE SUMMARY

RWDI USA LLC (RWDI) was retained by General Motors, LLC (GM) to complete the Relative Accuracy Testing Audit (RATA) emission sampling program at the General Motors Technical Center in Warren, Michigan. The test program was conducted to fulfill the requirements of the Michigan Department of Environment, Great Lakes and Energy (EGLE) MI-ROP-B4049-2019 in accordance with Appendix A, 40 CFR, Part 60, Subpart Db, US EPA Reference Methods 3A and 7E found in 40 CFR, Part 60, Appendix A, and Performance Specifications (PS) 2, 3, and 16 specified by 40 CFR, Part 60, Appendix B. The pollutants tested include oxygen (O<sub>2</sub>) and nitrogen oxides (NO<sub>x</sub>) from EU-BOILER1, EU-BOILER2, and EU-BOILER3

**Executive Summary Table i: Summary of Results – EU-BOILER1 – March 16, 2023**

Parameter	EU-BOILER1		
	Oxides of Nitrogen (ppm)	Oxides of Nitrogen (lb/MMBTU)	Oxygen (%)
<b>Relative Accuracy (RA)</b> (Mean Difference from RM %)	7.4% (Limit 20%)	8.0% (Limit 20%)	11.4% (Limit 20%)
<b>Relative Accuracy (RA)</b> (Absolute Difference from RM Concentration)	0.41	0.0007	0.40% (Limit 1%)
<b>Bias Present?</b>	No	Yes	Yes
<b>Bias Factor</b>	N/A	0.97	1.12

**Notes:** The average data is based on 9 of the 10 runs conducted on each source.

**Executive Summary Table ii: Summary of Results – EU-BOILER2 – March 15, 2023**

Parameter	EU-BOILER2		
	Oxides of Nitrogen (ppm)	Oxides of Nitrogen (lb/MMBTU)	Oxygen (%)
<b>Relative Accuracy (RA)</b> (Mean Difference from RM %)	1.5% (Limit 20%)	2.3% (Limit 20%)	12.6% (Limit 20%)
<b>Relative Accuracy (RA)</b> (Absolute Difference from RM Concentration)	0.04	0.0002	0.34% (Limit 1%)
<b>Bias Present?</b>	No	Yes	Yes
<b>Bias Factor</b>	N/A	0.98	0.91

**Notes:** The average data is based on 9 of the 10 runs conducted on each source.



**Executive Summary Table iii: Summary of Results - EUBOILER3 - March 14, 2023**

Parameter	EU-BOILER3		
	Oxides of Nitrogen (ppm)	Oxides of Nitrogen (lb/MMBTU)	Oxygen (%)
Relative Accuracy (RA) (Mean Difference from RM %)	2.2% (Limit 20%)	1.1% (Limit 20%)	8.4% (Limit 20%)
Relative Accuracy (RA) (Absolute Difference from RM Concentration)	0.43	0.0001	0.28% (Limit 1%)
Bias Present?	Yes	Yes	Yes
Bias Factor	1.01	1.00	0.93

**Notes:** The average data is based on 9 of the 10 runs conducted on each source.



# TABLE OF CONTENTS

<b>1.</b>	<b>INTRODUCTION</b> .....	<b>1</b>
1.1	Location and Dates of Testing.....	1
1.2	Purpose of Testing.....	1
1.3	Description of Source .....	1
1.4	Personnel Involved in Testing .....	2
<b>2.</b>	<b>SUMMARY OF RESULTS</b> .....	<b>2</b>
2.1	Operating Data.....	2
2.2	Applicable Permit Number .....	2
<b>3.</b>	<b>SOURCE DESCRIPTION</b> .....	<b>3</b>
3.1	Description of Process and Emission Control Equipment.....	3
3.2	Predictive Emission Monitors (PEMS) Specifications.....	3
3.3	Process Flow Sheet or Diagram .....	3
3.4	Type and Quantity of Raw and Finished Materials.....	3
3.5	Normal Rated Capacity of Process.....	3
3.6	Process Instrumentation Monitored During the Test.....	4
<b>4.</b>	<b>SAMPLING AND ANALYTICAL PROCEDURES</b> .....	<b>4</b>
4.1	Relative Accuracy Testing Audit (RATA) NO <sub>x</sub> and O <sub>2</sub> .....	4
4.2	EPA Method 3A, and 7E (O <sub>2</sub> , and NO <sub>x</sub> ).....	5
4.3	Nitrogen Oxides Emission Rate Calculation (US EPA Methods 19).....	5
4.4	Description of Recovery and Analytical Procedures .....	6
4.5	Sampling Port Description.....	6
4.6	Internal Quality Assurance.....	6



<b>5. TEST RESULTS AND DISCUSSION .....</b>	<b>6</b>
5.1 Results Summary.....	6
5.2 Discussion of Results.....	7
5.3 Variations in Testing Procedures.....	7
5.4 Process Upset Conditions During Testing.....	7
5.5 Maintenance Performed in Last Three Months.....	8
5.6 Re-Test.....	8
5.7 Audit Samples.....	8
5.8 Flows and Moisture.....	8
5.9 Calibration Data.....	8
5.10 Process Data.....	8
5.11 Example Calculations.....	8
5.12 Laboratory Data.....	8
<b>6. CONCLUSIONS .....</b>	<b>8</b>

## LIST OF TABLES

(Found Within The Report Text)

<b>Executive Summary Table i:</b>	Summary of Results – EU-BOILER1 – March 16, 2023.....	Executive Summary
<b>Executive Summary Table ii:</b>	Summary of Results – EU-BOILER2 – March 15, 2023.....	Executive Summary
<b>Executive Summary Table iii:</b>	Summary of Results – EU-BOILER3 – March 14, 2023.....	Executive Summary
<b>Table 1.4.1:</b>	Testing Personnel.....	2
<b>Table 3.2.1:</b>	Summary of PEMS Units.....	3
<b>Table 5.1.1:</b>	Summary of Results – EU-BOILER1 – March 16, 2023.....	6
<b>Table 5.1.2:</b>	Summary of Results – EU-BOILER2 – March 15, 2023.....	7
<b>Table 5.1.3:</b>	Summary of Results – EU-BOILER3 – March 14, 2023.....	7



## LIST OF TABLES

(Found After The Report Text)

<b>Table 1:</b>	Summary of Sampling Parameters and Methodology
<b>Table 2A:</b>	Sampling Summary – EU-BOILER1
<b>Table 2B:</b>	Sampling Summary – EU-BOILER2
<b>Table 2C:</b>	Sampling Summary – EU-BOILER3
<b>Table 3:</b>	EU-BOILER1: RATA Results
<b>Table 4:</b>	EU-BOILER2: RATA Results
<b>Table 5:</b>	EU-BOILER3: RATA Results

## LIST OF FIGURES

<b>Figure 1:</b>	USEPA Method 3A and 7E Schematic
------------------	----------------------------------

## LIST OF APPENDICES

<b>Appendix A:</b>	EU-BOILER1: RATA Results
<b>Appendix A1:</b>	Reference Method CEM Results – EU-BOILER1
<b>Appendix A2:</b>	GM PEMS Results – EU-BOILER1
<b>Appendix B:</b>	EU-BOILER2: RATA Results
<b>Appendix B1:</b>	Reference Method CEM Results – EU-BOILER2
<b>Appendix B2:</b>	GM PEMS Results – EU-BOILER2
<b>Appendix C:</b>	EU-BOILER3: RATA Results
<b>Appendix C1:</b>	Reference Method CEM Results – EU-BOILER3
<b>Appendix C2:</b>	GM PEMS Results – EU-BOILER3
<b>Appendix D:</b>	Calibration Data
<b>Appendix E:</b>	Field Notes
<b>Appendix E1:</b>	Field Notes – EU-BOILER1
<b>Appendix E2:</b>	Field Notes – EU-BOILER2
<b>Appendix E3:</b>	Field Notes – EU-BOILER3
<b>Appendix F:</b>	Example Calculations
<b>Appendix G:</b>	EGLE Approval Letter & Source Testing Plan



# 1. INTRODUCTION

RWDI USA LLC (RWDI) was retained by General Motors LLC (GM) to complete the Relative Accuracy Testing Audit (RATA) emission sampling program at the General Motors Technical Center in Warren, Michigan. The test program was conducted to fulfill the requirements of the Michigan Department of Environment, Great Lakes and Energy (EGLE) MI-ROP-B4049-2019a in accordance with Appendix A, 40 CFR, Part 60, Subpart Db, US EPA Reference Methods 3A and 7E found in 40 CFR, Part 60, Appendix A, and Performance Specifications (PS) 2, 3, and 16 specified by 40 CFR, Part 60, Appendix B. The pollutants tested include oxygen (O<sub>2</sub>) and nitrogen oxides (NO<sub>x</sub>) from EU-BOILER1, EU-BOILER2, and EU-BOILER3.

## 1.1 Location and Dates of Testing

The test program was completed on March 14 to 16, 2023 at the GM Technical Center.

## 1.2 Purpose of Testing

The emissions test program is required by EGLE permit number MI-ROP-N4049-2019a. The facility SRN number is N4049. This report outlines the results for the 2023 RATA for EU-BOILER1, EU-BOILER2 and EU-BOILER3.

## 1.3 Description of Source

The General Motors Technical Center located in Warren, Michigan has three boilers that are capable of firing natural gas. Each of the boilers has an input capacity of 108 MMBtu/hr while firing NG. The steam from the boilers is utilized as process steam. Low-NO<sub>x</sub> burners minimize the emissions of nitrogen oxides from the boilers.

**RECEIVED**

**MAY 03 2023**

**AIR QUALITY DIVISION**



## 1.4 Personnel Involved in Testing

**Table 1.4.1:** Testing Personnel

<b>Hunter Lyons</b> Environmental Engineer	<b>General Motors – Global Technical Center</b> 30001 Van Dyke Ave Warren, MI 48093	(586) 506-4046
<b>Matt Perko</b> Environmental Engineer	<b>General Motors – Global Technical Center</b> 30001 Van Dyke Ave Warren, MI 48093	(586) 242-6763
<b>Andrew Riley</b> Air Quality Division	State of Michigan Department of Environment, Great Lakes & Energy (EGLE)	(586) 565-7379
<b>Steve Smith</b> Project Manager	<b>RWDI USA LLC</b> 2239 Star Court Rochester Hills, MI 48309	(734) 751-9701
<b>Ben Durham</b> Senior Field Technician		(734) 474-1731
<b>Cade Smith</b> Field Technician		(734) 552-7270

## 2. SUMMARY OF RESULTS

### 2.1 Operating Data

Operational data collected during the testing includes:

- Heat Input (MMBTU/hr)
- Boiler steam load (klbs/hr)
- NO<sub>x</sub> ppm concentration (ppm<sub>vd</sub>)
- NO<sub>x</sub> ppm emission rate (lbs/MMBTU)
- O<sub>2</sub> ppm concentration (%)

This information can be found in **Appendices A, B and C**, respectively for EU-BOILER1, EU-BOILER2 and EU-BOILER3.

### 2.2 Applicable Permit Number

MI-ROP-N4049-2019a



### 3. SOURCE DESCRIPTION

#### 3.1 Description of Process and Emission Control Equipment

The General Motors Technical Center located in Warren, Michigan has three boilers that are capable of firing natural gas. Each of the boilers has an input capacity of 108 MMBtu/hr while firing NG. The steam from the boilers is utilized as process steam. Low-NOx burners minimize the emissions of nitrogen oxides from the boilers.

#### 3.2 Predictive Emission Monitors (PEMS) Specifications

The SmartCEMS 60 Predictive Emissions Monitoring System (PEMS) provides continuous data recording and report generation for compliance with 40 CFR Part 60 regulations. The data acquisition system provides a secure and reliable means of collecting and retrieving compliance data. This application has been customized to meet the requirements of gas-fired boiler under 40 CFR Part 60, Subpart Db; and as a PEMS, an alternative to continuous emissions monitoring under 40 CFR Part 60, Performance Specification 16 for Predictive Emissions Monitoring Systems (PS-16).

Table 3.2.1: Summary of PEMS Units

	EU-BOILER1, EU-BOILER2, EU-BOILER3
NOx (PS-2) Limit	Less than 20% of RM or 10% of AS – ppmvd Less than 20% of RM or 10% of AS – lb/MMBtu
O <sub>2</sub> (PS-3) Limit	Less than 20% of RM or 1% Difference
PEMS Unit O <sub>2</sub>	CMC Solutions – SmartCEMS-60 – GMBL 122042
PEMS Unit NOx	CMC Solutions – SmartCEMS-60 – GMBL 122041

#### 3.3 Process Flow Sheet or Diagram

Each boiler has a single outlet. A process flow diagram can be provided if requested.

#### 3.4 Type and Quantity of Raw and Finished Materials

Each boiler is fired by natural gas.

#### 3.5 Normal Rated Capacity of Process

Each boiler has a maximum heat input rating of 108 MMBTU/hr. Each test was completed with the boilers (EU-BOILER1, EU-BOILER2 and EU-BOILER3) operating at greater than 50% capacity for each test. Process data is provided in **Appendices A, B, and C.**



### 3.6 Process Instrumentation Monitored During the Test

The following process instrumentation data was monitored during each test:

- Heat Input (MMBTU/hr)
- Boiler steam load (klbs/hr)
- NO<sub>x</sub> ppm concentration (ppm<sub>vd</sub>)
- NO<sub>x</sub> ppm emission rate (lbs/MMBTU)
- O<sub>2</sub> ppm concentration (%)

This information can be found in **Appendices A, B and C**, respectively for EU-BOILER1, EU-BOILER2 and EU-BOILER3.

## 4. SAMPLING AND ANALYTICAL PROCEDURES

The following test methods were referenced in the test program. These methods can be found in 40 CFR, Part 60, Appendix A and B.

- **Method 3A:** Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources
- **Method 7E:** Determination of Nitrogen Oxides Emissions from Stationary Sources
- **Method 19:** Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates
- **Performance Specification 2:** Specifications and Test Procedures for SO<sub>2</sub> and NO<sub>x</sub> Continuous Emission Monitoring Systems in Stationary Sources
- **Performance Specification 3:** Specifications and Test Procedures for O<sub>2</sub> Continuous Emission Monitoring Systems in Stationary Sources
- **Performance Specification 16:** Specifications and Test Procedures for Predictive Emission Monitoring Systems in Stationary Sources

### 4.1 Relative Accuracy Testing Audit (RATA) NO<sub>x</sub> and O<sub>2</sub>

To satisfy the NO<sub>x</sub> data accuracy requirement, the relative accuracy results of a minimum of nine performance test runs must meet the criteria outlined in section 8.4.4 of the US EPA PS 2 for NO<sub>x</sub> and PS 3 for O<sub>2</sub>. A 21-minute period was used for each run. As per Performance Specification 2, traverse points were located at 16.7, 50.0, and 83.3 percent of the stack diameter. Each point was sampled at for 7 minutes in duration for each RATA run.

Prior to the RATA, a NO<sub>2</sub>-to-NO conversion efficiency check was performed. It met the criteria of ≥ 90%. Also prior to the RATA, an interference response test was performed on the analyzer used for this test program. The heated sample lines were operated at 250°F to avoid a buildup of condensation.



## 4.2 EPA Method 3A, and 7E (O<sub>2</sub>, and NO<sub>x</sub>)

A three-point (zero, mid-, and high-range) analyzer calibration error check was conducted on each reference analyzer before initiating the relative accuracy testing. This check was conducted (after final calibration adjustments are made) by injecting the calibration gases directly into each gas analyzer and recording the responses.

Zero and upscale calibration checks are conducted both before and after each test run to quantify measurement system calibration drift and sampling system bias. Upscale is either the mid- or high-range gas, whichever most closely approximates the flue gas level. During these checks, the calibration gases are introduced into the sampling system at the probe outlet so that the calibration gases are analyzed in the same manner as the flue gas samples.

A gas sample was continuously extracted from the stack and delivered to a series of gas analyzers, which measured the pollutant or diluent concentrations in the gas. The analyzers were calibrated on-site using EPA Protocol No. 1 certified calibration mixtures. The probe tip was equipped with a sintered stainless-steel filter for particulate removal. The end of the probe was connected to a heated Teflon sample line, which delivered the sample gases from the stack to the CEMs system. The heated sample line was designed to maintain the gas temperature above 250°F to prevent condensation of stack gas moisture within the line.

Before entering the analyzers, the gas sample passed directly into a refrigerated condenser, which cooled the gas to approximately 35°F to remove the stack gas moisture. After passing through the condenser, the dry gas entered a Teflon-head diaphragm pump and a flow control panel, which delivered the gas in series to the O<sub>2</sub> and NO<sub>x</sub> analyzer. This analyzer measured the respective gas concentrations on a dry volumetric basis.

## 4.3 Nitrogen Oxides Emission Rate Calculation (US EPA Methods 19)

USEPA Method 19, "Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates," was utilized to calculate a NO<sub>x</sub> emission factor based on Oxygen concentrations and appropriate F-factors. Equation 19-1 from the method was used. Table 19-1 was also used to determine the conversion factor for concentration ( $1.194 \times 10^{-7}$ ) for NO<sub>x</sub>. Table 19-2 was used for the F-Factor (natural gas 8,710 dscf/10<sup>6</sup> BTU).

$$E = (1.194 \times 10^{-7}) \times C_d \times F_d \times ((20.9 / (20.9 - \%O_{2d}))$$

Where:

E = Pollutant Emission Rate (lb/10<sup>6</sup> BTU)

C<sub>d</sub> = Pollutant Concentration, Dry Basis (ppm)

F<sub>d</sub> = Fuel Factor, Dry Basis (dscf/10<sup>6</sup> BTU)

%O<sub>2d</sub> = Oxygen Concentration, Dry Basis (%)

RECEIVED

MAY 03 2023

AIR QUALITY DIVISION

Page 5



## 4.4 Description of Recovery and Analytical Procedures

There were no samples to recover during this test program. All testing used real time data from the analyzers.

## 4.5 Sampling Port Description

All sampling ports meet USEPA Method 1 locations, not flow measurements were taken as emissions were determined via US EPA Method 19.

## 4.6 Internal Quality Assurance

Quality control procedures specific to the CEMS includes linearity checks to determine the instrument performance and reproducibility prior to its use in the testing program. Regular performance checks on the analyzers were also carried out during the testing program by performing zero and span calibration checks using EPA Protocol 1 gas standards. Sample system bias checks were also conducted. These checks were used to verify the ongoing precision of the monitor and sampling system over time. Pollutant-free nitrogen was introduced to perform the zero checks, followed by a known calibration (span) gas into the monitor. The response of the monitor to pollutant-free air and the corresponding sensitivity to the span gas was be recorded regularly during the tests. These records can be found in **Appendix E**.

# 5. TEST RESULTS AND DISCUSSION

## 5.1 Results Summary

**Table 5.1.1:** Summary of Results – EUBOILER1 – March 16, 2023

Parameter	EU-BOILER1		
	Oxides of Nitrogen (ppm)	Oxides of Nitrogen (lb/MMBTU)	Oxygen (%)
Relative Accuracy (RA) (Mean Difference from RM %)	7.4% (Limit 20%)	8.0% (Limit 20%)	11.4% (Limit 20%)
Relative Accuracy (RA) (Absolute Difference from RM Concentration)	0.41	0.0007	0.40% (Limit 1%)
Bias Present?	No	Yes	Yes
Bias Factor	N/A	0.97	1.12

**Notes:** The average data is based on 9 of the 10 runs conducted on each source.



**Table 5.1.2:** Summary of Results – EUBOILER2 – March 15, 2023

Parameter	EU-BOILER2		
	Oxides of Nitrogen (ppm)	Oxides of Nitrogen (lb/MMBTU)	Oxygen (%)
Relative Accuracy (RA) (Mean Difference from RM %)	1.5% (Limit 20%)	2.3% (Limit 20%)	12.6% (Limit 20%)
Relative Accuracy (RA) (Absolute Difference from RM Concentration)	0.04	0.0002	0.34% (Limit 1%)
Bias Present?	No	Yes	Yes
Bias Factor	N/A	0.98	0.91

**Notes:** The average data is based on 9 of the 10 runs conducted on each source.

**Table 5.1.3:** Summary of Results – EUBOILER3 – March 14, 2023

Parameter	EU-BOILER3		
	Oxides of Nitrogen (ppm)	Oxides of Nitrogen (lb/MMBTU)	Oxygen (%)
Relative Accuracy (RA) (Mean Difference from RM %)	2.2% (Limit 20%)	1.1% (Limit 20%)	8.4% (Limit 20%)
Relative Accuracy (RA) (Absolute Difference from RM Concentration)	0.43	0.0001	0.28% (Limit 1%)
Bias Present?	Yes	Yes	Yes
Bias Factor	1.01	1.00	0.93

**Notes:** The average data is based on 9 of the 10 runs conducted on each source.

## 5.2 Discussion of Results

Detailed results for each unit can be found in **Appendices A, B, and C**. Calibration documentation can be found in **Appendix D**. The calibration records for the Teledyne T200H NO<sub>x</sub> and O<sub>2</sub> analyzer, in compliance with USEPA Methods 3A and 7E, can be found in **Appendix A, B, C, and E**. BOILER OPERATING CONDITIONS

Operating conditions during the sampling were monitored by GM personnel. Testing was performed while each of the boilers operated at greater than 50% load. Contact was kept between RWDI and boiler operators to ensure the boiler was running at all times during the testing.

## 5.3 Variations in Testing Procedures

There were no sampling variations.

## 5.4 Process Upset Conditions During Testing

There were normal operation of each boiler during the testing.



## 5.5 Maintenance Performed in Last Three Months

Normal general maintenance to boilers were completed.

## 5.6 Re-Test

This was not a retest.

## 5.7 Audit Samples

This test did not require any audit samples.

## 5.8 Flows and Moisture

No flow and moisture data was collected.

## 5.9 Calibration Data

Calibration data can be found in **Appendices A, B, C, and D**.

## 5.10 Process Data

Process data can be found in **Appendices A, B and C**.

## 5.11 Example Calculations

Example calculations can be found in **Section 4.3 and Appendix F**.

## 5.12 Laboratory Data

There was no laboratory data from this testing program.

# 6. CONCLUSIONS

The purpose of the study was to perform 2023 RATA on the PEMS for EU-BOILER1, EU-BOILER2 and EU-BOILER3. PEMS determine concentrations for NO<sub>x</sub> and O<sub>2</sub> and NO<sub>x</sub> emission rate. All analyzers meet the relative accuracy requirements set out in Performance Specification in 40 CFR 60, Appendix B.

# TABLES



**Table 1: Summary of Sampling Parameters and Methodology**

Source Location	No. of Tests per Stack	Sampling Parameter	Sampling Method
EU-BOILER1	10	O <sub>2</sub>	U.S. EPA [1] Method 3A
	10	NO <sub>x</sub>	U.S. EPA [1] Method 7E
EU-BOILER2	10	O <sub>2</sub>	U.S. EPA [1] Method 3A
	10	NO <sub>x</sub>	U.S. EPA [1] Method 7E
EU-BOILER3	10	O <sub>2</sub>	U.S. EPA [1] Method 3A
	10	NO <sub>x</sub>	U.S. EPA [1] Method 7E

**Notes:**

[1] U.S. EPA - United States Environmental Protection Agency

**Table 2A: Sampling Summary - EU-BOILER1**

Test #	Sampling Date	Start Time	End Time
1	16-Mar-23	8:05	8:25
2		8:35	8:55
3		9:07	9:27
4		9:38	9:58
5		10:11	10:31
6		10:43	11:03
7		11:16	11:36
8		11:48	12:08
9		12:19	12:39
10		12:50	13:10

**Table 2B: Sampling Summary - EU-BOILER2**

Test #	Sampling Date	Start Time	End Time
1	15-Mar-23	7:45	8:05
2		8:15	8:35
3		8:46	9:06
4		9:17	9:37
5		9:48	10:08
6		10:18	10:38
7		10:48	11:08
8		11:34	11:54
9		12:04	12:24
10		12:35	12:55

**Table 2C: Sampling Summary - EU-BOILER3**

Test #	Sampling Date	Start Time	End Time
1	14-Mar-23	8:00	8:20
2		8:30	8:50
3		9:06	9:26
4		9:38	9:58
5		10:07	10:27
6		10:36	10:56
7		11:07	11:27
8		11:38	11:58
9		12:09	12:29
10		12:40	13:00

**Table 3: EU-BOILER1: RATA Results**

Date: Thursday, March 16, 2023

Test	RWDI Time		NOx				O <sub>2</sub>				Emission Rate			Load Steam (klb/hr)	Heat Input (MMBTU/hr)
	Start Time	End Time	RM (dppm)	RM (corppm)	PEMS (ppm)	di (ppm)	RM (d%)	RM (cor%)	PEMS (%)	di (%)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/MMBTU)		
1	8:05	8:25	18.33	18.38	20.71	-2.33	3.72	3.70	3.30	0.4	0.0232	0.0260	-0.0028	65.16	76.30
2	8:35	8:55	18.65	18.53	20.89	-2.36	3.63	3.64	3.30	0.3	0.0233	0.0260	-0.0027	62.61	73.67
3	9:07	9:27	<b>18.45</b>	<b>18.34</b>	<b>20.81</b>	<b>-2.47</b>	3.70	3.73	3.30	0.4	0.0232	0.0260	-0.0028	61.95	73.01
4	9:38	9:58	20.47	20.47	20.13	0.34	3.82	3.83	3.50	0.3	0.0261	0.0250	0.0011	53.79	66.06
5	10:11	10:31	20.92	20.86	19.63	1.23	3.87	3.87	3.50	0.4	0.0266	0.0250	0.0016	49.73	62.33
6	10:43	11:03	20.48	20.40	20.64	-0.24	<b>3.96</b>	<b>3.97</b>	<b>3.50</b>	<b>0.5</b>	0.0262	0.0260	0.0002	52.29	64.83
7	11:16	11:36	19.99	19.93	20.77	-0.84	3.90	3.90	3.50	0.4	0.0255	0.0260	-0.0005	54.20	66.39
8	11:48	12:08	19.96	19.89	20.99	-1.10	3.94	3.93	3.50	0.4	0.0255	0.0260	-0.0005	53.99	66.22
9	12:19	12:39	20.16	20.09	20.82	-0.73	3.94	3.92	3.50	0.4	0.0257	0.0260	-0.0003	53.30	65.71
10	12:50	13:10	21.32	21.49	19.16	2.33	4.10	4.08	3.60	0.5	<b>0.0278</b>	<b>0.0240</b>	<b>0.0038</b>	49.05	62.26
<b>AVERAGE</b>			-	20.01	20.42	-0.41	-	3.8	3.4	0.4	0.0250	0.0258	-0.0007	55.61	67.68
<b>STDS</b>			-	1.01	0.64	1.39	-	0.14	0.11	0.05	0.00138	0.00044	0.00166	-	-
<b>n</b>			9				9				9				
<b>Full Scale</b>			89.8				21				-				
<b>t<sub>0.975</sub></b>			2.306				2.306				2.306				
<b>  d  </b>			0.41				0.40				0.0007				
<b>  cc  </b>			1.07				0.04				0.0013				
<b>Bias present? ( d  &gt;  cc )</b>			<b>no bias</b>				<b>bias present</b>				<b>bias present</b>				
<b>Bias Factor</b>			<b>0.98</b>				<b>1.12</b>				<b>0.97</b>				
<b>Relative Accuracy (20% limit)</b>			<b>7.4%</b>				<b>11.4%</b>				<b>8.0%</b>				

Notes:

RM = Reference Method (RWDI measurements)  
 PEMS = Predictive Emission Monitor System (GM data)  
 di = Difference between PEMS and RM for each point  
 n = number of tests  
 | d | = Absolute mean difference between the PEMS and RM results  
**Bolded test runs were not used in the RA calculation**

**Table 4: EU-BOILER2: RATA Results**

Date: Wednesday, March 15, 2023

Test	RWDI Time		NOx				O <sub>2</sub>				Emission Rate			Load Steam (klb/hr)	Heat Input (MMBTU/hr)
	Start Time	End Time	RM (dppm)	RM (corppm)	PEMS (ppm)	di (ppm)	RM (d%)	RM (cor%)	PEMS (%)	di (%)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/MMBTU)		
1	7:45	8:05	25.54	25.93	26.50	-0.57	3.28	3.37	3.60	-0.2	0.0321	0.0330	-0.0009	58.94	65.57
2	8:15	8:35	25.45	25.90	26.43	-0.53	3.35	3.44	3.70	-0.3	0.0322	0.0330	-0.0008	55.70	64.52
3	8:46	9:06	25.29	25.92	26.19	-0.27	3.37	3.47	3.70	-0.2	0.0323	0.0330	-0.0007	56.96	63.86
4	9:17	9:37	25.40	26.12	26.32	-0.20	3.31	3.43	3.70	-0.3	0.0325	0.0330	-0.0005	56.85	63.88
5	9:48	10:08	25.10	25.85	25.54	0.31	3.34	3.48	3.90	-0.4	0.0323	0.0330	-0.0007	53.15	60.20
6	10:18	10:38	24.86	25.42	24.89	0.53	3.31	3.45	4.00	-0.6	0.0317	0.0320	-0.0003	50.34	57.19
7	10:48	11:08	24.52	24.90	24.17	0.73	<b>3.33</b>	<b>3.47</b>	<b>4.10</b>	<b>-0.6</b>	0.0311	0.0310	0.0001	46.15	52.74
8	11:34	11:54	25.89	26.21	26.05	0.16	3.31	3.46	3.70	-0.2	0.0327	0.0330	-0.0003	57.80	64.70
9	12:04	12:24	25.70	25.93	25.76	0.17	3.33	3.50	3.80	-0.3	0.0324	0.0330	-0.0006	54.59	61.48
10	12:35	12:55	<b>25.33</b>	<b>25.64</b>	<b>24.40</b>	<b>1.24</b>	3.31	3.47	4.00	-0.5	<b>0.0320</b>	<b>0.0310</b>	<b>0.0010</b>	50.77	57.63
<b>AVERAGE</b>			—	25.80	25.76	0.04	—	3.45	3.79	-0.3	0.0321	0.0327	-0.0005	54.13	61.18
<b>STDS</b>			—	0.40	0.78	0.46	—	0.04	0.15	0.13	0.00049	0.00071	0.00028	—	—
<b>n</b>			9				9				9				
<b>Full Scale</b>			49.9				21.05				-				
<b>t<sub>0.975</sub></b>			2.306				2.306				2.306				
<b>  d  </b>			0.04				0.34				0.0005				
<b>  cc  </b>			0.35				0.10				0.0002				
<b>Bias present? ( d  &gt;  cc )</b>			<b>no bias</b>				<b>bias present</b>				<b>bias present</b>				
<b>Bias Factor</b>			<b>1.00</b>				<b>0.91</b>				<b>0.98</b>				
<b>Relative Accuracy (20% limit)</b>			<b>1.5%</b>				<b>12.6%</b>				<b>2.3%</b>				

*Notes:*  
 RM = Reference Method (RWDI measurements)  
 PEMS = Predictive Emission Monitor System (GM data)  
 di = Difference between PMS and RM for each point  
 n = number of tests  
 | d | = Absolute mean difference between the PEMS and RM results  
**Bolded test runs were not used in the RA calculation**

**Table 5: EU-BOILER3 - RATA Results**

Date: Tuesday, March 14, 2023

Test	RWDI Time		NOx				O <sub>2</sub>				Emission Rate			Load Steam (klb/hr)	Heat Input (MMBTU/hr)
	Start Time	End Time	RM	RM	PEMS	di	RM	RM	PEMS	di	RM	PEMS	di		
			(dppm)	(corppm)	(ppm)	(ppm)	(d%)	(cor%)	(%)	(%)	(lb/MMBTU)	(lb/MMBTU)	(lb/MMBTU)		
1	8:00	8:20	33.55	33.99	33.88	0.11	3.37	3.47	3.80	-0.3	0.0424	0.0430	-0.0006	53.42	59.59
2	8:30	8:50	33.71	33.93	33.89	0.04	3.40	3.54	3.80	-0.3	0.0425	0.0430	-0.0005	53.39	59.64
3	9:06	9:26	33.83	33.98	33.90	0.08	3.40	3.54	3.80	-0.3	0.0426	0.0430	-0.0004	53.40	59.64
4	9:38	9:58	33.85	34.04	33.91	0.13	3.40	3.53	3.80	-0.3	0.0426	0.0430	-0.0004	53.35	59.65
5	10:07	10:27	33.96	34.15	33.90	0.25	3.39	3.54	3.80	-0.3	0.0428	0.0430	-0.0002	53.20	59.66
6	10:36	10:56	34.09	34.27	33.90	0.37	3.38	3.53	3.80	-0.3	0.0429	0.0430	-0.0001	53.29	59.66
7	11:07	11:27	34.19	34.71	33.90	0.81	3.39	3.53	3.80	-0.3	0.0434	0.0430	0.0004	53.40	59.74
8	11:38	11:58	34.03	34.85	33.90	0.95	3.38	3.52	3.80	-0.3	0.0436	0.0430	0.0006	53.36	59.63
9	12:09	12:29	34.19	35.00	33.91	1.09	3.37	3.51	3.80	-0.3	0.0437	0.0430	0.0007	53.31	59.63
10	12:40	13:00	<b>34.29</b>	<b>35.22</b>	<b>33.91</b>	<b>1.31</b>	<b>3.37</b>	<b>3.52</b>	<b>3.80</b>	<b>-0.3</b>	<b>0.0440</b>	<b>0.0430</b>	<b>0.0010</b>	53.18	59.65
AVERAGE			-	34.32	33.90	0.43	-	3.52	3.80	-0.3	0.0429	0.0430	-0.0001	53.33	59.65
STDS			-	0.42	0.01	0.41	-	0.02	0.00	0.02	0.00052	0.00000	0.00052	-	-
n			9				9				9				
Full Scale			49.9				21				-				
t <sub>0.975</sub>			2.306				2.306				2.306				
d			0.43				0.28				0.0001				
cc			0.32				0.02				0.0004				
Bias present? ( d  >  cc )			bias present				bias present				bias present				
Bias Factor			1.01				0.93				1.00				
Relative Accuracy (20% limit)			2.2%				8.4%				1.1%				

Notes:


- RM = Reference Method (RWDI measurements)
- PEMS = Predictive Emission Monitor System (GM data)
- di = Difference between PEMS and RM for each point
- n = number of tests
- | d | = Absolute mean difference between the PEMS and RM results
- Bolded test runs were not used in the RA calculation**

# FIGURES





Figure No. 1: USEPA Method 3A and 7E Schematic



**USEPA Method 3A and 7E**

General Motors, LLC  
GM Technical Center

Warren, Michigan

Project# 2302580

Date: March 14 - 16, 2023

