

**RECEIVED**

**AUG 02 2022**

Report of a ...

**AIR QUALITY DIVISION**

# **PEMS RATA**

Performed for ...

**Cleveland-Cliffs, Inc.  
Tilden Mining Company, L.C.  
Ishpeming, Michigan**

On...

**Boiler 4 (EU-BOILER4)**

At the...

**Tilden Mine  
National Mine, Michigan**

**June 21, 2022**

**Project #: 053.56**

**Performed By:**

**Network Environmental, Inc.  
Grand Rapids, MI**

**Performed for:**

Cleveland-Cliffs, Inc.  
Tilden Mining Company, L.C.  
1 Tilden Mine Road  
P.O. Box 2000  
Ishpeming, MI 49849-0901  
Contact: Tom O'Brien  
Telephone: (906) 475-3306  
e-mail: thomas.obrien@clevelandcliffs.com

**Performed at the:**

Tilden Mine  
National Mine, MI

**Performed by:**

Network Environmental, Inc.  
2629 Remico Street, Suite B  
Grand Rapids, MI 49519  
Contact: David D. Engelhardt  
Telephone: (616) 530-6330  
Fax: (616) 530-0001  
e-mail: netenviro@aol.com

## **TABLE OF CONTENTS**

	<u>Page</u>
I. Introduction	1
II. Presentation of Results	2
II.1 Table 1 – NO <sub>x</sub> (Lbs/MMBTU) Relative Accuracy Test Results	2
III. Discussion of Results	3
IV. Source Description	3
V. Sampling and Analytical Protocol	3-5
Figure 1 – NO <sub>x</sub> & O <sub>2</sub> Sampling Train Diagram	6

## **Appendices**

Reference Method DAS Data	A
PEMS Data	B
Calibration Gas & Analyzer Specification Data	C
Calculations	D
Raw Data	E

## **I. INTRODUCTION**

Network Environmental, Inc. was retained by the Tilden Mining Company, L.C. of Ishpeming, Michigan to perform a relative accuracy test audit (RATA) at the Tilden Mine located in National Mine, Michigan.

The purpose of the testing was to conduct a Relative Accuracy Test Audit (RATA) on the Predictive Emission Monitoring System (PEMS) that services the Gas Fired Boiler #4 (EU-BOILER4). The PEMS on the boiler is for oxides of nitrogen ( $\text{NO}_x$ ) and oxygen ( $\text{O}_2$ ). The PEMS was installed and the RATA was performed in order to meet the requirements of Michigan Department of Environment, Great Lakes & Energy (EGLE), Air Quality Division ROP No. MI-ROP-B4885-2017b.

The RATA was conducted in accordance with 40 CFR Part 60 Appendix B Performance Specification 16 (PS-16).

The following reference test methods were used to conduct the sampling:

- Oxides of Nitrogen ( $\text{NO}_x$ ) – U.S. EPA Method 7E
- Oxygen ( $\text{O}_2$ ) – U.S. EPA Method 3A

The sampling was performed on June 21, 2022 by Stephan K. Byrd and David D. Engelhardt of Network Environmental, Inc.. Assisting with the testing were Mr. Thomas O'Brien of the Tilden Mining Company, L.C. and the operating staff of the facility.

**RECEIVED**

**AUG 02 2022**

**AIR QUALITY DIVISION**

## **II. PRESENTATION OF RESULTS**

**II.1 TABLE 1**  
**NO<sub>x</sub> (LBS/MMBTU) RELATIVE ACCURACY TEST AUDIT RESULTS**  
**BOILER #4 (EU-BOILER4)**  
**TILDEN MINING COMPANY, L.C.**  
**NATIONAL MINE, MICHIGAN**  
**JUNE 21, 2022**

Run #	Time	REFERENCE METHOD			PEMS	DIFF
		NO <sub>x</sub> <sup>(1)</sup>	O <sub>2</sub> <sup>(2)</sup>	Lbs/MMBTU		
1	07:44-08:09	19.9	5.9	0.029	0.029	0.000
2	08:20-08:45	19.9	5.7	0.028	0.029	-0.001
3	08:54-09:19	19.5	6.1	0.029	0.030	-0.001
4	09:29-09:54	19.4	6.1	0.028	0.029	-0.001
5	10:04-10:29	19.4	5.7	0.028	0.029	-0.001
6	10:39-11:04	19.3	5.7	0.028	0.029	-0.001
7	11:14-11:39	19.1	5.7	0.027	0.029	-0.002
8	11:50-12:15	19.0	6.0	0.028	0.029	-0.001
9	12:24-12:49	18.7	5.8	0.027	0.029	-0.002

Mean Reference Value = 0.02800

Mean of the Difference = -0.00111

Standard Deviation = 0.00060

Confidence Co-efficient = 0.00046

**Relative Accuracy (RA) = 5.62% of the mean of the reference method**

- (1) Concentration in term of PPM by volume on a dry basis
- (2) Concentration in terms of % on a dry basis
- (3) RA needs to be less than 20%.

### **III. DISCUSSION OF RESULTS**

**III.1 NO<sub>x</sub> (LBS/MMBTU) RATA** – The results of the NO<sub>x</sub> Lbs/MMBTU RATA can be found in Table 1 (Section II.1). The relative accuracy calculations were performed in terms of Lbs/MMBTU. The Lbs/MMBTU results were calculated using the formula found in Section 2.1 of Method 19 for O<sub>2</sub> on a dry basis. The F factor used was 8,710. Nine (9) twenty-five (25) minute samples were collected from the boiler exhaust. Raw DAS output results were corrected per Equation 7E-5.

The relative accuracy for the NO<sub>x</sub> CEMS using Lbs/MMBTU was **5.62%** of the mean of the reference method samples.

According to Performance Specification 16 in 40 CFR Part 60 Appendix B, "The relative accuracy (RA) of the CEMS shall be no greater than 20 percent of the mean value of the reference method test data."

### **IV. SOURCE DESCRIPTION**

Boiler 4 is a natural gas-fired boiler with a rated capacity of 225 KLbs/Hr of steam. The boiler is equipped with low NO<sub>x</sub> burners. Boiler 4 is used to provide process steam to the facility. During the testing periods, the boiler was operated at approximately 50% of capacity. Steam Load and Gas Flow data during the sampling can be found in Appendix B.

The PEMS is a Wunderlich-Malec, Model No. PowerEMS, Serial No. SWCEM EU-BOILER4.

The boiler is exhausted to a stack through a four (4) foot by eight (8) foot breaching. A schematic diagram of the source and sampling location can be found in Appendix E.

### **V. SAMPLING AND ANALYTICAL PROTOCOL**

The sampling methods used for the reference method determinations were as follows:

**V.1 Oxides of Nitrogen** – The NO<sub>x</sub> sampling was conducted in accordance with U.S. EPA Reference Method 7E. A Thermo Environmental Model 42H gas analyzer was used to monitor the boiler exhaust. A

heated probe was used to extract the sample gases from the exhaust stack. A heated Teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the NO<sub>x</sub> concentrations (PPM).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 54.6 PPM was used to establish the initial instrument calibration. A calibration gas of 25.2 PPM was used to determine the calibration error of the analyzer. A direct injection of 51.0 PPM nitrogen dioxide (NO<sub>2</sub>) was performed to show the conversion efficiency of the monitor. The conversion efficiency data can be found in Appendix A. The sampling system (from the back of the stack probe to the analyzer) was injected using the 25.2 PPM gas to determine the system bias. After each sample, a system zero and system injection of 25.2 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler. A diagram of the NO<sub>x</sub> sampling train is shown in Figure 1.

**V.2 Oxygen** – The O<sub>2</sub> sampling was conducted in accordance with U.S. EPA Reference Method 3A. A Servomex Model 1400M portable stack gas analyzer was used to monitor the boiler exhaust. A heated probe was used to extract the sample gas from the stack. A heated Teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the O<sub>2</sub> concentrations (%).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 20.85% was used to establish the initial instrument calibration. Calibration gases of 12.10% and 5.90% were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 5.90% gas to determine the system bias. After each sample, a system zero and system injection of 5.90% were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.


The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler. A diagram of the O<sub>2</sub> sampling train is shown in Figure 1.

**V.3 Sampling Locations** – Prior to the initial RATA sampling (05/19), a twenty-four (24) point stratification test (as described in U.S. EPA Method 7E) was performed for the exhaust breaching. The breaching is 48 inches deep by 96 inches high with 4 sampling ports. The dimensions used for the stratification test were as follows:

<u>Traverse Point</u>	<u>Dimension (Inches)</u>
1	4.00
2	12.00
3	20.00
4	28.00
5	36.00
6	44.00


The stratification test showed no stratification (< 5%), so a single sampling point (Port 3 - Point 3) was used for the gas sampling. The results of the stratification test can be found in Appendix A.

This report was prepared by:



David D. Engelhardt  
Vice President

This report was reviewed by:




R. Scott Cargill  
Project Manager

RECEIVED

AUG 02 2022

AIR QUALITY DIVISION



**Figure 1**  
 **$\text{NO}_x$  &  $\text{O}_2$**   
**Sampling Train**

**APPENDIX A**  
**REFERENCE METHOD DAS DATA**

Company: Cleveland-Cliffs Tilden

Location: National Mine, MI

Source: Boiler 4

Date: 6/21/2022

Units: PPM %

Company: Cleveland-Cliffs Tilden  
 Location: National Mine, MI  
 Source: Boiler 4 PEMS  
 Date: 6/21/22

Monitor: Thermo Env. Model 42H - NOx  
 Operator: SKB / DDE  
 Cal. Span Value: 54.60  
 Page #: 1 of 1

Cal Gas Conc. PPM	Calibration Response, PPM					Analyzer Cal. Error, % of Span Gas	Drift, % of Span			System Bias, % of Span				
	Direct Injection	System Injection					Test 1	Test 2	Test 3	Pretest	Post 1	Post 2	Post 3	
		Pretest	Post 1	Post 2	Post 3									
7:14	7:23	8:12	8:48	9:22			0.37	0.00	0.00	0.00	0.37	0.37	0.37	
0.00	0.0	0.0	0.2	0.2	0.2		0.00							
25.20	25.3	25.4	25.4	25.5	25.5	0.18	0.00	0.18	0.00	0.18	0.18	0.37	0.37	
54.60	54.6													

System Injection						Drift, % of Span							System Bias, % of Span						
Post 4	Post 5	Post 6	Post 7	Post 8	Post 9	Post 4	Post 5	Post 6	Post 7	Post 8	Post 9	Post 4	Post 5	Post 6	Post 7	Post 8	Post 9		
9:58	10:32	11:07	11:42	12:18	12:52	0.2	0.00	0.00	0.37	0.00	0.00	0.37	0.37	0.37	0.73	0.73	0.73		
0.2	0.2	0.2	0.4	0.4	0.4	25.6	25.5	25.5	25.4	0.18	-0.18	0.00	0.00	-0.18	0.55	0.37	0.37		
25.6	25.5	25.5	25.5	25.5	25.4										0.37	0.37	0.18		

51.0 PPM NO<sub>2</sub> Read 48.2 PPM = 94.51% Conversion

Company: Cleveland-Cliffs Tilden  
 Location: National Mine, MI  
 Source: Boiler 4 PEMS  
 Date: 6/21/22

Monitor: Servomex Series 1400 - O<sub>2</sub>  
 Operator: SKB / DDE  
 Cal. Span Value: 20.85  
 Page #: 1 of 1

Cal Gas Conc. %	Calibration Response, %					Analyzer Cal. Error, % of Span Gas	Drift, % of Span			System Bias, % of Span				
	Direct Injection	System Injection					Test 1	Test 2	Test 3	Pretest	Post 1	Post 2	Post 3	
		Pretest	Post 1	Post 2	Post 3									
0.00	0.0	0.2	0.2	0.2	0.2		0.00	0.00	0.00	0.96	0.96	0.96	0.96	
5.90	6.0	5.9	5.9	5.9	5.9	0.48	0.00	0.00	0.00	-0.48	-0.48	-0.48	-0.48	
12.10	12.1					0.00								
20.85	20.9													

System Injection						Drift, % of Span							System Bias, % of Span						
Post 4	Post 5	Post 6	Post 7	Post 8	Post 9	Post 4	Post 5	Post 6	Post 7	Post 8	Post 9	Post 4	Post 5	Post 6	Post 7	Post 8	Post 9		
10:00	10:35	11:10	11:46	12:20	12:56	0.2	0.2	0.2	0.00	0.00	0.00	0.96	0.96	0.96	0.96	0.96	0.96		
0.2	0.2	0.2	0.2	0.2	0.2	0.00	0.00	0.00	0.00	0.00	0.00	0.96	0.96	0.96	0.96	0.96	0.96		
5.8	5.9	5.8	5.8	5.8	5.8	-0.48	0.48	-0.48	0.00	0.00	0.00	-0.96	-0.48	-0.96	-0.96	-0.96	-0.96		

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 1

Start Time 7:44:28

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	7:44:28	20.7	6.1
06/21/22	7:45:28	20.0	6.1
06/21/22	7:46:28	20.1	6.5
06/21/22	7:47:28	20.5	6.5
06/21/22	7:48:28	19.6	6.5
06/21/22	7:49:28	20.6	6.5
06/21/22	7:50:28	19.5	6.3
06/21/22	7:51:28	20.0	6.3
06/21/22	7:52:28	19.4	6.1
06/21/22	7:53:28	20.3	5.9
06/21/22	7:54:28	19.7	5.7
06/21/22	7:55:28	20.5	5.5
06/21/22	7:56:28	19.9	5.5
06/21/22	7:57:28	20.2	5.4
06/21/22	7:58:28	19.9	5.4
06/21/22	7:59:28	20.5	5.5
06/21/22	8:00:28	20.0	5.5
06/21/22	8:01:28	20.0	5.5
06/21/22	8:02:28	20.3	5.6
06/21/22	8:03:28	20.1	5.7
06/21/22	8:04:28	20.9	5.6
06/21/22	8:05:28	20.0	5.6
06/21/22	8:06:28	20.4	5.8
06/21/22	8:07:28	19.7	5.7
06/21/22	8:08:28	20.5	5.6

**Sample 1 Average 20.1 5.9**

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 2

Start Time 8:19:47

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	8:19:47	20.3	5.8
06/21/22	8:20:47	19.9	5.8
06/21/22	8:21:47	19.9	5.8
06/21/22	8:22:47	20.1	5.5
06/21/22	8:23:47	19.6	5.5
06/21/22	8:24:47	20.5	5.5
06/21/22	8:25:47	20.0	5.6
06/21/22	8:26:47	20.8	5.6
06/21/22	8:27:47	20.4	5.7
06/21/22	8:28:47	20.8	5.9
06/21/22	8:29:47	19.8	5.9
06/21/22	8:30:47	20.4	5.9
06/21/22	8:31:47	19.9	5.6
06/21/22	8:32:47	20.1	5.6
06/21/22	8:33:47	19.5	5.5
06/21/22	8:34:47	20.4	5.5
06/21/22	8:35:47	19.8	5.6
06/21/22	8:36:47	20.5	5.5
06/21/22	8:37:47	19.5	5.4
06/21/22	8:38:47	20.4	5.6
06/21/22	8:39:47	19.9	5.6
06/21/22	8:40:47	20.1	5.7
06/21/22	8:41:47	20.5	5.8
06/21/22	8:42:47	19.7	5.9
06/21/22	8:43:47	20.3	6.0

**Sample 2 Average 20.1 5.7**

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 3

Start Time 8:54:14

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	8:54:14	19.3	6.1
06/21/22	8:55:14	20.2	6.1
06/21/22	8:56:14	19.7	6.2
06/21/22	8:57:14	20.0	6.1
06/21/22	8:58:14	20.3	6.0
06/21/22	8:59:14	19.4	5.9
06/21/22	9:00:14	19.5	6.1
06/21/22	9:01:14	20.5	6.3
06/21/22	9:02:14	19.5	6.1
06/21/22	9:03:14	19.9	6.1
06/21/22	9:04:14	20.2	6.0
06/21/22	9:05:14	19.5	6.1
06/21/22	9:06:14	20.4	6.2
06/21/22	9:07:14	19.9	6.1
06/21/22	9:08:14	19.7	6.2
06/21/22	9:09:14	20.0	6.1
06/21/22	9:10:14	19.6	6.2
06/21/22	9:11:14	20.2	6.0
06/21/22	9:12:14	19.6	6.1
06/21/22	9:13:14	19.7	6.1
06/21/22	9:14:14	20.4	6.1
06/21/22	9:15:14	19.1	6.1
06/21/22	9:16:14	19.4	6.1
06/21/22	9:17:14	20.4	6.1
06/21/22	9:18:14	19.6	6.0

**Sample 3 Average 19.8 6.1**

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 4

Start Time 9:29:06

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	9:29:06	20.3	6.0
06/21/22	9:30:06	19.5	6.0
06/21/22	9:31:06	19.5	6.1
06/21/22	9:32:06	20.4	6.0
06/21/22	9:33:06	19.4	5.9
06/21/22	9:34:06	19.4	6.1
06/21/22	9:35:06	20.1	6.1
06/21/22	9:36:06	19.4	6.1
06/21/22	9:37:06	19.5	6.1
06/21/22	9:38:06	20.2	6.1
06/21/22	9:39:06	19.5	6.1
06/21/22	9:40:06	19.8	6.0
06/21/22	9:41:06	20.3	6.2
06/21/22	9:42:06	19.1	6.1
06/21/22	9:43:06	19.9	6.2
06/21/22	9:44:06	19.8	6.0
06/21/22	9:45:06	19.3	6.0
06/21/22	9:46:06	20.1	5.9
06/21/22	9:47:06	19.7	5.9
06/21/22	9:48:06	19.3	5.9
06/21/22	9:49:06	20.0	6.0
06/21/22	9:50:06	19.8	5.7
06/21/22	9:51:06	19.3	5.9
06/21/22	9:52:06	19.7	5.8
06/21/22	9:53:06	19.6	5.9

**Sample 4 Average 19.7 6.0**

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 5

Start Time 10:03:52

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	10:03:52	20.2	5.8
06/21/22	10:04:52	19.5	5.5
06/21/22	10:05:52	19.4	5.8
06/21/22	10:06:52	20.0	5.7
06/21/22	10:07:52	19.4	5.8
06/21/22	10:08:52	20.1	5.7
06/21/22	10:09:52	19.5	5.7
06/21/22	10:10:52	20.1	5.7
06/21/22	10:11:52	19.8	5.6
06/21/22	10:12:52	19.3	5.6
06/21/22	10:13:52	20.5	5.8
06/21/22	10:14:52	19.3	5.5
06/21/22	10:15:52	19.7	5.6
06/21/22	10:16:52	19.9	5.6
06/21/22	10:17:52	19.3	5.7
06/21/22	10:18:52	20.3	5.8
06/21/22	10:19:52	19.2	5.8
06/21/22	10:20:52	19.6	5.9
06/21/22	10:21:52	19.9	5.7
06/21/22	10:22:52	19.3	5.8
06/21/22	10:23:52	20.0	5.7
06/21/22	10:24:52	19.7	5.6
06/21/22	10:25:52	19.2	5.7
06/21/22	10:26:52	20.3	5.7
06/21/22	10:27:52	19.2	5.5

**Sample 5 Average 19.7 5.7**

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 6

Start Time 10:39:01

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	10:39:01	19.6	5.8
06/21/22	10:40:01	20.1	5.6
06/21/22	10:41:01	19.0	5.8
06/21/22	10:42:01	20.3	5.8
06/21/22	10:43:01	19.5	5.7
06/21/22	10:44:01	19.3	5.7
06/21/22	10:45:01	19.9	5.6
06/21/22	10:46:01	19.6	5.6
06/21/22	10:47:01	19.2	5.8
06/21/22	10:48:01	20.1	5.8
06/21/22	10:49:01	19.8	5.7
06/21/22	10:50:01	19.5	5.7
06/21/22	10:51:01	20.0	5.7
06/21/22	10:52:01	18.9	5.6
06/21/22	10:53:01	19.8	5.7
06/21/22	10:54:01	18.9	5.6
06/21/22	10:55:01	19.7	5.8
06/21/22	10:56:01	19.5	5.6
06/21/22	10:57:01	19.2	5.6
06/21/22	10:58:01	19.9	5.6
06/21/22	10:59:01	19.4	5.8
06/21/22	11:00:01	19.9	5.7
06/21/22	11:01:01	19.1	5.8
06/21/22	11:02:01	19.9	5.6
06/21/22	11:03:01	19.1	5.7

**Sample 6 Average 19.6 5.7**

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 7

Start Time 11:14:17

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	11:14:17	19.3	5.7
06/21/22	11:15:17	19.4	5.7
06/21/22	11:16:17	19.1	5.7
06/21/22	11:17:17	19.7	5.8
06/21/22	11:18:17	18.7	5.6
06/21/22	11:19:17	19.1	5.7
06/21/22	11:20:17	20.0	5.7
06/21/22	11:21:17	18.8	5.5
06/21/22	11:22:17	19.9	5.7
06/21/22	11:23:17	18.9	5.6
06/21/22	11:24:17	19.5	5.6
06/21/22	11:25:17	19.4	5.6
06/21/22	11:26:17	19.4	5.6
06/21/22	11:27:17	19.7	5.6
06/21/22	11:28:17	19.1	5.6
06/21/22	11:29:17	19.9	5.6
06/21/22	11:30:17	19.0	5.6
06/21/22	11:31:17	20.0	5.6
06/21/22	11:32:17	19.2	5.5
06/21/22	11:33:17	19.1	5.6
06/21/22	11:34:17	20.1	5.6
06/21/22	11:35:17	19.0	5.8
06/21/22	11:36:17	19.6	5.7
06/21/22	11:37:17	19.4	5.6
06/21/22	11:38:17	19.0	5.6

Sample 7 Average 19.4 5.6

RECEIVED

AUG 02 2022

AIR QUALITY DIVISION

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 8

Start Time 11:49:34

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	11:49:34	19.2	5.6
06/21/22	11:50:34	19.6	5.5
06/21/22	11:51:34	19.4	5.4
06/21/22	11:52:34	18.9	5.6
06/21/22	11:53:34	19.1	5.4
06/21/22	11:54:34	19.0	6.0
06/21/22	11:55:34	19.9	6.0
06/21/22	11:56:34	19.0	5.7
06/21/22	11:57:34	19.6	6.2
06/21/22	11:58:34	19.5	6.1
06/21/22	11:59:34	19.6	6.2
06/21/22	12:00:34	19.6	6.2
06/21/22	12:01:34	18.9	6.2
06/21/22	12:02:34	20.0	6.2
06/21/22	12:03:34	19.0	6.1
06/21/22	12:04:34	19.2	5.9
06/21/22	12:05:34	19.7	5.7
06/21/22	12:06:34	18.9	5.5
06/21/22	12:07:34	19.8	6.0
06/21/22	12:08:34	19.2	6.0
06/21/22	12:09:34	18.8	6.0
06/21/22	12:10:34	20.1	6.0
06/21/22	12:11:34	18.8	6.1
06/21/22	12:12:34	19.2	5.9
06/21/22	12:13:34	19.4	5.6

**Sample 8 Average 19.3 5.9**

Cleveland-Cliffs Tilden

National Mine, MI

Boiler 4

Sample # 9

Start Time 12:24:20

Date 06/21/22

Date	Time	NOx PPM	O2 %
06/21/22	12:24:20	18.9	5.8
06/21/22	12:25:20	18.7	6.1
06/21/22	12:26:20	19.5	6.1
06/21/22	12:27:20	18.6	6.0
06/21/22	12:28:20	19.1	6.1
06/21/22	12:29:20	19.4	5.6
06/21/22	12:30:20	18.8	5.8
06/21/22	12:31:20	18.9	5.8
06/21/22	12:32:20	19.3	5.8
06/21/22	12:33:20	18.7	5.9
06/21/22	12:34:20	18.8	5.7
06/21/22	12:35:20	19.5	5.6
06/21/22	12:36:20	19.3	5.5
06/21/22	12:37:20	19.0	5.5
06/21/22	12:38:20	19.6	5.6
06/21/22	12:39:20	19.3	5.5
06/21/22	12:40:20	18.4	5.7
06/21/22	12:41:20	19.7	5.7
06/21/22	12:42:20	18.7	5.7
06/21/22	12:43:20	19.0	5.6
06/21/22	12:44:20	19.2	5.4
06/21/22	12:45:20	18.5	5.6
06/21/22	12:46:20	18.8	5.6
06/21/22	12:47:20	19.8	5.5
06/21/22	12:48:20	18.7	5.4

**Sample 9 Average 19.0 5.7**

Tilden Mining Company  
 National Mine, MI  
 Boiler 4 Stratification Test  
 Sample # 1  
 Start Time 15:46:55  
 Date 05/06/19

Port/Point	Date	Time	NOx PPM	O2 %
4/6	05/06/19	15:46:55	20.3	6.0
	05/06/19	15:47:55	20.6	5.9
	05/06/19	15:48:55	20.3	5.8
	05/06/19	15:49:55	20.2	5.7
4/5	05/06/19	15:50:55	19.8	5.8
	05/06/19	15:51:55	19.9	5.9
	05/06/19	15:52:55	19.8	5.7
	05/06/19	15:53:55	20.3	5.7
4/4	05/06/19	15:54:55	20.1	5.8
	05/06/19	15:55:55	20.2	5.7
	05/06/19	15:56:55	20.3	6.0
	05/06/19	15:57:55	20.5	5.7
4/3	05/06/19	15:58:55	20.4	5.5
	05/06/19	15:59:55	20.1	5.6
	05/06/19	16:00:55	20.0	5.8
	05/06/19	16:01:55	20.5	5.7
4/2	05/06/19	16:02:55	20.3	5.8
	05/06/19	16:03:55	20.7	5.9
	05/06/19	16:04:55	20.5	5.8
	05/06/19	16:05:55	20.0	5.9
4/1	05/06/19	16:06:55	20.7	5.9
	05/06/19	16:07:55	20.8	5.9
	05/06/19	16:08:55	20.2	5.9
	05/06/19	16:09:55	20.6	6.0
3/6	05/06/19	16:14:24	20.2	5.8
	05/06/19	16:15:24	20.0	5.7
	05/06/19	16:16:24	20.1	5.8
	05/06/19	16:17:24	19.8	5.6
3/5	05/06/19	16:18:24	20.0	5.8
	05/06/19	16:19:24	20.0	5.7
	05/06/19	16:20:24	20.1	5.8
	05/06/19	16:21:24	20.2	5.7
3/4	05/06/19	16:22:24	20.5	5.9
	05/06/19	16:23:24	20.4	5.9
	05/06/19	16:24:24	20.8	6.0
	05/06/19	16:25:24	20.5	6.0
3/3	05/06/19	16:26:24	20.4	6.0
	05/06/19	16:27:24	20.4	5.8
	05/06/19	16:28:24	20.5	5.9
	05/06/19	16:29:24	20.2	5.9
3/2	05/06/19	16:30:24	19.6	6.0
	05/06/19	16:31:24	19.8	5.9
	05/06/19	16:32:24	20.0	5.8
	05/06/19	16:33:24	19.9	5.8
3/1	05/06/19	16:34:24	19.9	5.9
	05/06/19	16:35:24	20.0	5.9
	05/06/19	16:36:24	20.1	5.8
	05/06/19	16:37:24	20.0	5.8
2/6	05/06/19	16:41:21	20.4	5.8
	05/06/19	16:42:21	20.1	6.0
	05/06/19	16:43:21	20.6	6.0
	05/06/19	16:44:21	20.4	5.9
2/5	05/06/19	16:45:21	19.6	6.2
	05/06/19	16:46:21	19.5	5.7
	05/06/19	16:47:21	19.9	5.7
	05/06/19	16:48:21	19.8	5.7
2/4	05/06/19	16:49:21	19.5	6.2
	05/06/19	16:50:21	19.5	5.8
	05/06/19	16:51:21	20.0	5.9
	05/06/19	16:52:21	20.0	5.9
2/3	05/06/19	16:53:21	18.7	5.9
	05/06/19	16:54:21	19.2	6.0
	05/06/19	16:55:21	20.2	5.8
	05/06/19	16:56:21	20.1	5.8
2/2	05/06/19	16:57:21	18.7	5.9
	05/06/19	16:58:21	18.8	6.0
	05/06/19	16:59:21	19.1	6.0
	05/06/19	17:00:21	19.3	5.8
2/1	05/06/19	17:01:21	19.3	6.0
	05/06/19	17:02:21	19.7	6.0
	05/06/19	17:03:21	19.0	6.0
	05/06/19	17:04:21	19.0	5.9
1/6	05/06/19	17:08:11	20.1	6.0
	05/06/19	17:09:11	20.2	6.1
	05/06/19	17:10:11	20.1	6.0
	05/06/19	17:11:11	19.8	6.0
1/5	05/06/19	17:12:11	19.4	6.0
	05/06/19	17:13:11	19.6	5.9
	05/06/19	17:14:11	19.6	5.8
	05/06/19	17:15:11	19.4	5.8
1/4	05/06/19	17:16:11	18.6	6.0
	05/06/19	17:17:11	19.3	5.8
	05/06/19	17:18:11	20.2	5.8
	05/06/19	17:19:11	19.7	5.7
1/3	05/06/19	17:20:11	20.0	6.0
	05/06/19	17:21:11	19.7	5.9
	05/06/19	17:22:11	19.5	5.9
	05/06/19	17:23:11	19.8	5.9

	05/06/19	17:24:11	19.3	6.0
1/2	05/06/19	17:25:11	19.3	6.0
	05/06/19	17:26:11	19.5	6.0
	05/06/19	17:27:11	19.0	5.9
	05/06/19	17:28:11	19.9	6.0
1/1	05/06/19	17:29:11	20.0	6.0
	05/06/19	17:30:11	19.6	6.0
	05/06/19	17:31:11	19.2	6.0
		Average	19.9	5.9
Port 4	Point 6	Average	20.3	5.8
	Point 5	Average	19.9	5.8
	Point 4	Average	20.3	5.8
	Point 3	Average	20.3	5.7
	Point 2	Average	20.4	5.9
	Point 1	Average	20.6	5.9
Port 3	Point 6	Average	20.0	5.7
	Point 5	Average	20.1	5.7
	Point 4	Average	20.5	5.9
	Point 3	Average	20.3	5.9
	Point 2	Average	19.8	5.9
	Point 1	Average	20.0	5.9
Port 2	Point 6	Average	20.4	5.9
	Point 5	Average	19.7	5.8
	Point 4	Average	19.8	5.9
	Point 3	Average	19.6	5.9
	Point 2	Average	19.0	5.9
	Point 1	Average	19.3	6.0
Port 1	Point 6	Average	20.0	6.0
	Point 5	Average	19.5	5.9
	Point 4	Average	19.4	5.8
	Point 3	Average	19.8	5.9
	Point 2	Average	19.3	6.0
	Point 1	Average	19.7	6.0

Port 4	Point 6	% Diff.	2.1	-0.5
	Point 5	% Diff.	0.2	-1.7
	Point 4	% Diff.	1.9	-1.2
	Point 3	% Diff.	1.7	-3.5
	Point 2	% Diff.	2.4	-0.3
	Point 1	% Diff.	3.2	1.1
Port 3	Point 6	% Diff.	0.7	-2.7
	Point 5	% Diff.	1.0	-2.3
	Point 4	% Diff.	3.1	1.0
	Point 3	% Diff.	2.2	0.4
	Point 2	% Diff.	-0.4	0.2
	Point 1	% Diff.	0.4	-0.4
Port 2	Point 6	% Diff.	2.4	0.5
	Point 5	% Diff.	-1.2	-1.0
	Point 4	% Diff.	-0.8	1.1
	Point 3	% Diff.	-1.8	0.0
	Point 2	% Diff.	-4.6	0.9
	Point 1	% Diff.	-3.3	1.7
Port 1	Point 6	% Diff.	0.5	2.7
	Point 5	% Diff.	-2.0	0.0
	Point 4	% Diff.	-2.4	-1.0
	Point 3	% Diff.	-0.8	1.2
	Point 2	% Diff.	-3.2	1.7
	Point 1	% Diff.	-1.2	2.2

## **APPENDIX B**

### **PEMS DATA**

Tilden Mining Company L.C. EU-BOILER4: Run 1

Start Time: 06/21/2022 07:44:00

End Time: 06/21/2022 08:08:59

Date:Time	@ Missing	& Offline		# Invalid	* Deviation (blank)	No Value	^ Outside Limit				
		EU-Boiler 4					EU-Boiler 4	EU-Boiler 4			
		NOx ppm	O2 pct				Gas kscf/hr	Steam klb/hr			
		1-Minute	1-Minute				1-Minute	1-Minute			
6/21/2022 7:44		20.25	6.04		0.030		137.58	110.55			
6/21/2022 7:45		20.35	6.07		0.030		136.07	109.84			
6/21/2022 7:46		20.26	6.06		0.030		133.29	109.05			
6/21/2022 7:47		20.26	6.43		0.030		128.87	107.73			
6/21/2022 7:48		20.20	6.24		0.030		128.59	106.7			
6/21/2022 7:49		20.27	6.35		0.030		129.41	107.13			
6/21/2022 7:50		20.24	6.17		0.030		130.83	108.09			
6/21/2022 7:51		20.17	6.10		0.030		132.88	109.58			
6/21/2022 7:52		20.17	6.06		0.030		137.16	113.1			
6/21/2022 7:53		20.38	6.04		0.030		142.91	116.53			
6/21/2022 7:54		20.26	5.70		0.029		144.14	117.63			
6/21/2022 7:55		20.52	5.56		0.029		146.6	119.13			
6/21/2022 7:56		20.39	5.54		0.029		150.71	120.46			
6/21/2022 7:57		20.40	5.43		0.029		152.67	121.61			
6/21/2022 7:58		20.58	5.42		0.029		152.99	122.13			
6/21/2022 7:59		20.48	5.55		0.029		151.76	121.84			
6/21/2022 8:00		20.47	5.52		0.029		155.45	122.55			
6/21/2022 8:01		20.68	5.72		0.030		156.91	121.51			
6/21/2022 8:02		20.56	5.64		0.029		159.65	120.21			
6/21/2022 8:03		20.60	5.58		0.029		158.1	117.34			
6/21/2022 8:04		20.56	5.89		0.030		151.35	118.44			
6/21/2022 8:05		20.36	5.74		0.029		145.42	119.73			
6/21/2022 8:06		20.31	5.69		0.029		143.73	119.52			
6/21/2022 8:07		20.28	5.93		0.029		145.83	118.65			
6/21/2022 8:08		20.44	5.68		0.029		150.98	117.68			
	Average:	20.38	5.85		0.029		144.16	115.87			

Tilden Mining Company L.C. EU-BOILER4: Run 2

Start Time: 06/21/2022 08:20:00

End Time: 06/21/2022 08:44:59

Date:Time	@ Missing & Offline		# Invalid	* Deviation	(blank) No Value	^ Outside Limit
	EU-Boiler 4 NOx ppm	EU-Boiler 4 O2 pct	EU-Boiler 4 lb/MMBtu	EU-Boiler 4 Gas kscf/hr	EU-Boiler 4 Steam klb/hr	
	1-Minute	1-Minute	1-Minute	1-Minute	1-Minute	
6/21/2022 8:20	20.43	5.88	0.030	143.73	116.95	
6/21/2022 8:21	20.32	5.76	0.029	142.04	116.72	
6/21/2022 8:22	20.46	5.73	0.029	144.92	116.98	
6/21/2022 8:23	20.34	5.46	0.029	148.70	118.50	
6/21/2022 8:24	20.42	5.55	0.029	150.66	121.46	
6/21/2022 8:25	20.59	5.51	0.029	153.35	121.26	
6/21/2022 8:26	20.48	5.62	0.029	153.54	119.77	
6/21/2022 8:27	20.39	5.46	0.029	149.02	121.46	
6/21/2022 8:28	20.42	5.68	0.029	143.96	121.06	
6/21/2022 8:29	20.33	5.74	0.029	140.81	120.90	
6/21/2022 8:30	20.32	6.03	0.030	141.09	119.91	
6/21/2022 8:31	20.45	5.74	0.029	144.14	119.58	
6/21/2022 8:32	20.38	5.51	0.029	147.38	121.10	
6/21/2022 8:33	20.55	5.61	0.029	150.75	120.17	
6/21/2022 8:34	20.31	5.56	0.029	149.70	119.90	
6/21/2022 8:35	20.41	5.48	0.029	148.25	113.66	
6/21/2022 8:36	20.46	5.66	0.029	147.33	112.29	
6/21/2022 8:37	20.44	5.43	0.029	147.88	112.53	
6/21/2022 8:38	20.29	5.48	0.029	147.74	112.92	
6/21/2022 8:39	20.47	5.54	0.029	147.70	113.32	
6/21/2022 8:40	20.39	5.50	0.029	146.38	114.52	
6/21/2022 8:41	20.45	5.78	0.029	144.87	115.83	
6/21/2022 8:42	20.40	5.74	0.029	141.68	114.81	
6/21/2022 8:43	20.33	5.88	0.029	140.27	114.59	
6/21/2022 8:44	20.31	6.03	0.030	137.85	113.58	
Average:		20.40	5.65	0.029	146.15	117.35

Tilden Mining Company L.C. EU-BOILER4: Run 3

Start Time: 06/21/2022 08:54:00

End Time: 06/21/2022 09:18:59

@ Missing Date:Time	& Offline		# Invalid EU-Boiler 4 NOx ppm 1-Minute	* Deviation EU-Boiler 4 NOx lb/mmBtu 1-Minute	(blank) No Value EU-Boiler 4 Gas kscf/hr 1-Minute	^ Outside Limit EU-Boiler 4 Steam klb/hr 1-Minute
	EU-Boiler 4	EU-Boiler 4				
	NOx ppm	O2 pct				
6/21/2022 8:54	20.27	6.08		0.030	136.44	107.66
6/21/2022 8:55	20.42	6.01		0.030	136.89	107.78
6/21/2022 8:56	20.33	6.03		0.030	136.80	106.91
6/21/2022 8:57	20.20	6.05		0.030	136.66	106.92
6/21/2022 8:58	20.37	5.88		0.029	136.57	108.00
6/21/2022 8:59	20.28	5.91		0.029	136.94	109.07
6/21/2022 9:00	20.27	6.02		0.030	136.62	111.23
6/21/2022 9:01	20.33	6.06		0.030	136.34	112.90
6/21/2022 9:02	20.23	6.00		0.029	136.48	112.69
6/21/2022 9:03	20.17	6.03		0.029	136.62	113.49
6/21/2022 9:04	20.40	5.78		0.029	137.16	112.72
6/21/2022 9:05	20.16	5.92		0.029	136.94	113.40
6/21/2022 9:06	20.26	6.11		0.030	137.26	111.59
6/21/2022 9:07	20.32	5.98		0.030	137.16	111.35
6/21/2022 9:08	20.14	5.99		0.029	136.80	111.23
6/21/2022 9:09	20.30	6.06		0.030	136.53	110.33
6/21/2022 9:10	20.28	6.13		0.030	136.30	109.81
6/21/2022 9:11	20.33	5.94		0.030	137.21	107.92
6/21/2022 9:12	20.27	5.91		0.029	137.35	106.66
6/21/2022 9:13	20.27	5.90		0.029	136.94	106.28
6/21/2022 9:14	20.33	6.05		0.030	137.12	106.94
6/21/2022 9:15	20.23	5.85		0.029	136.75	106.64
6/21/2022 9:16	20.30	5.98		0.030	137.35	107.15
6/21/2022 9:17	20.35	5.95		0.030	137.21	108.60
6/21/2022 9:18	20.20	5.93		0.029	136.98	107.90
Average:		20.28	5.98	0.030	136.86	109.41

Tilden Mining Company L.C. EU-BOILER4: Run 4

Start Time: 06/21/2022 09:29:00

End Time: 06/21/2022 09:53:59

@ Missing Date:Time	& Offline EU-Boiler 4 NOx ppm 1-Minute	# Invalid EU-Boiler 4 O2 pct 1-Minute	* Deviation EU-Boiler 4 NOx lb/mmbtu 1-Minute	(blank) No Value EU-Boiler 4 Gas kscf/hr 1-Minute	^ Outside Limit	
					EU-Boiler 4 NOx lb/mmbtu 1-Minute	EU-Boiler 4 Steam klb/hr 1-Minute
					EU-Boiler 4 Gas kscf/hr 1-Minute	EU-Boiler 4 Steam klb/hr 1-Minute
6/21/2022 9:29	20.36	5.85	0.029	137.30		107.70
6/21/2022 9:30	20.28	5.88	0.029	136.85		108.79
6/21/2022 9:31	20.29	6.07	0.030	136.75		108.29
6/21/2022 9:32	20.35	5.95	0.030	137.03		108.19
6/21/2022 9:33	20.28	5.93	0.029	136.89		108.70
6/21/2022 9:34	20.20	6.06	0.030	137.21		109.71
6/21/2022 9:35	20.35	6.00	0.030	136.80		110.03
6/21/2022 9:36	20.14	6.02	0.029	136.62		111.78
6/21/2022 9:37	20.24	6.01	0.030	137.12		112.15
6/21/2022 9:38	20.30	6.02	0.030	136.94		113.77
6/21/2022 9:39	20.30	5.88	0.029	136.44		113.49
6/21/2022 9:40	20.34	5.64	0.029	136.85		113.20
6/21/2022 9:41	20.34	6.12	0.030	136.75		111.78
6/21/2022 9:42	20.27	5.98	0.030	137.07		111.74
6/21/2022 9:43	20.36	6.12	0.030	136.94		111.02
6/21/2022 9:44	20.33	5.94	0.030	136.39		109.80
6/21/2022 9:45	20.19	5.83	0.029	136.57		108.89
6/21/2022 9:46	20.38	5.84	0.029	137.30		107.63
6/21/2022 9:47	20.36	6.02	0.030	136.94		106.81
6/21/2022 9:48	20.28	5.86	0.029	136.94		105.93
6/21/2022 9:49	20.37	5.91	0.030	137.26		105.91
6/21/2022 9:50	20.35	5.76	0.029	136.80		106.64
6/21/2022 9:51	20.18	5.91	0.029	136.57		107.10
6/21/2022 9:52	20.27	5.89	0.029	137.12		107.06
6/21/2022 9:53	20.37	5.84	0.029	136.85		108.72
Average:	20.30	5.93	0.029	136.89		109.39

RECEIVED

AUG 02 2022

AIR QUALITY DIVISION

Tilden Mining Company L.C. EU-BOILER4: Run 5

Start Time: 06/21/2022 10:04:00

End Time: 06/21/2022 10:28:59

@ Missing Date:Time	& Offline EU-Boiler 4 NOx ppm 1-Minute	# Invalid	* Deviation	(blank)	No Value	^ Outside Limit
		EU-Boiler 4 O2 pct 1-Minute	EU-Boiler 4 NOx lb/mmbtu 1-Minute	EU-Boiler 4 Gas kscf/hr 1-Minute	EU-Boiler 4 Steam klb/hr 1-Minute	
6/21/2022 10:04	20.04	6.09	0.029	139.58	110.96	
6/21/2022 10:05	19.87	5.77	0.029	139.40	109.69	
6/21/2022 10:06	19.94	6.08	0.029	139.86	110.86	
6/21/2022 10:07	20.03	6.02	0.029	138.94	110.38	
6/21/2022 10:08	19.90	6.08	0.029	139.49	109.89	
6/21/2022 10:09	20.05	5.93	0.029	139.17	110.75	
6/21/2022 10:10	19.97	5.87	0.029	139.67	110.01	
6/21/2022 10:11	20.06	6.02	0.029	139.49	111.56	
6/21/2022 10:12	19.84	5.94	0.029	139.31	113.34	
6/21/2022 10:13	19.88	5.90	0.029	139.63	114.55	
6/21/2022 10:14	20.00	6.00	0.029	139.22	115.42	
6/21/2022 10:15	19.97	5.84	0.029	139.81	115.26	
6/21/2022 10:16	20.03	5.86	0.029	139.81	117.47	
6/21/2022 10:17	19.96	5.78	0.029	139.40	116.02	
6/21/2022 10:18	20.42	5.66	0.029	139.49	114.19	
6/21/2022 10:19	20.49	5.62	0.029	139.76	113.52	
6/21/2022 10:20	20.35	5.72	0.029	139.54	113.40	
6/21/2022 10:21	20.38	5.77	0.029	139.90	112.03	
6/21/2022 10:22	20.47	5.61	0.029	139.86	110.71	
6/21/2022 10:23	20.48	5.66	0.029	139.76	109.16	
6/21/2022 10:24	20.52	5.75	0.029	139.95	108.06	
6/21/2022 10:25	20.41	5.62	0.029	138.81	107.99	
6/21/2022 10:26	20.39	5.82	0.029	139.44	107.45	
6/21/2022 10:27	20.51	5.60	0.029	139.90	108.11	
6/21/2022 10:28	20.35	5.59	0.029	140.36	109.59	
Average:		20.17	5.82	0.029	139.58	111.61

Tilden Mining Company L.C. EU-BOILER4: Run 6

Start Time: 06/21/2022 10:39:00

End Time: 06/21/2022 11:03:59

@ Missing Date:Time	& Offline		# Invalid	* Deviation	(blank)	No Value	^ Outside Limit
	EU-Boiler 4		EU-Boiler 4	EU-Boiler 4 NOx		EU-Boiler 4	EU-Boiler 4
	NOx ppm	O2 pct	1-Minute	lb/mmBtu	1-Minute	Gas kscf/hr	Steam klb/hr
	1-Minute		1-Minute		1-Minute	1-Minute	1-Minute
6/21/2022 10:39	20.49	5.79		0.029		139.22	110.18
6/21/2022 10:40	20.53	5.63		0.029		139.40	110.19
6/21/2022 10:41	20.42	5.83		0.029		139.44	109.21
6/21/2022 10:42	20.50	5.78		0.029		139.31	110.30
6/21/2022 10:43	20.43	5.72		0.029		139.58	109.66
6/21/2022 10:44	20.40	5.55		0.029		139.86	110.14
6/21/2022 10:45	20.48	5.65		0.029		139.54	110.56
6/21/2022 10:46	20.45	5.49		0.029		140.13	112.43
6/21/2022 10:47	20.33	5.77		0.029		139.63	113.00
6/21/2022 10:48	20.54	5.72		0.029		139.22	113.94
6/21/2022 10:49	20.43	5.55		0.029		138.90	115.64
6/21/2022 10:50	20.38	5.69		0.029		139.90	115.89
6/21/2022 10:51	20.51	5.75		0.029		139.58	116.49
6/21/2022 10:52	20.36	5.57		0.029		139.40	115.45
6/21/2022 10:53	20.57	5.81		0.030		139.76	113.89
6/21/2022 10:54	20.45	5.56		0.029		140.13	113.25
6/21/2022 10:55	20.49	5.82		0.030		139.22	112.41
6/21/2022 10:56	20.48	5.59		0.029		139.49	111.74
6/21/2022 10:57	20.40	5.63		0.029		139.90	109.84
6/21/2022 10:58	20.45	5.71		0.029		139.63	109.09
6/21/2022 10:59	20.32	5.65		0.029		139.26	107.70
6/21/2022 11:00	20.51	5.70		0.029		140.04	107.95
6/21/2022 11:01	20.37	5.87		0.029		139.44	106.98
6/21/2022 11:02	20.52	5.47		0.029		139.72	107.98
6/21/2022 11:03	20.50	5.72		0.029		140.04	110.73
Average:	20.45	5.68		0.029		139.59	111.39

Tilden Mining Company L.C. EU-BOILER4: Run 7

Start Time: 06/21/2022 11:14:00

End Time: 06/21/2022 11:38:59

@ Missing Date:Time	& Offline EU-Boiler 4 NOx ppm 1-Minute	# Invalid	* Deviation	(blank)	No Value	^ Outside Limit
		EU-Boiler 4 O2 pct	EU-Boiler 4 NOx lb/mmBtu	EU-Boiler 4 Gas kscf/hr	EU-Boiler 4 Steam klb/hr	
		1-Minute	1-Minute	1-Minute	1-Minute	1-Minute
6/21/2022 11:14	20.50	5.72	0.029	139.35	111.11	
6/21/2022 11:15	20.52	5.76	0.029	139.67	109.54	
6/21/2022 11:16	20.34	5.68	0.029	140.08	107.31	
6/21/2022 11:17	20.42	5.83	0.029	139.49	107.06	
6/21/2022 11:18	20.41	5.79	0.029	139.67	107.30	
6/21/2022 11:19	20.41	5.82	0.029	139.67	107.33	
6/21/2022 11:20	20.42	5.72	0.029	139.44	107.69	
6/21/2022 11:21	20.34	5.54	0.029	139.81	108.53	
6/21/2022 11:22	20.41	5.73	0.029	139.44	110.04	
6/21/2022 11:23	20.37	5.73	0.029	139.76	111.82	
6/21/2022 11:24	20.35	5.74	0.029	139.17	114.46	
6/21/2022 11:25	20.42	5.70	0.029	139.54	115.59	
6/21/2022 11:26	20.29	5.74	0.029	139.58	115.50	
6/21/2022 11:27	20.47	5.67	0.029	139.76	114.32	
6/21/2022 11:28	20.35	5.69	0.029	139.95	113.45	
6/21/2022 11:29	20.44	5.79	0.029	139.81	112.64	
6/21/2022 11:30	20.31	5.67	0.029	139.86	111.26	
6/21/2022 11:31	20.37	5.75	0.029	139.90	110.95	
6/21/2022 11:32	20.36	5.45	0.029	139.58	110.52	
6/21/2022 11:33	20.36	5.65	0.029	139.40	110.74	
6/21/2022 11:34	20.47	5.62	0.029	140.08	109.68	
6/21/2022 11:35	20.26	5.96	0.029	139.72	110.83	
6/21/2022 11:36	20.36	5.69	0.029	139.90	109.45	
6/21/2022 11:37	20.42	5.73	0.029	139.99	111.10	
6/21/2022 11:38	20.30	5.71	0.029	140.13	109.73	
Average:	20.39	5.71	0.029	139.71	110.72	

Tilden Mining Company L.C. EU-BOILER4: Run 8

Start Time: 06/21/2022 11:50:00

End Time: 06/21/2022 12:14:59

Date:Time	EU-Boiler 4 NOx ppm 1-Minute	# Invalid	* Deviation (blank) No Value	^ Outside Limit	
				EU-Boiler 4 O2 pct 1-Minute	EU-Boiler 4 NOx lb/mmBtu 1-Minute
6/21/2022 11:50	20.26	5.64	0.029	139.49	109.10
6/21/2022 11:51	20.49	5.64	0.029	139.76	108.24
6/21/2022 11:52	20.25	5.62	0.029	139.90	107.48
6/21/2022 11:53	20.48	5.64	0.029	139.99	108.03
6/21/2022 11:54	20.39	5.60	0.029	139.76	108.56
6/21/2022 11:55	20.41	5.67	0.029	139.63	108.57
6/21/2022 11:56	20.37	5.70	0.029	140.04	108.46
6/21/2022 11:57	20.30	5.48	0.029	139.54	109.76
6/21/2022 11:58	20.47	5.74	0.029	139.58	111.07
6/21/2022 11:59	20.30	5.57	0.029	139.40	112.72
6/21/2022 12:00	20.43	5.73	0.029	139.86	116.18
6/21/2022 12:01	20.41	5.66	0.029	139.81	115.61
6/21/2022 12:02	20.43	5.91	0.030	139.13	115.20
6/21/2022 12:03	20.41	5.74	0.029	139.26	113.44
6/21/2022 12:04	20.28	5.44	0.029	139.95	113.17
6/21/2022 12:05	20.44	5.80	0.029	139.44	111.62
6/21/2022 12:06	20.22	5.87	0.029	137.16	110.61
6/21/2022 12:07	20.37	5.70	0.029	139.90	109.30
6/21/2022 12:08	20.43	5.65	0.029	139.95	109.99
6/21/2022 12:09	20.33	5.52	0.029	139.63	110.73
6/21/2022 12:10	20.42	5.70	0.029	139.22	108.75
6/21/2022 12:11	20.40	5.75	0.029	139.26	111.30
6/21/2022 12:12	20.37	5.52	0.029	139.26	111.56
6/21/2022 12:13	20.39	5.56	0.029	139.49	112.48
6/21/2022 12:14	20.33	5.60	0.029	139.40	114.03
Average:		20.37	5.66	0.029	139.51
					111.04

Tilden Mining Company L.C. EU-BOILER4: Run 9

Start Time: 06/21/2022 12:24:00

End Time: 06/21/2022 12:48:59

Date:Time	& Offline EU-Boiler 4 NOx ppm 1-Minute	# Invalid	* Deviation	(blank) No Value	^ Outside Limit
		EU-Boiler 4 O2 pct	EU-Boiler 4 NOx lb/mmBtu 1-Minute	EU-Boiler 4 Gas kscf/hr 1-Minute	EU-Boiler 4 Steam klb/hr 1-Minute
6/21/2022 12:24	20.44	5.62	0.029	140.08	111.52
6/21/2022 12:25	20.18	5.68	0.029	138.49	109.41
6/21/2022 12:26	20.36	6.00	0.030	139.13	108.06
6/21/2022 12:27	20.35	5.64	0.029	139.22	107.32
6/21/2022 12:28	20.35	5.77	0.029	139.72	107.29
6/21/2022 12:29	20.41	5.58	0.029	139.90	109.61
6/21/2022 12:30	20.35	5.67	0.029	139.72	110.53
6/21/2022 12:31	20.25	5.54	0.029	139.90	112.12
6/21/2022 12:32	20.36	5.45	0.029	140.27	114.83
6/21/2022 12:33	20.40	5.48	0.029	140.08	115.61
6/21/2022 12:34	20.34	5.79	0.029	139.54	116.29
6/21/2022 12:35	20.38	5.73	0.029	138.99	115.92
6/21/2022 12:36	20.42	5.60	0.029	139.22	114.94
6/21/2022 12:37	20.29	5.63	0.029	140.13	114.58
6/21/2022 12:38	20.33	5.50	0.029	139.44	113.92
6/21/2022 12:39	20.43	5.62	0.029	139.86	113.01
6/21/2022 12:40	20.31	5.68	0.029	139.44	111.79
6/21/2022 12:41	20.43	5.93	0.030	139.95	109.99
6/21/2022 12:42	20.39	5.66	0.029	139.86	109.68
6/21/2022 12:43	20.29	5.77	0.029	139.95	108.25
6/21/2022 12:44	20.42	5.58	0.029	139.44	107.83
6/21/2022 12:45	20.35	5.71	0.029	139.26	108.11
6/21/2022 12:46	20.36	5.65	0.029	139.76	108.97
6/21/2022 12:47	20.43	5.90	0.030	139.86	110.67
6/21/2022 12:48	20.33	5.42	0.029	139.72	112.35
Average:		20.36	5.66	0.029	139.64
					111.30