



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
WARREN DISTRICT OFFICE



LIESL EICHLER CLARK  
DIRECTOR

March 22, 2022

VIA E-MAIL

Mr. Michael Waters  
Manager, Transmission and Storage Operations  
DTE Gas Company - Belle River Mills Compressor Station  
5440 Puttygut Road  
China, MI 48054

SRN: B6478, St. Clair County

Dear Mr. Anderson:

**VIOLATION NOTICE**

On February 24, 2022, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted a review of the renewable operating permit semi-annual/annual report of DTE Gas Company - Belle River Mills Compressor Station located at 5440 Puttygut Road, China, Michigan. The purpose of this review was to determine Belle River Mills Compressor Station's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and the conditions of Renewable Operating Permit (ROP) number MI-ROP-B6478-2021.

During the review, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
Large, existing, glycol dehydration unit	EUDEHY S.C. V.4	DTE submitted records on February 7, 2022, indicating the required annual "no detectable emissions" annual testing had not been completed in 2021.

Although the e-mail dated March 4, 2022, from Joseph Neruda outlines the corrective action towards the cited violation, please review all the conditions of Renewable Operating Permit (ROP) number MI-ROP-B6478-2021 to make sure meeting all compliance timely and submit a written response to this Violation Notice by April 12, 2022 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes

Mr. Michael Waters  
DTE Gas Company - Belle River Mills Compressor Station  
Page 2  
March 22, 2022

and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to EGLE, AQD, Warren District, at 27700 Donald Court, Warren, Michigan 48092 and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If DTE believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number or e-mail listed below.

Sincerely,



Mark Dziadosz  
Senior Environmental Quality Analyst  
Air Quality Division  
586-854-1611 or [dziadoszm@michigan.gov](mailto:dziadoszm@michigan.gov)

cc: Ms. Mary Ann Dolehanty, EGLE  
Dr. Eduardo Olaguer, EGLE  
Ms. Jenine Camilleri, EGLE  
Mr. Christopher Ethridge, EGLE  
Ms. Joyce Zhu, EGLE