

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Midland Cogeneration Venture	SRN : B6527
Location : 100 E. Progress Place	District : Bay City
	County : MIDLAND
City : MIDLAND State: MI Zip Code : 48640	Compliance Status : Compliance
Source Class : MAJOR	Staff : Benjamin Wittkopp
FCE Begin Date : 6/16/2020	FCE Completion Date : 6/16/2021
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/16/2021	On-site Inspection	Compliance	On site and records review
06/08/2021	MAERS	Compliance	timely
05/11/2021	Excess Emissions (CEM)	Compliance	Quarterly Excess Emissions Monitoring Reports - TPU issue - CEMS unit 5 had 8.56% down time. However, a CEMS Downtime and Corrective Actions Report was submitted as required. Levels above 10% would trigger a VN. Several units were over emission limits but for short periods.
04/22/2021	ROP Annual Cert	Compliance	received timely
04/15/2021	ROP SEMI 2 CERT	Compliance	received timely
03/10/2021	Excess Emissions (CEM)	Compliance	Quarterly emissions monitoring reports - Several units were over emission limits but for short periods
11/19/2020	Stack Test	Compliance	well under limits
11/17/2020	Excess Emissions (CEM)	Non Compliance	Quarterly Emissions Monitoring Reports - TPU issued VN unit 18 had 11.72% downtime & unit 19 had 13.61% downtime. Several units were over emission limits but for short periods
10/20/2020	ROP Semi 1 Cert	Compliance	received timely
08/18/2020	Excess Emissions (CEM)	Compliance	Quarterly emissions monitoring reports - TPU issue - CEMS unit 18 had 27.75% down time but due primarily to QA cal. Several units were over emission limits but for short periods
07/07/2020	MAERS	Compliance	

Name: B. Wittkopp

Date: 9-28-21

Supervisor: C. Hare