



1531 Wyngate Drive • Deland, FL 32724
Phone: (386) 451-7166 • Fax: (386) 451-7167
www.coastalairconsulting.com

**RELATIVE ACCURACY TEST AUDIT
TEST REPORT**
No. 191-002

**MIDLAND COGENERATION VENTURE
MIDLAND MICHIGAN**

**EU TURBINES 03-08
(Units 3-8)**

Prepared for:

Midland Cogeneration Venture
100 Progress Place
Midland, Michigan 48640

Prepared by:

Coastal Air Consulting, Inc.
1531 Wyngate Dr.
DeLand, FL 32724
(386) 451-0169

Completed On:

August 22, 23 & 26, 2022

STATEMENT OF VALIDITY

All testing activities and results represented herein were conducted and obtained in accordance with the approved EPA protocols listed in 40 CFR Parts 60 & 75. The contents have been reviewed and verified to be true and correct.

Stephen C. Webb

Stephen Webb

Digitally signed by Stephen Webb
DN: cn=Stephen Webb, o=Coastal Air
Consulting, Inc., ou,
email=coastalair123@aol.com, c=US
Date: 2022.10.05 08:24:08 -04'00'

President
Coastal Air Consulting, Inc.

TABLE OF CONTENTS

LETTER OF TRANSMITTAL

TITLE PAGE

EXECUTIVE SUMMARY

PROJECT STATISTICS

TABLE OF CONTENTS

- 1 Introduction
- 2 Test Program Summary
- 3 Results of testing
- 4 Description of Source
- 5 Sampling Procedures
- 6 Operating Conditions
- 7 Quality Assurance

APPENDICES

- 1 Reference Data
- 2 Plant Data
- 3 Quality Assurance
- 4 Sample Calculations
- 5 Figures
- 6 QSTI

PROJECT STATISTICS

Client: Midland Cogeneration Venture (MCV)

Facility: Midland Michigan Generating Station

Location: 100 ProgressPlace
Midland, Michigan 48640

Type of Process Tested: EU 03-08 Unfired Duct Burners

Test Protocols Performed: Oxygen/Carbon Dioxide-EPA Method 3A
Nitrogen Oxide -EPA Method 7E

Testing Firm: Coastal Air Consulting, Inc.
1531 Wyngate Dr.
DeLand, FL 32724

Test Personnel: Stephen Webb QSTI
Troy Marlowe
James Garrett

Test Dates: August 22, 23 & 26, 2022

Client Representative: Jim Lazzaro

Observers: Dan Droste - MDEQ

RECEIVED
OCT 18 2022
AIR QUALITY DIVISION

1.0 Introduction

Coastal Air Consulting, Inc. (Coastal) was contracted by Midland Cogeneration Venture (MCV) to perform the annual RATA testing for NO_x. Testing was performed to satisfy the requirements contained in the Michigan Department of Environmental Quality (MDEQ) Renewable Operating Permit (ROP) No. MI-ROP-B6527a. The testing was performed by Coastal personnel, with the assistance of personnel assigned by Midland Cogeneration Venture (MCV).

2.0 Test Program Summary

A summary of test results developed by this source sampling program is presented in Table 1.

TABLE 1
Relative Accuracy Summary

UNIT	DATE	PARAMETERS	RELATIVE ACCURACY	BIAS	ALLOWABLE ANNUAL
EU 03	8/26/2022	NO _x (lb/mmBtu)	4.834 %	NB	7.5%
EU 04	8/26/2022	NO _x (lb/mmBtu)	5.161 %	NB	7.5%
EU 05	8/22/2022	NO _x (lb/mmBtu)	3.888 %	NB	7.5%
EU 06	8/22/2022	NO _x (lb/mmBtu)	7.231 %	NB	7.5%
EU 07	8/23/2022	NO _x (lb/mmBtu)	5.621 %	NB	7.5%
EU 08	8/23/2022	NO _x (lb/mmBtu)	7.124 %	NB	7.5%

3.0 Results of Testing

Testing was conducted according to the procedures in the Code of Federal Regulations, Title 40, Part 75 (40CFR75), Appendix A. Reference Methods 3A and 7E, as defined in 40 CFR 60 Appendix A, were used to determine Carbon Dioxide and Nitrogen Oxides. The NO_x CEMS Relative Accuracy was performed using 40CFR75 Appendix A Section 6.5. NO_x Relative Accuracy results must meet the criteria of 40CFR75 Appendix A, Section 3.3 and shall not exceed 10.0% (or 7.5% to achieve reduced RATA frequency incentive for annual RATAs). Exceptions are as follows:

Low NO_x emitting units (≤ 0.2 lb/MMBtu): the difference between the mean value of the CEMS measurements and the reference method mean value is not to exceed ± 0.02 lb/mmBtu whenever the Relative Accuracy is greater than 10% (or ± 0.015 lb/mmBtu for reduced RATA frequency).

A stratification test was performed in accordance with section 6.5.6.2 of 40 CFR part 75 Appendix A. No stratification was found.

These results indicate that Units EU03 – EU08 passed the compliance testing at the time of testing under normal operating conditions.

4.0 Description of Source

The MCV Units 3-8 are operated as a cycling facility, in that they are expected to be brought on-line and off-line several times per day, most often during the summer months. The plant may also be dispatched at other appropriate times whenever system demand, capacity/steam and commercial energy availability, market, and/or as emergency conditions dictate. Each unit is a combined-cycle natural gas-fired turbine rated brought on-line and off-line several times per day, most often during the summer at 984 MMBtu/hr at ISO conditions. Each turbine is equipped with steam injection for NO_x control.

The following serial numbers are associated with each dedicated CEMS.

Emission Unit	Pollutant	Serial Number
Unit 3 EUTURBINE 03	NO _x	1413461772
	CO ₂	N1-ND-0872
Unit 4 EUTURBINE 04	NO _x	1413461773
	CO ₂	N1-ND-0851
Unit 5 EUTURBINE 05	NO _x	1413461774
	CO ₂	N1-ND-0850
Unit 6 EUTURBINE 06	NO _x	1413461775
	CO ₂	N1-ND-0853
Unit 7 EUTURBINE 07	NO _x	1314158017
	CO ₂	N1-ND-0857
Unit 8 EUTURBINE 08	NO _x	1314158019
	CO ₂	N1-ND-0855

5.0 Sampling Procedures

EPA testing methods utilized during this test program include the following;

EPA Method 3A Gas Analysis for CO₂, O₂, Excess Air and Dry Molecular Weight (Instrumental Analyzer Method)

EPA Method 7E Determination of Nitrogen Oxides Emissions From Stationary Sources

6.0 Operating Conditions

MCV personnel monitored operating conditions throughout the duration of the sampling program. The data is included in Appendix 2 "Plant Data".

7.0 Quality Assurance Procedures

Quality assurance procedures followed during these testing activities were applied consistent with the requirements outlined by the EPA methods referenced in 40 CFR Parts 60 & 75.

RECEIVED
OCT 18 2022
AIR QUALITY DIVISION