

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : ANR -- Rapid River Compressor Station	SRN : B7197
Location : 2170 Rabourn Rd. NE	District : Gaylord
	County : KALKASKA
City : KALKASKA State: MI Zip Code : 49646	Compliance Status : Compliance
Source Class : MAJOR	Staff : Bill Rogers
FCE Begin Date : 2/20/2014	FCE Completion Date : 2/19/2015
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
02/19/2015	Scheduled Inspection	Compliance	Compliance inspection, observed stack test, observed natural gas sampling, observed Leak Detection and Repair (LDAR) inspection, record review
02/13/2015	ROP Other	Compliance	Small Glycol Dehydration Unit Test Notification for February 3, 2015 through March 4, 2015.
02/13/2015	ROP SEMI 2 CERT	Compliance	For ROP No. MI-ROP-B7197-2012a Properly certified. It claims compliance with no deviations.
02/13/2015	ROP Other	Compliance	Control equipment alarm log for dehydrator thermal oxidizer. Most alarms were false with dehy not running or oxidizer getting up to temperature before production. Two "near misses" which did not quite violate permit limit, two days (5 2-min. alarm periods) thermal oxidizer offline, they used the backup condenser.
02/13/2015	ROP Annual Cert	Compliance	ROP Annual Certification. Properly certified. It claims compliance with no deviations.
09/04/2014	ROP Semi 1 Cert	Compliance	Properly certified. Claims compliance with no deviations.
09/04/2014	ROP Other	Compliance	Semi-annual Control Equipment Alarm Event Log Several alarms, but as alarm point is above required temperature, no deviations. Also a false alarm when dehydrator was offline.

Activity Date	Activity Type	Compliance Status	Comments
03/20/2014	MAERS	Compliance	2013 MAERS, Check MAERS for any review comments Passed audit, properly certified

Name: William J Rogers Date: 2/20/2015

Supervisor: 

 Page 2 of 2