

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : BAY CITY ELECTRIC LIGHT & POWER	SRN : B7529
Location : 900 S WATER ST	District : Saginaw Bay
	County : BAY
City : BAY CITY State: MI Zip Code : 48708	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Gina McCann
FCE Begin Date : 1/1/2014	FCE Completion Date : 1/13/2016
Comments : FCE from January 1, 2014 through January 13, 2016. glm	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
01/07/2016	Scheduled Inspection	Compliance	Inspection of SM-Opt Out 587-96A.
08/14/2014	Stack Test	Compliance	MACT demonstration for >70% CO reduction. Engine #1 avg =87.15%, Engine #2 =87.32% reduction
05/01/2014	208A Registration	Compliance	208a Annual Renewal Registration

Name:  Date: 1/13/2016 Supervisor: 