



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
DETROIT



DAN WYANT  
DIRECTOR

December 16, 2015

Mr. Linwood Bubar  
Detroit Renewable Power  
5700 Russell St.  
Detroit, MI 48211

SRN: M4148, Wayne County

Dear Mr. Bubar:

**VIOLATION NOTICE**

On Dec. 16, 2015, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), received the Notification of Exceedance of Carbon Monoxide (CO) Emissions report for Detroit Renewable Power, located at 5700 Russell St., Detroit, Michigan. The notification report reveals the following:

Process Description	Rule/Permit Condition Violated	Comments
Refuse-derived fuel (RDF) fired boiler #12	ROP No. MI-ROP-M4148-2011, Table FGBOILERS011-013, Condition I. 11.	The CO emission based on a 1-hour block average exceeded 267 ppmv during operating hours 6:00 – 13:59 on 12/11/15.
RDF fired boiler #13	ROP No. MI-ROP-M4148-2011, Table FGBOILERS011-013, Condition I. 11.	The CO emission based on a 1-hour block average exceeded 267 ppmv during operating hours 6:00 – 9:59 on 12/15/15.

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by January 6, 2016 (which coincides with 21 calendar days from the date of this letter). The written response should include: causes of the violation; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Detroit Renewable Power believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Mr. Linwood Bubar  
Page 2  
December 16, 2015

Thank you for your attention to resolving the violations cited above. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Joyce Zhu  
Senior Environmental Engineer  
Air Quality Division  
586-753-3748

cc: Mr. Damian Doerfer, DRP  
Ms. LaReina Wheeler, City of Detroit, BSEED  
cc/via e-mail: Ms. Lynn Fiedler, DEQ  
Ms. Mary Ann Dolehanty, DEQ  
Ms. Teresa Seidel, DEQ  
Mr. Thomas Hess, DEQ  
Ms. Wilhemina McLemore, DEQ  
Mr. Jeff Korniski, DEQ