



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
DETROIT



KEITH CREAGH  
DIRECTOR

February 12, 2016

Mr. Linwood Bubar  
Detroit Renewable Power  
5700 Russell St.  
Detroit, MI 48211

SRN: M4148, Wayne County

Dear Mr. Bubar:

**VIOLATION NOTICE**

On February 9, 2016, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), received the annual emission test report for emissions from the three boilers located at Detroit Renewable Power, which is at 5700 Russell St., Detroit, Michigan. The testing report reveals the following:

Process Description	Rule/Permit Condition Violated	Comments
Refuse-derived fuel (RDF) fired boiler #11	<ul style="list-style-type: none"> <li>• ROP No. MI-ROP-M4148-2011a Table FGBOILERS011-013, Condition I.1.</li> <li>• 40 CFR 62 Subpart FFF 62.14103(a)(1) &amp; 62.14109,</li> <li>• 40 CFR 60 Subpart Cb 60.33b(a)(1),</li> <li>• 40 CFR 60 Subpart Db 60.43b(d)(1), and</li> <li>• 40 CFR 60 Subpart Eb 60.58b(a)(1).</li> </ul>	The Particulate Matter (PM) emission exceeded 0.010 grains/dscf corrected to 7% oxygen during the stack test on 12/2/2015


Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by March 4, 2016 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Detroit Renewable Power believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Mr. Linwood Bubar  
Page 2  
February 12, 2016

Thank you for your attention to resolving the violations cited above. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

A handwritten signature in black ink, appearing to read "Joyce Zhu", with a long horizontal flourish extending to the right.

Joyce Zhu  
Senior Environmental Engineer  
Air Quality Division  
586-753-3748

cc: Mr. Damian Doerfer, DRP  
Ms. LaReina Wheeler, City of Detroit, BSEED  
cc/via e-mail: Ms. Lynn Fiedler, DEQ  
Ms. Teresa Seidel, DEQ  
Ms. Heidi Hollenbach, DEQ  
Mr. Thomas Hess, DEQ  
Ms. Wilhemina McLemore, DEQ  
Mr. Jeff Korniski, DEQ