

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (763) 786-6020
FAX: (763) 786-7854

**RESULTS OF THE MAY 6-7, 2020
AIR EMISSION COMPLIANCE TESTING
AT THE LOUISIANA PACIFIC SIDING
PLANT IN NEWBERRY, MICHIGAN**

Submitted to:

LOUISIANA-PACIFIC CORPORATION
7299 North C.R. 403
Newberry, Michigan 49868

Attention:

Nick Waddell

Reviewed by:



Kathleen Eickstadt
Coordinator
Source Testing

Report Number 20-38411
June 8, 2020
KE/kce

TABLE OF CONTENTS

ABBREVIATIONS	iii
1 INTRODUCTION.....	1
2 SUMMARY AND DISCUSSION.....	3
3 RESULTS.....	15
3.1 Results of Gas Composition & Moisture Determinations.....	16
3.2 Particulate/PM-10 Sampling Data.....	21
3.3 Trace Metals Sampling Data	25

APPENDICES:

- A - Test Protocol
- B - Field Data Sheets
- C - Interpoll Laboratories Analytical Results
- D - Computer Datalogger Printouts
- E - Measurement Systems Performance Specifications
- F - Calibration Gas Certification Sheets
- G - Process Rate Information
- H - Procedures
- I - Calculation Equations
- J - Sampling Train Calibration Data

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	Diameter
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/10 ⁶ BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
MW	megawatt
mg/dscm	milligrams per dry standard cubic meter
ug/dscm	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight

Standard conditions are defined as 68 °F (20 °C) and 29.92 IN. of mercury pressure

1 INTRODUCTION

On May 6-7, 2020 Interpoll Laboratories personnel conducted Air Emission compliance testing on the Dryer RTO and Konus Thermal Oil Heater at the Louisiana Pacific Corporation (LP) OSB Plant located in Newberry, Michigan. On-site testing was performed by Scott Fjelsta, Jim Thoma, Chris Warneke, Josh Kircher and Ed Juers. Coordination between testing activities and plant operation was provided by Nick Waddell of Louisiana Pacific Corp. The tests were witnessed by Jeremy Howe and Joseph Scanlon of the State of Michigan Department of Environment, Great Lakes, and Energy.

Particulate evaluations were performed in accordance with EPA Methods 1-5, CFR Title 40, Part 60, and Appendix A (revised July 1, 2019). A preliminary determination of the gas linear velocity profile was made at each test location before the first particulate determination to allow selection of the appropriate nozzle diameter for isokinetic sample withdrawal. An Interpoll Labs sampling train, which meets or exceeds specifications in the above-cited reference was used to isokinetically extract particulate samples by means of a heated glass-lined probe. Wet catch samples were collected in the back half of the Method 5 sampling train and analyzed in accordance with EPA Method 202.

Oxygen, carbon dioxide, oxides of nitrogen, carbon monoxide and total hydrocarbon concentrations were determined in accordance with Methods 3A, 7E, 10 and 25A (*Ibid*). A slipstream of sample gas was withdrawn from the exhaust gas stream using a heated stainless steel probe equipped with a filter to remove interfering particulate material. The particulate-free gas was transported to the analyzers by means of a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser-type moisture removal system. The particulate-free dry gas was then transported to the analyzers with the excess exhausted to the atmosphere through a calibrated orifice, which was used to ensure that the flow from the stack exceeds the requirements of the analyzers.

Total gaseous hydrocarbon concentrations were determined instrumentally using a VIG Model 20/2 heated flame ionization detector (HFID) calibrated against propane in air standards. The THC concentration was continuously monitored by extracting a slipstream of exhaust gas by means of a heated probe and filter holder. A heat-traced Teflon line was used to transport the sample gas

from the filter holder outlet to the analyzer inlet.

The analog response of each analyzer was recorded with a computer datalogger. The O₂, CO₂, NOx, CO and VOC analyzers were calibrated with EPA Protocol 1 standard gases. The instrument was calibrated before and after each run.

Trace metal sampling was performed in accordance with EPA Method 29. The Multi-Metal Modified Method 5 (4M5) sampling train, described in this method, was used to isokinetically collect solid and vapor phase trace metals from the exhaust gas stream at the Stack. The aerosol or solid phase trace metal samples were collected on Pallflex^R Type 2500 QAT ultra pure filters. The vapor phase trace metals were collected in an all glass impinger train. The first and second impingers each contained 100 cc of a mixture of 5% HNO₃ and 10% H₂O₂. The recovered four-part samples were returned to the laboratory where the probe rinse, filter, nitric acid impinger catch was dissolved in acid (including the quartz filter) and analyzed for manganese by Inductively Coupled Argon Plasma Emission Spectrometry (ICP). Two field-biased blanks were collected, recovered and analyzed with the field samples.

The results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The results of the compliance tests are summarized in the following tables. An overview of all results is presented in the table below:

Table 1: Summary of the Test Results

Stack Vent No.: Emission Unit No.	Underlying Applicable Requirements	Pollutant Tested and Applicable Emission Limit	Test Result
(EUDRYERRC) Dryer System Stack P002	EUDRYERRC V Testing and Sampling R336.1202(3)	PM/PM10 0.020 gr/dscf 7.9 lb/hr	PM/PM10 (No Recirc) 0.0029 gr/dscf 1.158 lb/hr
			PM/PM10 (Recirc) 0.0035 gr/dscf 1.266 lb/hr
		CO 23.98 lb/hr	CO (No Recirc) 17.22 lb/hr
			CO (Recirc) 20.20 lb/hr
		NOx 14.8 lb/hr	NOx (No Recirc) 4.31 lb/hr
			NOx (Recirc) 4.89 lb/hr
		VOC 5.12 lb/hr	VOC (No Recirc) 2.63 lb Carbon/hr
			VOC (Recirc) 3.24 lb Carbon/hr
		Acetaldehyde 1.17 lb/hr	Acetaldehyde (No Recirc) 0.70 lb/hr
			Acetaldehyde (Recirc) 0.74 lb/hr
		Acrolein 0.195 lb/hr	Acrolein (No Recirc) 0.29 lb/hr
			Acrolein (Recirc) 0.31 lb/hr
		Formaldehyde 1.11 lb/hr	Formaldehyde (No Recirc) 1.78 lb/hr
			Formaldehyde (Recirc) 1.89 lb/hr
		Manganese 0.03 lb/hr	Manganese (No Recirc) ≤ 0.001 lb/hr
			Manganese (Recirc) ≤ 0.001 lb/hr

Stack Vent No.: Emission Unit No.	Underlying Applicable Requirements	Pollutant Tested and Applicable Emission Limit	Test Result
Thermal Oil Heater (EUKONUSTOH) Stack P001	R336.1205 (3) R336.1331	PM/PM10 4.3 lb/hr 0.081 lb/1,000 lb exhaust gases corrected to 50% excess air	PM/PM10 0.508 lb/hr 0.019 lb/1,000 lb exhaust gases corrected to 50% excess air
		CO 26.1b/hr 0.87 lb/MMBtu	CO 4.82 lb/hr 0.246 lb/MMBtu
		NOx 15.5 lb/hr 0.4 lb/MMBtu	NOx 4.08 lb/hr 0.211 lb/MMBtu
		VOC 0.77 lb/hr	VOC 0.04 lb carbon/hr

No difficulties were encountered in the field by Interpoll Labs or in the laboratory evaluation of the samples, which were conducted by Interpoll Labs. On the basis of these facts and a complete review of the data and results, it is our opinion that the results reported herein are accurate and closely reflect the actual values, which existed at the time the test was performed.

**Test 9 Summary of the May 6, 2020, PM/PM10 Emission Compliance Test on the Dryer
RTO Outlet (Stack P002) at the LP Facility Located in Newberry, MI.**

(No Dryer Recirculation)		Item	Run 1	Run 2	Run 3	Average
Date of test			05-06-20	05-06-20	05-06-20	
Time (Start/Finish)		(Hrs)	0850 / 0955	1042 / 1147	1216 / 1321	
Volumetric Flow						
Actual	(ACFM)	81,811	83,110	84,335	83,085	
Standard	(SCFM)	59,819	60,795	61,425	60,680	
Dry Standard	(DSCFM)	45,211	46,258	47,088	46,186	
Gas Temperature	(°F)	246	246	249	247	
Moisture Content	(%v/v)	24.42	23.91	23.34	23.89	
Gas Composition	(%v/v, dry)					
Carbon Dioxide		3.50	3.26	3.15	3.30	
Oxygen		17.16	17.23	17.37	17.25	
Nitrogen		79.34	79.51	79.49	79.45	
Sample Volume	(dscf)	51.12	52.32	53.21	52.21	
Isokinetic Variation	(%)	99.2	99.2	99.1	99.2	
Particulate Results-EPA Methods 5 & 202 (Dry Impinger Technique)						
<i>Front Half Dry Catch Only (Filterable only)</i>						
Sample Mass (Nozzle, PW, Filter)	(g)	0.0071	0.0058	0.0021		
Concentration - Actual	(GR/ACF)	0.00118	0.00095	0.00034	0.00083	
Concentration - Actual	(MGI/ACM)	2.709	2.179	0.778	1.88865	
Concentration - Standard	(GR/DSCF)	0.00214	0.00171	0.00061	0.00149	
Emission Rate	(LB/HR)	0.830	0.678	0.246	0.585	
<i>Organic CPM</i>						
Sample Mass	(g)	0.001238462	0.000538462	0.001338462		
Concentration - Actual	(GR/ACF)	0.00021	0.00009	0.00022	0.000171	
Concentration - Actual	(GR/DSCF)	0.00037	0.00016	0.00039	0.000307	
Concentration - Standard	(LB/HR)	0.145	0.063	0.157	0.122	
Emission Rate						
<i>Inorganic CPM</i>						
Sample Mass	(g)	0.003961538	0.004061538	0.003561538		
Concentration - Actual	(GR/ACF)	0.00066	0.00067	0.00058	0.000635	
Concentration - Standard	(GR/DSCF)	0.00120	0.00120	0.00103	0.001142	
Emission Rate	(LB/HR)	0.463	0.475	0.417	0.452	
<i>Total Particulate (Dry + Organic + Inorganic)</i>						
Sample Mass	(g)	0.0123	0.0104	0.007		
Concentration - Actual	(GR/ACF)	0.00205	0.00171	0.00113	0.001630	
Concentration - Standard	(GR/DSCF)	0.00371	0.00307	0.00203	0.002937	
Emission Rate	(LB/HR)	1.439	1.216	0.819	1.158	

**Test 10 Summary of the May 6, 2020, Oxides of Nitrogen, Carbon Monoxide and VOC's Test on the RTO Outlet Duct
at the LP facility located in Newberry, Michigan.**

(No Dryer Recirculation)

Date of test	Item	Run 1 05-06-20 0850 / 0950 (Hrs)	Run 2 05-06-20 1042 / 1142 (Hrs)	Run 3 05-06-20 1216 / 1316 (Hrs)	Average
Time runs were done					
Volumetric Flow					
Actual	(ACFM) (SCFM) (DSCFM)	81,811 59,819 45,211	83,110 60,795 46,258	84,335 61,425 47,088	83,085 60,680 46,186
Standard	(^o F)	246	246	249	247
Standard	(%V/V)	24.42	23.91	23.34	23.89
Gas Temperature					
Moisture Content					
Gas Composition					
Carbon Dioxide	(%v/v, dry)	3.50	3.26	3.15	3.30
Oxygen		17.16	17.23	17.37	17.25
Nitrogen		79.34	79.51	79.49	79.45
Results:					
Oxides of Nitrogen (EPA Method 7E)					
Concentration	(ppm, d) (LB /HR)	14.01 4.54	12.83 4.25	12.32 4.15	13.05 4.31
Emission Rate					
Carbon Monoxide (EPA Method 10)					
Concentration	(ppm, d) (LB /HR)	87.75 17.30	85.81 17.31	82.96 17.03	85.51 17.22
VOC (EPA Method 25a)					
Concentration	(ppm Propane, d) (TGNM ppm Propane, d)	11.60 11.04	10.35 9.55	10.59 9.86	10.85 10.15
Concentration	(ppm Carbon, d) (TGNM ppm Carbon, d)	34.81 33.11	31.06 28.66	31.77 29.57	32.55 30.45
Emission Rate (Lb x/Hr)	(LB Carbon/HR) (TGNM LB Carbon/HR)	2.95 2.80	2.69 2.48	2.80 2.61	2.81 2.63
Emission Rate (Lb x/Hr)	(LB Propane/HR) (TGNM LB Propane/HR)	3.61 3.43	3.29 3.04	3.42 3.19	3.44 3.22

TGNM = Total Gaseous Non-methane

Results of NCASI 98.01 Determinations

Interpoll Laboratories Report Number 20-38411

LP
Newberry, MI

Test Number	RTO Outlet	Run 1	Run 2	Run 3	Average
Date of Test		05-06-20	05-06-20	05-06-20	05-06-20
Time of Runs					
Start	(Hrs)	0850		1042	1216
End	(Hrs)	0950		1142	1316
Total	(Min)	60		60	60
Moisture Content	(%v/v)	24.4		23.9	23.3
Volumetric Flow Rate	(DSCFM)	45.211		46.258	47.088
Sample Volume	(DSL)	20.46	20.17	22.25	24.22
Acetaldehyde	(ppm,d) (ppm,d of duplicate) (LB/HR)	1.88 0.58	3.51 1.75	2.38 0.76	3.62 2.16
					2.34 0.76
					3.56 2.13
					2.20 0.70
Acrolein	(ppm,d) (ppm,d of duplicate) (LB/HR)	0.62 0.243	1.29 0.59	0.79 0.317	1.24 0.66
					0.78 0.322
					1.24 0.67
					0.73 0.29
Formaldehyde	(ppm,d) (ppm,d of duplicate) (LB/HR)	6.98 1.48	9.23 6.82	9.00 1.95	10.78 8.77
					8.76 1.93
					8.83 1.93
					10.80 1.78
					8.83 1.78
					103.54% 1.30%
					0.40% 1.30%

Table 12 Summary of the Results of the May 6, 2020 Manganese Emission Test on the Dryer RTO (Stack P002) at the LP Facility Located in Newberry, MI.

(No Dryer Recirculation)		Item	Run 1			Run 2			Run 3			Average
Date of test	Time runs were done		(Hrs)	05-06-20	05-06-20	05-06-20	05-06-20	05-06-20	05-06-20	05-06-20	05-06-20	
Volumetric Flow												
Actual		(ACFM) (DSCFM)	1355 / 1500			1525 / 1630			1655 / 1800			
Standard		(DSCFM)	47560			46649			47529			
Gas Temperature		(°F)	251			253			251			
Moisture Content		(%v/v)	23.69			24.91			23.86			
Gas Composition		(%v/v, dry)										
Carbon Dioxide			3.61			3.76			3.41			
Oxygen			17.33			17.19			17.24			
Nitrogen			79.06			79.04			79.34			
Isokinetic Variation		(%)	99.7			101.3			98.8			
Sample Volume		(DSCF)	46.94			46.80			46.47			
Results												
Manganese	Concentration - Actual Emission Rate	(ug) < (ug/DSCM) < (LB/HR) <	8.00 6.018 0.001	<	<	8.00 6.036 <	<	<	9.80 7.447 0.001	< < <	< < <	6.500 0.001

"<" = BDL (Below Detection Level)-All analytical levels used to calculate emission values are less than the laboratory's detection levels.

"≤" = DLL (Detection Level Limited)- At least one but not all values used to calculated emission values are less than the laboratory's detection levels.

Test 13 Summary of the Results of the May 6, 2020, Particulate Emission Compliance Test on the Thermal Oil Heater (Stack P001) at the LP Facility Located in Newberry, MI.

	Item	Run 1 05-06-20 (Hrs)	Run 2 05-06-20 (Hrs)	Run 3 05-06-20 (Hrs)	Average
Date of test					
Time (Start/Finish)					
Volumetric Flow					
Actual					
Standard	(ACFM) (SCFM) (DSCFM)	16.976 11,571 10,389	15,997 10,900 9,695	16,273 11,066 9,863	16,415 11,179 9,982
Dry Standard	(°F)	297	298	299	298
Gas Temperature					
Moisture Content	(%v/v)	10.22	11.05	10.87	10.71
Gas Composition	(%v/v, dry)				
Carbon Dioxide		5.48	6.35	6.40	6.08
Oxygen		14.61	14.05	13.93	14.20
Nitrogen		79.91	79.60	79.67	79.73
Sample Volume	(dscf)	59.90	56.30	56.78	57.66
Isokinetic Variation	(%)	99.9	100.6	99.7	100.1
Particulate Results-EPA Methods 5 & 202 (Dry Impinger Technique)					
<i>Front Half Dry Catch Only (filterable only)</i>					
Sample Mass (Nozzle, PW, Filter)	(g)	0.0293	0.0131	0.0145	0.0036
Concentration - Actual	(GR/ACF) (MG/ACM)	0.00462 10.568	0.00218 4.979	0.00239 5.465	7.0038
Concentration - Standard	(GR/DSCF) (LB/HR)	0.00756 0.672	0.00359 0.298	0.00394 0.333	0.00503 0.434
Emission Rate	(LB/MMBTU)	0.034	0.015	0.016	0.022
Emission Factor					
Organic CPM					
Sample Mass	(g)	0.0008	0.0008	0.0009	0.0009
Concentration - Actual	(GR/ACF)	0.00010	0.00014	0.00015	0.000131
Concentration - Standard	(GR/DSCF) (LB/HR)	0.000016 0.015	0.00023 0.019	0.00025 0.021	0.00025 0.018
Emission Rate	(LB/MMBTU)	0.001	0.001	0.001	0.001
Emission Factor					
Inorganic CPM					
Sample Mass	(g)	0.0032	0.0023	0.0019	0.0019
Concentration - Actual	(GR/ACF) (GR/DSCF)	0.00050 0.00082	0.00038 0.00062	0.00031 0.00051	0.00034 0.000648
Concentration - Standard	(LB/HR)	0.073	0.052	0.043	0.056
Emission Rate	(LB/MMBTU)	0.004	0.003	0.002	0.003
Emission Factor					
<i>Total Particulate (Dry + Organic + Inorganic)</i>					
Sample Mass	(g)	0.0331	0.0162	0.0173	0.0173
Concentration - Actual	(GR/ACF) (GR/DSCF)	0.00522 0.00853	0.00269 0.00444	0.00285 0.00470	0.003586 0.005889
Concentration - Standard	(LB/HR)	0.759	0.369	0.397	0.508
Emission Rate	(LB/1,000 LB Flue Gas Corr.to 50% excess air)	0.029	0.014	0.015	0.019
Emission Factor	(LB/MMBTU)	0.039	0.019	0.019	0.026

Test 14

Summary of the Results of the May 6, 2020, Oxides of Nitrogen, Carbon Monoxide and VOCs Test on the Thermal Oil Heater at the Louisiana Pacific Facility located in Newberry, MI.

Date of test	Item	Run 1 05-06-20 (Hrs)	Run 2 05-06-20 1250 / 1350	Run 3 05-06-20 1535 / 1635	Average
Time runs were done					
Volumetric Flow					
Actual	(ACFM) (SCFM) (DSCFM)	16,982 11,576 10,393	16,006 10,906 9,701	16,283 11,072 9,988	16,424 11,185 9,988
Standard					
Standard					
Gas Temperature	(°F)	297	298	299	298
Moisture Content	(%v/v)	10.22	11.05	10.87	10.71
Gas Composition	(%v/v, dry)				
Carbon Dioxide	5.28	6.03	6.13	5.81	
Oxygen	14.82	14.40	14.02	14.41	
Nitrogen	79.90	79.57	79.85	79.77	
Results:					
Oxides of Nitrogen (EPA Method 7E)					
Concentration	(ppm, d) (LB /HR) (lb/mmBTU)	57.19 4.26 0.225	57.76 4.01 0.213	56.08 3.96 0.195	57.01 4.08 0.211
Emission Rate					
Emission Factor					
Carbon Monoxide (EPA Method 10)					
Concentration	(ppm, d) (LB /HR) (lb/mmBTU)	74.74 3.39 0.179	93.42 3.95 0.210	165.32 7.12 0.350	111.16 4.82 0.246
Emission Rate					
Emission Factor					
VOC (EPA Method 25a)					
Concentration	(ppm Propane, d) (TGNM ppm Propane, d)	1.35 0.65	1.78 0.58	2.75 0.68	1.96 0.64
Concentration					
Concentration	(ppm Carbon, d) (TGNM ppm Carbon, d)	4.05 1.95	5.35 1.75	8.24 2.04	5.88 1.91
Concentration					
Emission Rate (Lb x/Hr)	(LB Carbon/LB Carbon/HR)	0.08	0.10	0.15	0.11
Emission Rate (Lb x/Hr)	(TGNM LB Carbon/HR)	0.04	0.03	0.04	0.04
Emission Rate (Lb x/Hr)	(LB Propane/HR)	0.10	0.12	0.19	0.13
Emission Rate (Lb x/Hr)	(TGNM LB Propane/HR)	0.05	0.04	0.05	0.04

TGNM = Total Gaseous Non-methane

Test 15 Summary of the May 7, 2020, PM/PM10 Emission Compliance Test on the Dryer
 RTO (Stack P002) at the LP Facility Located in Newberry, MI.

(With Dryer Recirculation)		Item	Run 1	Run 2	Run 3	Average
Date of test			05-07-20	05-07-20	05-07-20	
Time (Start/Finish)	(Hrs)		0745 / 0850	0915 / 1020	1050 / 1155	
Volumetric Flow						
Actual	(ACFM)	81,801	80,302	79,803	80,636	
Standard	(SCFM)	59,223	58,199	58,120	58,514	
Dry Standard	(DSCFM)	42,185	41,593	42,092	41,957	
Gas Temperature	(°F)	249	248	245	247	
Moisture Content	(%v/v)	28.77	28.53	27.58	28.29	
Gas Composition	(%v/v, dry)					
Carbon Dioxide		3.95	3.89	3.69	3.84	
Oxygen		16.08	16.26	16.49	16.28	
Nitrogen		79.97	79.85	79.82	79.88	
Sample Volume	(dscf)	50.19	47.30	47.38	48.29	
Isokinetic Variation	(%)	104.4	99.7	98.7	100.9	
Particulate Results-EPA Methods 5 & 202 (Dry Impinger Technique)						
<i>Front Half Dry Catch Only (filterable only)</i>						
Sample Mass (Nozzle, PW, Filter)	(g)	0.0062	0.0052	0.005	0.005	
Concentration - Actual	(GR/ACF)	0.00098	0.00088	0.00086	0.00091	
Concentration - Actual	(MG/ACM)	2.249	2.009	1.966	2.074	
Concentration - Standard	(GR/DSCF)	0.00191	0.00170	0.00163	0.00174	
Emission Rate	(LB/HR)	0.689	0.605	0.587	0.627	
<i>Organic CPM</i>						
Sample Mass	(g)	0.001390323	0.001090323	0.000990323	0.000990323	
Concentration - Actual	(GR/ACF)	0.00022	0.00018	0.00017	0.000191	
Concentration - Standard	(GR/DSCF)	0.00043	0.00036	0.00032	0.000369	
Emission Rate	(LB/HR)	0.154	0.127	0.117	0.133	
<i>Inorganic CPM</i>						
Sample Mass	(g)	0.004609677	0.004609677	0.003709677	0.003709677	
Concentration - Actual	(GR/ACF)	0.00078	0.00078	0.00064	0.00064	
Concentration - Standard	(GR/DSCF)	0.00151	0.00150	0.00121	0.001407	
Emission Rate	(LB/HR)	0.546	0.536	0.436	0.506	
<i>Total Particulate (Dry + Organic + Inorganic)</i>						
Sample Mass	(g)	0.0125	0.0109	0.0097	0.0097	
Concentration - Actual	(GR/ACF)	0.00198	0.00184	0.00167	0.001829	
Concentration - Standard	(GR/DSCF)	0.00384	0.00356	0.00316	0.003519	
Emission Rate	(LB/HR)	1.389	1.268	1.140	1.266	

**Test 16 Summary of the May 7, 2020, Oxides of Nitrogen, Carbon Monoxide and VOC's Test on the RTO Outlet Duct
at the LP facility located in Newberry, Michigan.**

(With Dryer Recirculation)

Date of test	Item	Run 1	Run 2	Run 3	Average
Time runs were done		05-07-20 (Hrs) 0745 / 0845	05-07-20 0915 / 1015	05-07-20 1050 / 1150	
Volumetric Flow					
Actual	(ACFM) (SCFM) (DSCFM)	81,801 59,223 42,185	80,302 58,199 41,593	79,803 58,120 42,092	80,636 58,514 41,957
Standard					
Standard					
Gas Temperature	(°F)	249	248	245	247
Moisture Content	(%v/v)	28.77	28.53	27.58	28.29
Gas Composition	(%v/v, dry)				
Carbon Dioxide	3.95	3.89	3.69	3.84	
Oxygen	16.08	16.26	16.49	16.28	
Nitrogen	79.97	79.85	79.82	79.88	
Results:					
Oxides of Nitrogen (EPA Method 7E)					
Concentration	(ppm, d) (LB /HR)	17.86 5.40	16.32 4.86	14.60 4.40	16.26 4.89
Emission Rate					
Carbon Monoxide (EPA Method 10)					
Concentration	(ppm, d) (LB /HR)	114.68 21.10	116.24 21.08	100.32 18.42	110.41 20.20
Emission Rate					
VOC (EPA Method 25a)					
Concentration	(ppm Propane, d) (TGNM ppm Propane, d)	15.77 14.47	15.57 14.40	13.73 12.43	15.03 13.77
Concentration					
Concentration	(ppm Carbon, d) (TGNM ppm Carbon, d)	47.32 43.42	46.71 43.21	41.19 37.29	45.08 41.31
Emission Rate (lb x/Hr)	(LB Carbon/LB Carbon/HR)	3.74	3.64	3.24	3.54
Emission Rate (lb x/Hr)	(TGNM LB Carbon/HR)	3.43	3.36	2.94	3.24
Emission Rate (lb x/Hr)	(LB Propane/LB Propane/HR)	4.57	4.45	3.97	4.33
Emission Rate (lb x/Hr)	(TGNM LB Propane/HR)	4.20	4.12	3.60	3.97

TGNM = Total Gaseous Non-methane

Results of NCASI 98.01 Determinations

Interpoll Laboratories Report Number 20-38411
LP
Newberry, MI

Test Number	RTO Outlet	Run 1	Run 2	Run 3	Average
Date of Test		05-07-20	05-07-20	05-07-20	
Time of Runs	Start (Hrs)	0745	0915	1050	
	End (Hrs)	0845	1015	1316	
	Total (Min)	60	60	60	
Moisture Content	(%v/v)	28.8	28.5	27.6	
Volumetric Flow Rate	(DSCFM)	42,185	41,583	42,092	
Sample Volume	(DSL)	20.60	19.66	20.24	
Acetaldehyde	(ppm,d) (ppm,d of duplicate) (LB/HR)	2.73 2.54 0.79	4.41 2.54 0.77	2.69 2.54 0.77	
	(%) (Duplicate %)	89.88% 3.58%	91.15% 2.87%	85.65% 4.76%	
Acrolein	(ppm,d) (ppm,d of duplicate) (LB/HR)	0.93 0.88 0.343	1.64 0.88 0.334	0.92 0.82 0.334	
	(%) (Duplicate %)	92.97% 2.94%	85.21% 5.86%	85.49% 6.79%	
Formaldehyde	(ppm,d) (ppm,d of duplicate) (LB/HR)	9.58 9.56 1.89	12.20 9.56 1.89	10.04 9.91 1.95	
	(%) (Duplicate %)	99.07% 0.13%	94.47% 0.66%	95.93% 0.46%	

Table 18 Summary of the Results of the May 7, 2020, Manganese Emission Test on the Dryer RTO (Stack P002) at the LP Facility Located in Newberry, MI.

Date of test	Item	Run 1	Run 2	Run 3	Average
		05-07-20	05-07-20	05-07-20	
Time runs were done	(Hrs)	1218 / 1323	1345 / 1450	1512 / 1617	
Volumetric Flow					
Actual	(ACFM) (DSCFM)	80588 42821	83764 43567	82995 43287	82449 43225
Standard					
Gas Temperature	(°F)	247	247	247	247
Moisture Content	(%v/v)	26.81	28.39	28.18	27.79
Gas Composition	(%v/v, dry)				
Carbon Dioxide	3.84	3.94	3.88	3.88	
Oxygen	16.83	16.59	16.95	16.79	
Nitrogen	79.33	79.47	79.18	79.32	
Isokinetic Variation	(%)	98.9	101.9	99.8	100.2
Sample Volume	(DSCF)	41.94	43.96	42.79	
Results					
Manganese	(ug) (ug/DSCM) (LB/HR)	< < \leq	9.20 7.746 0.001240	10.80 8.675 0.001414	10.90 8.995 0.001456
Concentration - Actual					
Emission Rate					

"<" = BDL (Below Detection Level)-All analytical levels used to calculate emission values are less than the laboratory's detection levels.

" \leq " = DLL (Detection Level Limited)- At least one but not all values used to calculate emission values are less than the laboratory's detection levels.

RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition and moisture is presented first followed by the computer printout of the particulate, and trace metals sampling data. Preliminary measurements including test port locations are given in the appendices.

The results have been calculated on a personal computer using programs written in Microsoft Excel spreadsheets specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The emission rates have been calculated using the product of the concentration times flow method.

3.1 Results of Gas Composition and Moisture Determinations

Interpoll Laboratories Report Number 20-38411
LP
Newberry, MI

Test Number 9
RTO Outlet

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

Date of Run	Run 1 05-06-20	Run 2 05-06-20	Run 3 05-06-20
-------------	-------------------	-------------------	-------------------

Dry basis

Carbon Dioxide.....	(%)	3.50	3.26	3.15
Oxygen.....	(%)	17.16	17.23	17.37
Nitrogen.....	(%)	79.34	79.51	79.49

Wet basis

Carbon Dioxide.....	(%)	2.64	2.48	2.41
Oxygen.....	(%)	12.97	13.11	13.31
Nitrogen.....	(%)	59.96	60.50	60.93
Water Vapor.....		24.42	23.91	23.34

Dry Molecular Weight.....	(g/gmole)	29.25	29.21	29.20
Wet Molecular Weight.....	(g/gmole)	26.50	26.53	26.58
Specific Gravity.....		0.915	0.916	0.918
Water Mass Flow.....	(lb/hr)	40989	40771	40211
Fo.....		1.068	1.126	1.123

Interpoll Laboratories Report Number 20-38411
LP
Newberry, MI

Test Number 12
RTO Outlet

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

Date of Run	Run 1 05-06-20	Run 2 05-06-20	Run 3 05-06-20
Dry basis (Orsat)			
Carbon Dioxide.....	3.61	3.76	3.41
Oxygen.....	17.33	17.19	17.24
Nitrogen.....	79.06	79.04	79.34
Wet basis (Orsat)			
Carbon Dioxide.....	2.75	2.83	2.60
Oxygen.....	13.22	12.91	13.13
Nitrogen.....	60.33	59.35	60.41
Water Vapor.....	23.69	24.91	23.86
Dry Molecular Weight.....	29.27	29.29	29.24
Wet Molecular Weight.....	26.6003	26.48	26.55
Specific Gravity.....	0.919	0.915	0.917
Water Mass Flow.....	41434	43408	41782
Fo.....	0.990	0.984	1.072

Interpoll Laboratories Report Number 20-38411
LP / Newberry
Newberry, MI

Test Number 13
Thermal Oil Heater

Results of Gas Composition and Moisture Analyses -- Methods 3A and 4 (% v/v)

Date of Run		Run 1	Run 2	Run 3
	05-06-20	05-06-20	05-06-20	
Dry basis				
Carbon Dioxide.....	(%)	5.48	6.35	6.40
Oxygen.....	(%)	14.61	14.05	13.93
Nitrogen.....	(%)	79.91	79.60	79.67
Wet basis				
Carbon Dioxide.....	(%)	4.92	5.65	5.71
Oxygen.....	(%)	13.11	12.50	12.42
Nitrogen.....	(%)	71.75	70.80	71.01
Water Vapor.....		10.22	11.05	10.87
Dry Molecular Weight.....	(g/gmole)	29.46	29.58	29.58
Wet Molecular Weight.....	(g/gmole)	28.29	28.30	28.32
Specific Gravity.....		0.977	0.977	0.978
Water Mass Flow.....	(lb/hr)	3318	3379	3372
Fo.....		1.149	1.079	1.089

Interpoll Laboratories Report Number 20-38411
LP
Newberry, MI

Test Number 15
RTO Outlet

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

Date of Run	Run 1 05-07-20	Run 2 05-07-20	Run 3 05-07-20
-------------	-------------------	-------------------	-------------------

Dry basis

Carbon Dioxide.....	(%)	3.95	3.89	3.69
Oxygen.....	(%)	16.08	16.26	16.49
Nitrogen.....	(%)	79.97	79.85	79.82

Wet basis

Carbon Dioxide.....	(%)	2.81	2.78	2.67
Oxygen.....	(%)	11.46	11.62	11.95
Nitrogen.....	(%)	56.96	57.07	57.81
Water Vapor.....		28.77	28.53	27.58

Dry Molecular Weight.....	(g/gmole)	29.28	29.27	29.25
Wet Molecular Weight.....	(g/gmole)	26.03	26.06	26.15
Specific Gravity.....		0.899	0.900	0.903
Water Mass Flow.....	(lb/hr)	47805	46573	44950
Fo.....		1.219	1.193	1.194

3.2 Particulate Sampling Data

Test Numbe 9**RTO Outlet****Results of EPA Method 5/202 Sampling Data**

Date of Test		Run 1		Run 2		Run 3	
		05-06-20	05-06-20	05-06-20	05-06-20	05-06-20	05-06-20
Time of Runs	(Hrs)	0850 /	0955	1042 /	1147	1216 /	1321
Static Pressure	(In. of WC)		-0.50		-0.50		-0.50
Cross Sectional Area	(Sq. ft)		22.17		22.17		22.17
Pitot Tube Coefficient			0.84		0.84		0.84
Avg. Sq. root of Delta p			0.8976		0.9126		0.9250
Water in Sample Gas							
Impingers	(g)		328.9		333.0		328.5
Desiccant	(g)		21.4		15.7		15.1
Total	(g)		350.3		348.7		343.6
Gas Meter Coefficient			1.0065		1.0065		1.0065
Barometric Pressure	(In. of Hg)		29.29		29.29		29.29
Avg. Orifice Pressure Drop	(In. of WC)		2.17		2.28		2.37
Avg. Gas Meter Temperature	(°F)		66.3		69.0		72.7
Volume Through Gas Meter							
Meter Conditions	(CF)		51.45		52.92		54.18
Standard Conditions	(DSCF)		51.12		52.32		53.21
Total Sampling Time	(Min.)		64.00		64.00		64.00
Nozzle Diameter	(In.)		0.269		0.269		0.269
Avg. Stack Gas Temperature	(°F)		246		246		249
Volumetric Flow Rate							
Actual	(ACFM)		81,811		83,110		84,335
Dry Standard	(DSCFM)		45,211		46,258		47,088
Isokinetic Variation	(%)		99.2		99.2		99.1

Interpoll Laboratories Report Number 20-38411
 LP / Newberry
 Newberry, MI

Test Number 13
Thermal Oil Heater

Results of EPA Method 5/202 Sampling Data

Date of Test	(Hrs)	Run 1		Run 2		Run 3	
		0955 /	1204	1250 /	1456	1535 /	1740
Time of Runs							
Static Pressure	(In. of WC)		-0.10		-0.10		-0.10
Cross Sectional Area	(Sq. ft)		19.63		19.63		19.63
Pitot Tube Coefficient			0.84		0.84		0.84
Avg. Sq. root of Delta p		0.209756992		0.197650871		0.200945578	
Water in Sample Gas							
Impingers	(g)		133.6		138.4		137.8
Desiccant	(g)		11.0		10.0		9.0
Total	(g)		144.6		148.4		146.8
Gas Meter Coefficient			0.9959		0.9959		0.9959
Barometric Pressure	(In. of Hg)		29.26		29.26		29.26
Avg. Orifice Pressure Drop	(In. of WC)		0.87		0.78		0.80
Avg. Gas Meter Temperature	(°F)		71.5		75.7		80.5
Volume Through Gas Meter							
Meter Conditions	(CF)		61.81		58.56		59.58
Standard Conditions	(DSCF)		59.90		56.30		56.78
Total Sampling Time	(Min.)		120.00		120.00		120.00
Nozzle Diameter	(In.)		0.416		0.416		0.416
Avg. Stack Gas Temperature	(°F)		297		298		299
Volumetric Flow Rate							
Actual	(ACFM)		16,976		15,997		16,273
Dry Standard	(DSCFM)		10,389		9,695		9,863
Isokinetic Variation	(%)		99.9		100.6		99.7

Test Numbe 15
RTO Outlet

Results of EPA Method 5/202 Sampling Data

Date of Test		Run 1		Run 2		Run 3	
		05-07-20		05-07-20		05-07-20	
Time of Runs	(Hrs)	0745 /	0850	0915 /	1020	1050 /	1155
Static Pressure	(In. of WC)		-0.50		-0.50		-0.50
Cross Sectional Area	(Sq. ft)		22.17		22.17		22.17
Pitot Tube Coefficient			0.84		0.84		0.84
Avg. Sq. root of Delta p			0.8851		0.8698		0.8680
Water in Sample Gas							
Impingers	(g)		412.3		387.7		369.2
Desiccant	(g)		17.6		12.8		13.4
Total	(g)		429.9		400.5		382.6
Gas Meter Coefficient			1.0065		1.0065		1.0065
Barometric Pressure	(In. of Hg)		29.12		29.12		29.12
Avg. Orifice Pressure Drop	(In. of WC)		2.13		1.87		1.88
Avg. Gas Meter Temperature	(°F)		73.5		69.6		69.0
Volume Through Gas Meter							
Meter Conditions	(CF)		51.51		48.22		48.25
Standard Conditions	(DSCF)		50.19		47.30		47.38
Total Sampling Time	(Min.)		64.00		64.00		64.00
Nozzle Diameter	(In.)		0.269		0.269		0.269
Avg. Stack Gas Temperature	(°F)		249		248		245
Volumetric Flow Rate							
Actual	(ACFM)		81,801		80,302		79,803
Dry Standard	(DSCFM)		42,185		41,593		42,092
Isokinetic Variation	(%)		104.4		99.7		98.7