

Report of a...

Relative Accuracy Test Audit

performed for...

National Energy
McBain, Michigan

on the

Wood Fired Boiler

August 18, 2022

126.43

Network Environmental, Inc.
Grand Rapids, MI

Performed for:

National Energy of McBain
6751 Gerwoude Drive
McBain, MI 49657
Contact: Matt Doolittle
Telephone: (231) 825-2772 Ext: 102
Fax: (231) 825-8024
E-mail: matthew.doolittle@nssccorp.com

Performed by:

Network Environmental, Inc.
2629 Remico Street, Suite B
Grand Rapids, MI 49519
Contact: David D. Engelhardt
Telephone: (616) 530-6330
Fax: (616) 530-0001
E-mail: netenviro@aol.com

TABLE OF CONTENTS

	<u>Page</u>
I. Introduction	1
II. Summary Tables of Results	2-4
II.1 Table 1 - NO _x RATA Results	2
II.2 Table 2 - CO RATA Results	3
II.3 Table 3 - SO ₂ RATA Results	4
III. Discussion of Results	5-6
III.1 NO _x RATA	5
III.2 CO RATA	5
III.3 SO ₂ RATA	5-6
III.4 Opacity Audit	6
IV. Source Description	6
V. CEMS Description	6-7
VI. Sampling and Analytical Protocol	7-11
VI.1 Oxides of Nitrogen	7-8
VI.2 Carbon Monoxide	8-9
VI.3 Sulfur Dioxide	9
VI.4 Oxygen	9-10
VI.5 Opacity Audit	10
Figure 1 - NO _x , CO, SO ₂ & O ₂ Sampling Train	11

Appendices

Reference Method Data Acquisition System Data	A
CEM Data	B
Opacity Audit Data	C
Calibration Gas & Analyzer Specification Data	D
Calculations	E
Raw Data	F

I. INTRODUCTION

Network Environmental, Inc. was retained by National Energy of McBain, Michigan to perform a Relative Accuracy Test Audit (RATA) on the Continuous Emissions Monitoring System (CEMS) that services their wood fired boiler. The CEMS is for oxides of nitrogen (NO_x), carbon monoxide (CO), sulfur dioxide (SO₂) and oxygen (O₂).

In addition to the RATA, the opacity monitor was audited per Performance Specification 1 and the U.S. EPA Technical Assistance Document EPA 450/4-92-010 "Performance Audit Procedures for Opacity Monitors".

The RATA and opacity audit were performed on August 18, 2022. Richard D. Eerdmans and David D. Engelhardt of Network Environmental, Inc. conducted the RATA in accordance with 40 CFR Part 60 Appendix B Performance Specifications 2 for NO_x and SO₂, 3 for O₂ and 4 for CO. Assisting with the RATA were Mr. Matt Doolittle, Mr. Kyle Foster and the operating staff of National Energy McBain. Mr. Dave Bowman of the Michigan Department of Environment, Great Lakes & Energy (EGLE) - Air Quality Division was present to observe the testing and source operation.

II. PRESENTATION OF RESULTS

**II.1 TABLE 1
NO_x RELATIVE ACCURACY TEST AUDIT RESULTS
WOOD FIRED BOILER
NATIONAL ENERGY
McBAIN, MICHIGAN
AUGUST 18, 2022**

Run #	Time	REFERENCE METHOD			CEM	DIFF
		NO _x ⁽¹⁾	O ₂ ⁽²⁾	Lbs/MMBTU	Lbs/MMBTU	
1	08:30-08:55	137.1	7.3	0.239	0.220	0.019
2	09:18-09:43	135.6	7.4	0.238	0.211	0.027
3	10:06-10:31	130.4	7.4	0.229	0.193	0.036
4	10:56-11:21	129.1	7.3	0.225	0.194	0.031
5	11:43-12:08	128.6	7.2	0.222	0.188	0.034
6	12:29-12:54	132.7	7.2	0.229	0.209	0.020
7	13:11-13:36	129.9	7.2	0.224	0.207	0.017
8	13:55-14:20	133.0	7.6	0.237	0.215	0.022
9	14:40-15:05	134.4	7.6	0.239	0.220	0.019

Mean Reference Value 0.23133

Absolute Value of the Mean of the Difference 0.02500

Standard Deviation 0.00718

Confidence Co-efficient 0.00552

Relative Accuracy = 13.19% of the mean of the reference method

(1) = Concentration in terms of PPM by volume on a dry basis

(2) = Concentration in terms of % by volume on a dry basis

**II.2 TABLE 2
CO RELATIVE ACCURACY TEST AUDIT RESULTS
WOOD FIRED BOILER
NATIONAL ENERGY
McBAIN, MICHIGAN
AUGUST 18, 2022**

Run #	Time	REFERENCE METHOD			CEM	DIFF
		CO ⁽¹⁾	O ₂ ⁽²⁾	Lbs/MMBTU	Lbs/MMBTU	
1	08:30-08:55	48.0	7.3	0.051	0.055	-0.004
2	09:18-09:43	48.4	7.4	0.052	0.056	-0.004
3	10:06-10:31	43.9	7.4	0.047	0.051	-0.004
4	10:56-11:21	41.1	7.3	0.044	0.048	-0.004
5	11:43-12:08	39.0	7.2	0.041	0.045	-0.004
6	12:29-12:54	40.8	7.2	0.043	0.047	-0.004
7	13:11-13:36	41.5	7.2	0.044	0.048	-0.004
8	13:55-14:20	56.1	7.6	0.061	0.064	-0.003
9	14:40-15:05	56.8	7.6	0.062	0.066	-0.004

Mean Reference Value 0.04944

Absolute Value of the Mean of the Difference 0.00389

Standard Deviation 0.00033

Confidence Co-efficient 0.00026

Relative Accuracy = 1.66% of the emission limit (0.25 Lbs/MMBTU)

(1) = Concentration in terms of PPM by volume on a dry basis

(2) = Concentration in terms of % by volume on a dry basis

**II.3 TABLE 3
SO₂ RELATIVE ACCURACY TEST AUDIT RESULTS
WOOD FIRED BOILER
NATIONAL ENERGY
McBAIN, MICHIGAN
AUGUST 18, 2022**

Run #	Time	REFERENCE METHOD			CEM	DIFF
		SO ₂ ⁽¹⁾	O ₂ ⁽²⁾	Lbs/MMBTU	Lbs/MMBTU	
1	08:30-08:55	88.8	7.3	0.215	0.209	0.006
2	09:18-09:43	98.5	7.4	0.240	0.239	0.001
3	10:06-10:31	101.8	7.4	0.248	0.244	0.004
4	10:56-11:21	97.1	7.3	0.235	0.231	0.004
5	11:43-12:08	97.2	7.2	0.234	0.229	0.005
6	12:29-12:54	108.8	7.2	0.262	0.250	0.012
7	13:11-13:36	97.8	7.2	0.235	0.228	0.007
8	13:55-14:20	75.4	7.6	0.187	0.185	0.002
9	14:40-15:05	86.5	7.6	0.214	0.211	0.003

Mean Reference Value 0.23000

Absolute Value of the Mean of the Difference 0.00489

Standard Deviation 0.00326

Confidence Co-efficient 0.00250

Relative Accuracy = 3.21% of the mean of the reference method

(1) = Concentration in terms of PPM by volume on a dry basis

(2) = Concentration in terms of % by volume on a dry basis

III. DISCUSSION OF RESULTS

III.1 NO_x RATA - The results of the NO_x RATA can be found in Table 1 (Section II.1). The relative accuracy calculations were performed in terms of Lbs/MMBTU in accordance with U.S. EPA Reference Method 19. The Lbs/MMBTU results were calculated using the formula found in Section 12.2.1 (Equation 19-1) of Method 19 for O₂ on a dry basis. The F factor used was 9,475. Nine (9), twenty-five (25) minute samples were collected from the boiler exhaust.

The relative accuracy for the NO_x CEMS was 13.19% of the mean of the reference method samples.

According to Performance Specification 2 in 40 CFR Part 60 Appendix B, "The relative accuracy (RA) of the CEMS shall be no greater than 20 percent of the mean value of the reference method test data in terms of the units of the emission standard or 10 percent of the applicable standard, whichever is greater."

III.2 CO RATA - The results of the CO RATA can be found in Table 2 (Section II.2). The relative accuracy calculations were performed in terms of Lbs/MMBTU in accordance with U.S. EPA Reference Method 19. The Lbs/MMBTU results were calculated using the formula found in Section 12.2.1 (Equation 19-1) of Method 19 for O₂ on a dry basis. The F factor used was 9,475. Nine (9), twenty-five (25) minute samples were collected from the boiler exhaust.

The relative accuracy for the CO CEMS was 1.66% of the emission limit (0.25 Lbs/MMBTU).

According to Performance Specification 4 in 40 CFR Part 60 Appendix B, "The relative accuracy (RA) of the CEMS shall be no greater than 10 percent of the mean value of the reference method test data in terms of the units of the emission standard or 5 percent of the applicable standard, whichever is greater."

III.3 SO₂ RATA - The results of the SO₂ RATA can be found in Table 3 (Section II.3). The relative accuracy calculations were performed in terms of Lbs/MMBTU in accordance with U.S. EPA Reference Method 19. The Lbs/MMBTU results were calculated using the formula found in Section 12.2.1 (Equation 19-1) of Method 19 for O₂ on a dry basis. The F factor used was 9,475. Nine (9),

twenty-five (25) minute samples were collected from the boiler exhaust.

The relative accuracy for the SO₂ CEMS was 3.21% of the mean of the reference method samples.

According to Performance Specification 2 in 40 CFR Part 60 Appendix B, "The relative accuracy (RA) of the CEMS shall be no greater than 20 percent of the mean value of the reference method test data in terms of the units of the emission standard or 10 percent of the applicable standard, whichever is greater."

III.4 Opacity Audit - The results of the opacity audit can be found in Appendix C. The calibration errors were as follows:

Filter	Calibration Error
Low	0.28%
Mid	0.89%
High	1.30%

According to Performance Specification 1 in 40 CFR Part 60 Appendix B, the calibration error of the monitor should be less than or equal to 3% opacity.

IV. SOURCE DESCRIPTION

The CEMS services a wood fired boiler with a capacity of 600 tons per day of fuel. The exhaust is controlled by an electrostatic precipitator. The boiler was operated at approximately 100% of load during the testing period. The waste wood was supplemented by tire derived fuel (TDF) during the RATA.

V. CEMS DESCRIPTION

The NO_x monitor is a Fuji infra-red Model ZRF1PEY2-2EOYY-YYOYYFY NO_x analyzer, Serial # A5G3347T. The monitor records data on a dry basis. The span range is 0-500 PPM.

The CO monitor is a Thermo Scientific Model 48I-ANSCA, Serial # JC1606001770. The monitor records data on a dry basis. The span range is 0-1000 PPM.

The SO₂ monitor is a Bovar Western Research Model # 721-M SO₂ analyzer, Serial # VE-721-721M-8653-3. The monitor records on a dry basis. The span range is 0-250 PPM.

The O₂ monitor is a Ametek Model RM CEM O2-IQ, Serial # 10210202. The monitor records data on a dry basis. The span range is 0-21 %.

The opacity monitor is a Thermo Environmental Model 400B opacity monitor, Serial # 400B-40940-B56/264. The span range is 0-100 %.

VI. SAMPLING AND ANALYTICAL PROTOCOL

The RATA was performed in accordance with 40 CFR Part 60 Appendix B Performance Specifications 2 for NO_x and SO₂, 3 for O₂ and 4 for CO. In addition to the RATA, the opacity monitor was audited per Performance Specification 1 and the U.S. EPA Technical Assistance Document EPA 450/4-92-010 "Performance Audit Procedures for Opacity Monitors".

The sampling was conducted on the 71 inch I.D. exhaust stack at a location that exceeds 8 duct diameters downstream and 2 duct diameters upstream from the nearest disturbances (U.S. EPA Reference Method 1 requirement).

The RATA was performed in accordance with the protocol approved by EGLE-Air Quality Division. Prior testing has shown no stratification in the exhaust stack. One (1) point (50% of diameter) sampling was used to collect the exhaust gas from the stack.

The sampling methods used for the reference method determinations were as follows:

VI.1 Oxides of Nitrogen

The NO_x sampling was conducted in accordance with U.S. EPA Reference Method 7E. A Thermo Environmental Model 42H gas analyzer was used to monitor the boiler exhaust. Sample gas was

extracted through a heated probe. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the NO_x concentrations (PPM).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 191.0 PPM was used to establish the initial instrument calibration. Calibration gases of 101.0 PPM and 54.6 PPM were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 101.0 PPM gas to determine the system bias. After each sample, a system zero and system injection of 101.0 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler.

VI.2 Carbon Monoxide

The CO sampling was conducted in accordance with U.S. EPA Reference Method 10. A Thermo Environmental Model 48C gas analyzer was used to monitor the boiler exhaust. Sample gas was extracted through a heated probe. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the CO concentrations (PPM).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 168.0 PPM was used to establish the initial instrument calibration. Calibration gases of 92.9 PPM and 51.1 PPM were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 92.9 PPM gas to determine the system bias. After each sample, a system zero and system injection of 92.9 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler.

VI.3 Sulfur Dioxide

The SO₂ sampling was conducted in accordance with U.S. EPA Reference Method 6C. A Bovar Model 721M gas analyzer was used to monitor the boiler exhaust. Sample gas was extracted through a heated probe. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the SO₂ concentrations (PPM).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 269.0 PPM was used to establish the initial instrument calibration. Calibration gases of 95.2 PPM and 148.0 PPM were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 95.2 PPM gas to determine the system bias. After each sample, a system zero and system injection of 95.2 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler.

VI.4 Oxygen

The O₂ sampling was conducted in accordance with U.S. EPA Reference Method 3A. A Servomex Model 1400M portable stack gas analyzer was used to monitor the boiler exhaust. Sample gas was extracted through a heated probe. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the O₂ concentrations (%).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 20.85% was

used to establish the initial instrument calibration. Calibration gases of 5.90% and 12.0% were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 5.90% gas to determine the system bias. After each sample, a system zero and system injection of 5.90% were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler.

VI.5 Opacity Audit

The opacity audit was conducted in accordance with Performance Specification 1 and the U.S. EPA Technical Assistance Document EPA450/4-92-010 "Performance Audit Procedures for Opacity Monitors". A three-point calibration error test of the opacity monitor was conducted. Three (3) neutral density filters, meeting the requirements of PS-1, were placed in the light beam path five consecutive times and the monitor responses were recorded. The calibration error of the monitor was calculated in accordance with Section 8.0 of Performance Specification 1.

This report was prepared by:



David D. Engelhardt
Vice President

This report was reviewed by:



R. Scott Cargill
Project Manager




Figure 1
NO_x, CO, SO₂ & O₂
Sampling Train