

Report of...

Compliance Emission Testing

performed for...

Viking Energy of McBain
McBain, Michigan

RECEIVED
NOV 01 2021
AIR QUALITY DIVISION

on the

Wood Fired Boiler

August 17-19, 2021

126.40

Network Environmental, Inc.
Grand Rapids, MI

Performed for:

Viking Energy
6751 Gerwoude Drive
McBain, MI 49657
Contact: Keith Stackpoole
Telephone: (231) 825-2772
Fax: (231) 825-8024
E-mail: keith.stackpoole@nssccorp.com

Performed by:

Network Environmental, Inc.
2629 Remico Street, Suite B
Grand Rapids, MI 49519
Contact: David D. Engelhardt
Telephone: (616) 530-6330
Fax: (616) 530-0001
E-mail: netenviro@aol.com

TABLE OF CONTENTS

	<u>Page</u>
I. Introduction	1-2
II. Presentation of Results	3-8
II.1 Table 1 – Total Particulate Emission Results	3
II.2 Table 2 – VOC Emission Results	4
II.3 Table 3 – Lead (Pb) Emission Results	5
II.4 Table 4 – Mercury (Hg) Emission Results	5
II.5 Table 5 – Arsenic (As) Emission Results	6
II.6 Table 6 – Total Chromium (Cr) Emission Results	6
II.7 Table 7 – Total Dioxin & Furan Emission Results	7
II.8 Table 8 – Benzo-A-Pyrene Emission Results	7
II.9 Table 9 – Sulfuric Acid (H ₂ SO ₄) Emission Results	8
III. Discussion of Results	9-12
V. Sampling and Analytical Protocol	12-20
Figure 1 – Particulate Sampling Train	16
Figure 2 – VOC Sampling Train	17
Figure 3 – Metals Sampling Train	18
Figure 4 – Dioxin, Furan & Benzo-A-Pyrene Sampling Train	19
Figure 5 – H ₂ SO ₄ Sampling Train	20

Appendices

Particulate Emission Results, Sampling Train Data & Exhaust Gas Parameters	A
Source Operating Data	B
Field Data	C
Analyzer & Calibration Gas Specifications	D
Analytical Data	E
Calculations	F
Raw Data	G

I. INTRODUCTION

Network Environmental, Inc. was retained by Viking Energy of McBain, Michigan to conduct a compliance emission study at their facility. The purpose of the study was to meet the emission testing requirements of Renewable Operating Permit (ROP) No. MI-ROP-N1160-2018.

The following is a list of the applicable emission limits for the boiler exhaust:

Emission Limit(s)
PM-10: 0.10 Lbs/MMBTU of Heat Input, 23.0 Lbs/Hr & 98.9 Tons/Year
VOC's: 0.020 Lbs/MMBTU of Heat Input, 4.6 Lbs/Hr & 19.1 Tons/Year
Lead (Pb): 5.0E-04 Lbs/MMBTU of Heat Input, 0.12 Lbs/Hr & 0.5 Tons/Year
Mercury (Hg): 1.4 ug/M ³ @ 7% O ₂ , 3.2E-04 Lbs/Hr & 0.0014 Tons/Year
Arsenic (As): 40 ug/M ³ @ 7% O ₂ , 0.009 Lbs/Hr & 0.04 Tons/Year
Total Chromium (Cr): 23.0 ug/M ³ @ 7% O ₂ , 0.0052 Lbs/Hr & 0.023 Tons/Year
Dioxins & Furans: 2.9E-05 ug/M ³ @ 7% O ₂ , 6.5E-09 Lbs/Hr & 2.9E-08 Tons/Year
Benzo-A-Pyrene: 0.008 ug/M ³ @ 7% O ₂ , 1.9E-06 Lbs/Hr & 8.4E-06 Tons/Year
H₂SO₄: 0.03 Lbs/MMBTU of Heat Input, 7.6 Lbs/Hr & 33.3 Tons/Year

The following reference test methods were employed to conduct the emission sampling:

- Particulate Matter – U.S. EPA Methods 17 & 202
- VOC's – U.S. EPA Method 25A
- Metals – U.S. EPA Method 29
- Dioxins & Furans – U.S. EPA Method 23
- Benzo-A-Pyrene – U.S. EPA Method 23
- H₂SO₄ – U.S. EPA Method 8
- Exhaust Gas Parameters (air flow rate, temperature, moisture & density) – U.S. EPA Methods 1- 4

During the sampling the boiler was firing a combination of wood waste and tire derived fuel (TDF).

The sampling was performed over the period of August 17-19, 2021 by Stephan K. Byrd, Richard D. Eerdmans, and David D. Engelhardt of Network Environmental, Inc.. Assisting with the study were Mr. Keith Stackpoole and the operating staff of the facility. Mr. Jeremy Howe and Mr. Rob Dickman of the

Michigan Department of Environment, Great Lakes and Energy (EGLE) - Air Quality Division were present to observe the sampling and source operation.

II. PRESENTATION OF RESULTS

**II.1 TABLE 1
TOTAL PARTICULATE⁽¹⁾ EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽²⁾	Total Particulate Emissions		
				Lbs/Hr ⁽³⁾	Lbs/MMBTU ⁽⁴⁾	Tons/Year ⁽⁵⁾
1	8/19/21	09:17-10:20	53,753	4.17	0.0183	17.93
2	8/19/21	11:00-12:04	54,473	3.35	0.0145	14.41
3	8/19/21	12:44-13:48	55,044	3.72	0.0162	16.00
Average			54,423	3.75	0.0163	16.11

- (1) Total Particulate = Front Half Filterable and Back Half Condensable
- (2) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
- (3) Lbs/Hr = Pounds Per Hour
- (4) Lbs/MMBTU = Pounds Per Million BTU Of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
- (5) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

**II.2 TABLE 2
TOTAL HYDROCARBON (VOC) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate SCFM ⁽¹⁾	VOC Emissions		
				Lbs/Hr ⁽²⁾	Lbs/MMBTU ⁽³⁾	Tons/Year ⁽⁴⁾
1	8/17/21	09:13-10:53	65,659	0.045	0.00019	0.19
2	8/17/21	11:09-12:35	64,584	0.353	0.00154	1.52
3	8/17/21	12:49-13:49	63,789	0.087	0.00038	0.37
Average			64,677	0.162	0.00070	0.69

- (1) SCFM = Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
- (2) Lbs/Hr = Pounds Per Hour As Propane
- (3) Lbs/MMBTU = Pounds Per Million BTU Of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
- (4) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

**II.3 TABLE 3
LEAD (Pb) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Lead (Pb) Emissions		
				Lbs/Hr ⁽²⁾	Lbs/MMBTU ⁽³⁾	Tons/Year ⁽⁴⁾
1	8/17/21	09:33-10:51	55,143	0.0065	2.81E-05	0.028
2	8/17/21	11:28-12:46	54,318	0.0036	1.56E-05	0.015
3	8/17/21	13:33-14:50	53,621	0.0041	1.74E-05	0.018
Average			54,361	0.0047	2.04E-05	0.020

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) Lbs/Hr = Pounds Per Hour
(3) Lbs/MMBTU = Pounds Per Million BTU Of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
(4) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

**II.4 TABLE 4
MERCURY (Hg) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Mercury (Hg) Emissions		
				ug/M ³ @ 7% O ₂ ⁽²⁾	Lbs/Hr ⁽³⁾	Tons/Year ⁽⁴⁾
1	8/17/21	09:33-10:51	55,143	N.D. ⁽⁵⁾	N.D. ⁽⁵⁾	N.D. ⁽⁵⁾
2	8/17/21	11:28-12:46	54,318	N.D. ⁽⁵⁾	N.D. ⁽⁵⁾	N.D. ⁽⁵⁾
3	8/17/21	13:33-14:50	53,621	N.D. ⁽⁵⁾	N.D. ⁽⁵⁾	N.D. ⁽⁵⁾
Average			54,361	-----	-----	-----

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) ug/M³ @ 7% O₂ = Micrograms Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen (STP = 68 °F and 29.92 in. Hg)
(3) Lbs/Hr = Pounds Per Hour
(4) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.
(5) N.D. = Non Detected At Detection Limits Of 0.529 ug/M³ @ 7% O₂, 1.09E-04 Lbs/Hr & 0.00047 Tons/Year

RECEIVED
NOV 01 2021
AIR QUALITY DIVISION

**II.5 TABLE 5
ARSENIC (As) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Arsenic (As) Emissions		
				ug/M ³ @ 7% O ₂ ⁽²⁾	Lbs/Hr ⁽³⁾	Tons/Year ⁽⁴⁾
1	8/17/21	09:33-10:51	55,143	2.42	0.00050	0.0022
2	8/17/21	11:28-12:46	54,318	1.88	0.00038	0.0016
3	8/17/21	13:33-14:50	53,621	1.17	0.00024	0.0010
Average			54,361	1.82	0.00038	0.0016

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) ug/M³ @ 7% O₂ = Micrograms Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen (STP = 68 °F and 29.92 in. Hg)
 (3) Lbs/Hr = Pounds Per Hour
 (4) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

**II.6 TABLE 6
TOTAL CHROMIUM (Cr) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Total Chromium (Cr) Emissions		
				ug/M ³ @ 7% O ₂ ⁽²⁾	Lbs/Hr ⁽³⁾	Tons/Year ⁽⁴⁾
1	8/17/21	09:33-10:51	55,143	4.07	0.00084	0.0036
2	8/17/21	11:28-12:46	54,318	5.07	0.00104	0.0045
3	8/17/21	13:33-14:50	53,621	4.24	0.00088	0.0038
Average			54,361	4.46	0.00092	0.0040

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) ug/M³ @ 7% O₂ = Micrograms Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen (STP = 68 °F and 29.92 in. Hg)
 (3) Lbs/Hr = Pounds Per Hour
 (4) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

**II.7 TABLE 7
TOTAL DIOXIN & FURAN⁽¹⁾ EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽²⁾	Total Dioxin & Furan Emissions		
				ug/M ³ @ 7% O ₂ ⁽³⁾	Lbs/Hr ⁽⁴⁾	Tons/Year ⁽⁵⁾
1	8/18/21	11:06-12:29	55,886	2.39E-05	4.94E-09	2.12E-08
2	8/18/21	13:35-14:52	56,529	9.63E-06	2.01E-09	8.64E-09
3	8/18/21	15:52-17:12	55,799	3.89E-06	8.24E-10	3.54E-09
Average			56,071	1.25E-05	2.59E-09	1.11E-08

- (1) Compounds listed are the 2,3,7,8 congeners of TCDDs/TCDFs with Toxic Equivalent Factors (TEFs) greater than zero. Where the compounds were non detected, the detection limit value was used in the calculation.
(2) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(3) ug/M³ @ 7% O₂ = Micrograms Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen (STP = 68 °F and 29.92 in. Hg)
(4) Lbs/Hr = Pounds Per Hour
(5) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

**II.8 TABLE 8
BENZO-A-PYRENE EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Benzo-A-Pyrene Emissions		
				ug/M ³ @ 7% O ₂ ⁽²⁾	Lbs/Hr ⁽³⁾	Tons/Year ⁽⁵⁾
1	8/18/21	11:06-12:29	55,886	0.0066	1.36E-06	5.84E-06
2	8/18/21	13:35-14:52	56,529	0.0053	1.11E-06	4.77E-06
3	8/18/21	15:52-17:12	55,799	0.0070	1.47E-06	6.32E-06
Average			56,071	0.0063	1.31E-06	5.64E-06

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) ug/M³ @ 7% O₂ = Micrograms Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen (STP = 68 °F and 29.92 in. Hg)
(3) Lbs/Hr = Pounds Per Hour
(4) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

**II.9 TABLE 9
SULFURIC ACID (H₂SO₄) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
VIKING ENERGY OF McBAIN
McBAIN, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Sulfuric Acid (H ₂ SO ₄) Emissions		
				Lbs/Hr ⁽²⁾	Lbs/MMBTU ⁽³⁾	Tons/Year ⁽⁴⁾
1	8/17/21	15:41-16:45	55,066	0.93	0.00398	4.00
2	8/17/21	17:14-18:17	55,469	0.13	0.00057	0.56
3	8/18/21	08:17-09:21	53,879	0.11	0.00049	0.47
Average			54,805	0.39	0.00168	1.68

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) Lbs/Hr = Pounds Per Hour
(3) Lbs/MMBTU = Pounds Per Million BTU Of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
(4) Tons/Year were calculated using 8,600 hours of operation per year as per the maximum operating hours established in MI-ROP-N1160-2018.

III. DISCUSSION OF RESULTS

The results of the emission sampling are summarized in Tables 1 through 9 (Sections II.1 through II.9). The results are presented as follows:

III.1 Total Particulate Emission Results (Table 1)

Table 1 summarizes the total (front half filterable & back half condensable) particulate emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Particulate Mass Emission Rates:
 - ✧ Lbs/Hr - Pounds of Particulate Per Hour
 - ✧ Lbs/MMBTU - Pounds of Particulate Per Million BTU of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
 - ✧ Tons/Year - Tons of Particulate Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

III.2 VOC Emission Results (Table 2)

Table 2 summarizes the total hydrocarbon (VOC) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (SCFM) - Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- VOC Mass Emission Rates:
 - ✧ Lbs/Hr - Pounds of VOC Per Hour As Propane
 - ✧ Lbs/MMBTU - Pounds of VOC Per Million BTU of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
 - ✧ Tons/Year - Tons of VOC Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

III.3 Lead (Pb) Emission Results (Table 3)

Table 3 summarizes the lead (Pb) emission results as follows:

- Sample
- Date

- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Lead (Pb) Mass Emission Rates:
 - ✧ Lbs/Hr - Pounds of Lead Per Hour
 - ✧ Lbs/MMBTU - Pounds of Lead Per Million BTU of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
 - ✧ Tons/Year - Tons of Pb Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

III.4 Mercury (Hg) Emission Results (Table 4)

Table 4 summarizes the mercury (Hg) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Mercury (Hg) Concentration ($\mu\text{g}/\text{M}^3$ @ 7% O_2) - Micrograms of Mercury Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen
- Mercury (Hg) Mass Emission Rate:
 - ✧ Lbs/Hr - Pounds of Mercury Per Hour
 - ✧ Tons/Year - Tons of Hg Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

III.5 Arsenic (As) Emission Results (Table 5)

Table 5 summarizes the arsenic (As) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Arsenic (As) Concentration ($\mu\text{g}/\text{M}^3$ @ 7% O_2) - Micrograms of Arsenic Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen
- Arsenic (As) Mass Emission Rate:
 - ✧ Lbs/Hr - Pounds of Arsenic Per Hour
 - ✧ Tons/Year - Tons of As Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

III.6 Total Chromium (Cr) Emission Results (Table 6)

Table 6 summarizes the total chromium (Cr) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Chromium (Cr) Concentration (ug/M³ @ 7% O₂) - Micrograms of Chromium Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen
- Chromium (Cr) Mass Emission Rate:
 - ✧ Lbs/Hr - Pounds of Chromium Per Hour
 - ✧ Tons/Year - Tons of Cr Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

III.7 Total Dioxin & Furan Emission Results (Table 7)

Table 7 summarizes the total dioxin & furan emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Total Dioxin & Furan Concentration (ug/M³ @ 7% O₂) - Micrograms of Dioxins & Furans Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen
- Total Dioxin & Furan Mass Emission Rate:
 - ✧ Lbs/Hr - Pounds of Dioxins & Furans Per Hour
 - ✧ Tons/Year - Tons of Dioxins & Furans Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

The total dioxin & furan results consist of the 2,3,7,8 congeners of TCDDs/TCDFs with Toxic Equivalent Factors (TEFs) greater than zero. Whenever a compound was non detected, the detection limit value was used in the calculations. All the Dioxin & Furan results were blank corrected using the field blank (T-4) results.

III.8 Benzo-A-Pyrene Emission Results (Table 8)

Table 8 summarizes the benzo-a-pyrene emission results as follows:

- Sample
- Date
- Time

- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Benzo-A-Pyrene Concentration (ug/M³ @ 7% O₂) - Micrograms of Benzo-A-Pyrene Per Dry Standard Cubic Meter Corrected To 7 Percent Oxygen
- Benzo-A-Pyrene Mass Emission Rate:
 - ◇ Lbs/Hr - Pounds of Benzo-A-Pyrene Per Hour
 - ◇ Tons/Year - Tons of Benzo-A-Pyrene Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

III.9 Sulfuric Acid (H₂SO₄) Emission Results (Table 9)

Table 9 summarizes the sulfuric acid (H₂SO₄) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Sulfuric Acid (H₂SO₄) Mass Emission Rates:
 - ◇ Lbs/Hr - Pounds of Sulfuric Acid Per Hour
 - ◇ Lbs/MMBTU - Pounds of Sulfuric Acid Per Million BTU of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,475 DSCF/MMBTU)
 - ◇ Tons/Year - Tons of H₂SO₄ Per Year (Calculated using 8,600 hours of operation per year. These are the maximum allowed operating hours as established in MI-ROP-N1160-2018).

IV. SAMPLING AND ANALYTICAL PROTOCOL

The sampling location for the boiler exhaust was on the 71 inch diameter exhaust at a location that meets the 8 duct diameter downstream and 2 duct diameter upstream requirement of U.S. EPA Method 1. There are 4 sample ports. For the particulate & sulfuric acid sampling, only two (2) of the sampling ports were used. For the metals, Dioxin/Furan and Benzo-A-Pyrene sampling, all four (4) sampling ports were used. Twelve (12) sampling points (6 per port when sampling 2 ports and 3 per port when sampling 4 ports) were used for the isokinetic sampling. The sampling point dimensions were as follows:

<u>Sample Point</u>	<u>Dimension (Inches)</u>
1	3.12
2	10.37
3	21.02
4	49.98
5	60.63
6	67.88

IV.1 Particulate – The particulate determinations were performed in accordance with U.S. EPA Methods 17 & 202. Method 17 is an in-stack filtration method. Three (3) samples, each sixty (60) minutes in duration, were collected from the exhaust. Each sample had a minimum sample volume of thirty (30) dry standard cubic feet. The sampling systems were operated isokinetically. After the completion of each sample, a sixty (60) minute nitrogen purge was conducted on the back half (impingers) in accordance with Method 202.

The front and back half catches were recovered as per Methods 17 & 202. The front half (nozzle/probe acetone rinse & filter) were measured gravimetrically. The back half was measured for condensables. The condensable fraction was determined by using the extraction technique found in EPA Method 202 and separate gravimetric analysis of the solvent (organic) and water (inorganic) fractions. All the quality assurance requirements specified in the methods were incorporated in the sampling and analysis. Figure 1 is a diagram of the particulate sampling train.

IV.2 VOC – The total hydrocarbon (VOC) emission sampling was conducted in accordance with U.S. EPA Reference Method 25A. A J.U.M. Model 3-500 flame ionization detector (FID) analyzer was used to monitor the boiler exhaust. Sample gas was extracted through a heated probe. A heated teflon sample line was used to transport the exhaust gases to the analyzer. The analyzer produces instantaneous readouts of the VOC concentrations (PPM).

The analyzer was calibrated by system injection (from the back of the stack probe to the analyzer) prior to the testing. A span gas of 94.9 PPM was used to establish the initial instrument calibration. Calibration gases of 30.2 PPM and 50.6 PPM were used to determine the calibration error of the analyzer. After each sample, a system zero and system injection of 30.2 PPM were performed to establish system drift and system bias during the test period. All calibration gases used were EPA Protocol Propane Calibration Gases. Three (3) samples were collected from the boiler exhaust. Each sample was sixty (60) minutes in duration.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler exhaust. All reference method data was corrected using Equation 7E-5 from U.S. EPA Method 7E. Figure 2 is a diagram of the Method 25A VOC sampling train.

IV.3 Metals – The metals emission sampling was conducted by employing U.S. EPA Method 29. This is an out of stack filtration method, where the sampling probe and filter are heated at 250 °F (plus or minus 25 °F).

The samples were collected isokinetically on quartz filters, and in a nitric acid/hydrogen peroxide solution and an acidic potassium permanganate solution. The nozzle/probe rinses, filters and nitric acid/hydrogen peroxide solutions were analyzed for all the above listed metals by inductively coupled argon plasma/mass spectrophotometry (ICAP/MS) analysis in accordance with Method 29. The nozzle/probe rinses, filters, nitric acid/hydrogen peroxide solutions, and acidic potassium permanganate solutions were analyzed for mercury (Hg) by cold vapor atomic absorption spectroscopy (CVAAS) analysis in accordance with Method 29. All the quality assurance and quality control procedures listed in the method were incorporated in the sampling and analysis. Figure 3 is a diagram of the metals sampling train.

IV.4 Dioxins, Furans & Benzo-A-Pyrene – The PCDD's/PCDF's (polychlorinated dibenzo-p-dioxins and polychlorinated dibenzofurans: 2,3,7,8 substituted congeners from the Tetra through Octa homologs) and benzo-a-pyrene emission sampling was performed in accordance with U.S. EPA Method 23. A Modified Method 5 (MM5) sampling train, as described in Method 23, was used to collect the samples. The sampling train consisted of a heated glass lined probe followed by a heated pre-cleaned quartz filter. A condenser coil followed by an XAD sorbent trap followed the heated filter. An impinger train containing HPLC water followed the XAD trap. All sampling train components were pre-cleaned in accordance with the method.

Three (3) samples were collected. Each sample was sixty (60) minutes in duration, and had a minimum sample volume of thirty (30) dry standard cubic feet. The sampling system operation was consistent with U.S. EPA Method 5. The three samples and the blank train were recovered in pre-cleaned sample bottles with Teflon lined caps. The probe rinse and filter rinse were combined with the XAD extract for analysis. The back-half impinger condensate was also analyzed. The analytes were extracted from the sample, separated by high resolution gas chromatography, and measured by high resolution mass spectrometry. The analysis followed the procedures of SW-846 Method 8290. All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis. Figure 4 is a diagram of the Method 23 sampling train.


IV.5 Sulfuric Acid – The sulfuric acid determinations were conducted in accordance with U.S. EPA Method 8. The exhaust gas was extracted through a heated probe which led to an impinger train. The first impinger contained 80% isopropyl alcohol (IPA), which is where the sulfuric acid was collected. The samples were collected isokinetically as described in the method. Immediately following each sample, a

fifteen (15) minute purge (at approximately the average sampling rate) using ambient air was performed on the impinger train. The purge is designed to remove any SO₂ that might remain in the first impinger. The samples were analyzed for sulfate using HPLC analysis (Method ALT-133). Three (3) samples, were collected. Each sample was sixty (60) minutes in duration and had a minimum sample volume of thirty (30) dry standard cubic feet. All the quality assurance and quality control requirements of the method will be incorporated in the sampling and analysis. The sulfuric acid sampling train is shown in Figure 5.

IV.6 Exhaust Gas Parameters – The exhaust gas parameters (air flow rate, temperature, moisture and density) were determined in conjunction with the other sampling by employing U.S. EPA Methods 1 through 4. Air flow rates, temperatures, moistures and densities were determined using the isokinetic sampling trains. Bag samples were collected from the exhaust of the isokinetic sampling trains and analyzed for O₂ and CO₂ by Orsat. Moisture, temperature and air flow rates were also determined using the isokinetic sampling trains.


All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis.

This report was prepared by:



David D. Engelhardt
Vice President

This report was reviewed by:



Stephan K. Byrd
President